

# Housing Authority of the City of Pittsburgh

Contracting Officer  
100 Ross Street  
2<sup>nd</sup> Floor Suite 200  
Pittsburgh, PA 15219  
(412) 456-5116  
Fax: (412) 456-5007  
[www.hacp.org](http://www.hacp.org)

**September 26, 2013**

## **Parking Lot Drainage Repairs at Allegheny 3 Quote Bid**

### **ADDENDUM NO.1**

This addendum issued September 26, 2013 becomes in its entirety a part of the 3 quote bid request as is fully set forth herein:


**Item 1:** Scope of Work Clarification –

- The catch basin in the upper parking lot is to be connected to the new inlet that is located at the parking area located at the bottom of the steps.
- The drawings are intended to familiarize the bidder with the area of the work and are otherwise not intended to prescribe means/methods.
- Scope data is intended as a frame of reference and establishes limits for bidding purposes but is not intended to represent exact existing conditions with regard to quantities, dimensions, and depths required for the performance of the work. Contractor is required to field verify conditions, quantities, dimensions, and depths.
- There will be no lateral drop to flow line.
- Grout in existing outlet when done.
- Work is permitted to go off of existing inlet to help the flow.
- Contractor to perform the means necessary to provide the connections minimizing concrete cuts.
- Cleanouts to be provided include the location at the half way point from the catch basin in the upper parking lot and at the below location prior to the connection to the new inlet.
- Lamp hole covers are to be provided.
- Revise 600 linear feet of 8" SDR 35 pipe to 300+/- linear feet of 8" SDR 35 pipe as a basis for bidding.

**Item 2:** The proposal due date is remains unchanged at September 27, 2013 at 2 pm.

---

**END OF ADDENDUM NO. 1**

  
\_\_\_\_\_  
Mr. Kim Detrick  
Procurement Detrick/Contracting Officer

9/26/13  
\_\_\_\_\_  
Date