

Housing Authority of the City of Pittsburgh

Contracting Officer
100 Ross Street
2nd Floor Suite 200
Pittsburgh, PA 15219
(412) 456-5248
Fax: (412) 456-5007
www.hacp.org

Nov. 15, 2013

Bedford Dwellings Window Replacement & Masonry Repairs IFB#600-27-13


ADDENDUM NO.2

This addendum issued November. 15 2013 becomes in its entirety a part of the Invitation for Bids IFB#600-27-13 as is fully set forth herein:

- Item 1:** Q: Regarding conduit for cable and lighting run around each building and at locations where masonry repairs and lintel replacement occurs:
- Is the masonry contractor/general contractor permitted to remove the conduits during the repair and then reinstall?
A: Yes, please see 04 01 20.63, 3.1.C.1. All other masonry sections must conform to this provision.
- Item 2:** Q: Is a licensed electrician or power company required to do this work?
A: Please see 04 01 20.63, 3.1.C.1
- Item 3:** Q: On the side of each building are electrical entrance cables, lighting boxes, cable and phone boxes, conduits and etc.:
A: The contractor shall remove and reinstall this fascia under this contract.
- Item 4:** Q: Has the existing plaster returns on the window openings been tested for lead if so and it is positive what is the procedure for any disturbance that may result during the window and asbestos work?
A: Yes, the window openings have tested positive for ACM, but except that the contractor must coordinate it's work with the ACM Abatement Contractor.

Item 5: The bid due date, time and location remain unchanged at November 20, 2013 at 10:00 AM. at the HACP Procurement Dept., 100 Ross St. 2nd Floor, Suite 200, Pittsburgh, PA 15219.

END OF ADDENDUM NO. 2

A handwritten signature in black ink, appearing to read "Kim Detrick", is written over a horizontal line.

Mr. Kim Detrick.
Procurement Director/Contracting Officer

November 15, 2013

Date