

Housing Authority of the City of Pittsburgh

Contracting Officer
100 Ross Street
2nd Floor Suite 200
Pittsburgh, PA 15219
(412) 456-5248
Fax: (412) 456-5007
www.hacp.org

July 24, 2015

Caliguri Windows and Façade Replacement PA-1-41 RFP#600-19-15GE

ADDENDUM NO.4

This addendum issued July 24, 2015 becomes in its entirety a part of the Invitation for Bid IFB #600-19-15GE as is fully set forth herein:


Item 1: The bid due date, is revised to August 11, 2015. The time and location remain unchanged at 2:00 PM at the HACP Procurement Dept., 100 Ross St. 2nd Floor, Suite 200, Pittsburgh, PA 15219.

Item 2: A 3rd site visit is scheduled for Thursday July 30, 2015 at 10 a.m. at Caliguri Plaza, 803 East Warrington Ave, Pittsburgh PA 15210.

Item 3: Question: "Please advise if the "FIRE JOINT SPRAY" on detail 5/A510 refers to specification section 078446 Fire-resistive Joint Systems. Thank you!"

Answer: Yes, the detail does refer to the 078446 Fire-Resistive Joint Systems specification. Specifically, 2.1, C Joints at Exterior Wall/Floor Intersections.

END OF ADDENDUM NO. 4


Mr. Kim Detrick
Procurement Director/Contracting Officer

7-24-15
Date