



Housing Authority of the City of Pittsburgh

Contracting Officer
100 Ross Street
2nd Floor Suite 200
Pittsburgh, PA 15219
(412) 456-5248
Fax: (412) 456-5007
www.hacp.org

October 4, 2017

Emergency Generator & Fire Pump Maintenance and Emergency Repairs IFB#300-43-17

ADDENDUM NO. 2

This addendum issued October 4, 2017 becomes in its entirety a part of the Invitation for Bid IFB #300-43-17 as is fully set forth herein:

Item 1: Q: There are two discrepancies on page 33 regarding the generator kW. Carrick Regency and Gualtieri Manor have both been replaced with 150kW generators. Also Brookline Mazza has a 200kW generator, TBD is listed on the sheet.

A: Carrick and Gualtieri are 150 KW Generators
Mazza is 200 KW Generator

Item 2: Q: As this is an annual visit, the ability to gather proper information for the PM's is needed in order to ensure the proper procurement of parts. In order to do this, the model and serial number of each item listed for bid is needed. Is there a list that contains the model and serial number (also spec number for Kohler and Onan/Cummins units) for both generators and engine?

A: Morse Gen MGR ONAN, Gen Model# DGFA-5769155 Gen S/N G060951125 ENG MGR, Cummins ENG Model # 6CTA8.3-P2 ENG S/N 46645169

Mazza GEN MGR # Cummins GEN Model # DSHAC-6113337, GEN S/N K100172537 ENG MFR Cummins, ENG Model # QSL9-G2-NR3, ENG S/N 73158051.

Finello FP – GEN MFR Peerless, GEN Model # 4AEF12, GEN S/N 482832, ENG MFR Detroit ENG Model # 5034-8312 ENG S/N 3D212373.

Caliguiri GEM MFR ONAN, GEN Model # DFEJ-5769157, GEN S/N J060977254, ENG MFR Cummins ENG Model # QSB7-G5NR3 ENG S/N 73334694

Glen Hazel High Rise – GEN MFR Kohler GEN Model #200R0ZD81 GEN S/N 385842, ENG MFR Detroit ENG Model # 10637305 ENG S/N 06A0473719.

Gualtieri – GEN MFR Cummins, GEN Model # DSGAC – 9576809, GEN S/N L110279552, ENG MFR Cummins ENG Model # QSB7-G5NR3 ENG S/N 73334694

Carrick – GEN MFR ONAN GEN Model # DPFA – 5769154 GEN S/N P0G0951127, ENG MFR Cummins, ENG Model # 6CTA8.3-P2 ENG S/N 4GG45167

Northview – GEN MFR ONAN GEN Model #50DGCA GEN S/N F970642312. ENG MFR Cummins ENG Model # 4BT3.9 ENG S/N 45537336.

Pressley High Rise FP – GEN MFR Peerless GEN Model # DDFP-03DT-5068F GEN S/N 3D212375, ENG MFR Detroit ENG Model # 5034-8312 ENG S/N 3D212375

Northview FP – GEN MFR Peerless (FP) GEN Model # 3X6yRHGEN S/N FP-C109-002 ENG MFR CAT ENG Model # 3208DINA ENG S/N 90N75214

Bidwell – GEN MFR Kohler GEN Model # 250R0ZD81 GEN S/N 333874, ENG MFR Detroit ENG Model #8063-7305 ENG S/N 6VF203257

Murray – GEN MFR ONAN / Cummins GEN Model # DGCA- 5769156, GEN S/N G060951126, ENG MFR Cummins ENG Model # 4BT3.9 ENG S/N 46644568.

Murray FP GEN MFR Clarke, GEN Model # DDFP-63DT-5068F, GEN S/N 3D-212374, ENG MFR Detroit ENG Model # 5034-8312, ENG S/N 3D0212374.

Pressley – GEN Onan GEN Model #50GDD, GEN S/N I000145592, ENG MFR Cummins ENG Model # GBT5.9-G6, ENG S/N 46022504.

Finello – GEN MFR Onan, GEN Model # 75.0ENT-15R, GEN S/N D850756967, ENG MFR Ford, ENG Model # LSG-8751-6005-A, ENF S/N 03805 L-7-TC

Item 3: Q: Where is the location of the units rooftop, basement, outside, etc.?

A: **Northview – Basement**
Northview Store – Outside
Bidwell – Ground Floor
Pressley – Outside
Murray Towers – Ground Floor
GlenHazel – Outside
Mazza – Outside
Caliguiri – Basement Ground Floor
Finello – Basement
Morse – Outside
Carrick – Ground Floor
Gualtieri - Outside
Northview – FP – Basement
Pressley FP – Basement
Murray FP – Ground Floor
Finello FP – Ground Floor

Item 4: Q: As the company I work for is ultimately a subsidiary of a much larger corporation, the demographic questions can be quite extensive. However, our office is located in Maryland and would be the representative covering this area. Do we have to complete this sheet for the entire company or just the regional office?

A: Yes

Item 5: Q: Is the testing for each done as performed under full load?

A: Yes

Item 6: Q: Can you please forward me a list of M/WBE sub contractors for towing and delivery services

A: Please check the Pennsylvania Unified Certification Program (PA UCP) website: www.dotsbe.pa.gov/PAUCPWeb/paucp/viewHome.do

Item 7: The proposal due date is changed to October 12, 2017, and the time and location remain unchanged at 10:00 AM at the HACP Procurement Dept., 100 Ross St. 2nd Floor, Suite 200, Pittsburgh, PA 15219.

END OF ADDENDUM NO. 2



Mr. Kim Detrick
Procurement Director/Contracting Officer



Date