



Housing Authority of the City of Pittsburgh

Contracting Officer
100 Ross Street
2nd Floor Suite 200
Pittsburgh, PA 15219
(412) 456-5248
Fax: (412) 456-5007
www.hacp.org

November 21, 2013

Glen Hazel Siding Replacement and Door Painting IFB#600-23-13


ADDENDUM NO.4

This addendum issued November 21, 2013 becomes in its entirety a part of the Invitation for Bids IFB#600-23-13 as is fully set forth herein:


- Item 1:** Q: On DWG A2.1, states "ALL NEW WOOD TO HAVE WATERPROOFING APPLIED". Is there a specification for what you want us to use?
A: See Division 06-Wood and plastics, Part 2-Products 2.1 Wood products, General, C.
- Item 2:** Q: Will any drywall or plaster patching be required on the interior of units for new hose bib installation?
A: Incidental drywall/plaster patching will be required for new hose bib installation.
- Item 3:** Q: Note 17 on D1.1 states "CONTRACTOR SHALL REMOVE ANY PLYWOOD OVER EXISTING WINDOWS AND/OR DOORS. REINSTALL AS PER HACP DIRECTION". On the elevations the 17 is pointing at canopies? Are we removing and reinstalling plywood over same windows and/or doors? Please clarify
A: On the elevations the number should be 16 not 17 when indicating the canopies. Note 17 is correct under General Demolition Notes
- Item 4:** Q: How do we know how much framing to replace at canopies per 4/D2.1
A: The drawing describes the specific amount of framing

Item 5: The bid due date and time has changed from November 21, 2013 to November 25, 2013 at 11:00 AM. The location will remain unchanged at the HACP Procurement Dept., 100 Ross St. 2nd Floor, Suite 200, Pittsburgh, PA 15219.

END OF ADDENDUM NO. 4



Mr. Kim Detrick.
Procurement Director/Contracting Officer



Date