Quote Request

Parts and Labor for Fire Panel at Gualtieri Manor

Quotes due March 12, 2014 @ 9:00 a.m.

Fax to Debbie Norkevicus at (412) 456-5007

Scope of Work

Provide the Following:

- Vendor will supply the equipment necessary for installation, programming, and final testing of fire panel.
- This is for the installation of the new fire panel to repair the existing fire control panel, which cannot be repaired with replacement components because they are no longer available.
- Fire panel should be new SAFELINC Internet Interface (or equivalent) and a service modem.
- A new LCD annunciator will be installed in the building vestibule.
- Installation of all devices, wiring, conduit and fixtures will be the responsibility of the Vendor.
- This new fire panel must be compatible with existing "Auto-Call" system.
- Gualtieri Manor is located at 2521 Los Angeles Street, Pittsburgh, PA 15216.
- Work area to be left in a clean and safe condition
- No debris to be place in HACP trash receptacles
- Vendor is responsible for obtaining all required permits
- Cost of bid/quote preparation will not be reimbursed.

Please contact Debbie Norkevicus at 412.456.5000 ext 8505 or Debbie.Norkevicus@HACP.org with any questions about the above scope.

Parts and Labor for Fire Panel at Gualtieri Manor

(Due 3/12/15 @ 9:00 AM)

Total for equipment, labor a	nd testing:
Total for equipment, labor a	nd testing:(in words)
	(in words)
B	Bid Award Based off of lowest bid total Bid amount
(Please print clearly) Company Name:	
Signature:	
Print Name:	
	(of person signing)
Address:	
	(of company)
Phone Number:	Fax:
Email:	