



# Housing Authority of the City of Pittsburgh

Contracting Officer  
100 Ross Street  
2<sup>nd</sup> Floor Suite 200  
Pittsburgh, PA 15219  
(412) 456-5248  
Fax: (412) 456-5007  
www.hacp.org

May 18, 2016

**SMOKE DETECTOR AND FIRE EXTINGUISHER UPGRADES AT  
GLEN HAZEL FAMILY COMMUNITY PA-1-32  
IFB#300-28-16**


**ADDENDUM NO.2**

This addendum issued May 18, 2016 becomes in its entirety a part of the Invitation for Bid IFB #300-28-16 as is fully set forth herein:

**Item 1:**    **Q:**    Are the smoke detectors 110V, low voltage or just battery operated?  
              **A:**    Smoke detectors are battery operated.

**Item 2:**    The proposal due date, time and location remain unchanged May 27, 2016, 10:00 AM at the HACP Procurement Dept., 100 Ross St. 2<sup>nd</sup> Floor, Suite 200, Pittsburgh, PA 15219.

**END OF ADDENDUM NO. 2**

  
\_\_\_\_\_  
Mr. Kim Detrick  
Procurement Director/Contracting Officer

5-18-16  
\_\_\_\_\_  
Date