



Contracting Officer  
100 Ross Street, Suite 200  
Pittsburgh, PA 15219  
(412) 456-5248  
www.hacp.org

November 21, 2011

**Switchboard Replacement at the Bidwell Highrise  
IFB#600-30-11 E**

**ADDENDUM NO. 3**

This addendum issued November 21, 2011 becomes in its entirety a part of the Invitation to Bid IFB#600-30-11E as is fully set forth herein:

**Item 1: Q:** Are current limiter's required on each phase conductor at the secondary termination point at the transformer and at the line side of the main disconnecting means?

A: Current limiters are not a Duquesne Light requirement at Bidwell

**Item 2:** The Bid due date, time and location remains unchanged at Monday, November 28 at 3:30 pm at the HACP Procurement Dept., 100 Ross St. 2<sup>nd</sup> Floor, Suite 200, Pittsburgh, PA 15219.

**END OF ADDENDUM NO. 3**

A handwritten signature in black ink, appearing to read 'William D. McDanel', is written over a horizontal line.

William D. McDanel  
Contracting Officer

11/21/2011  
Date