



Housing Authority of the City of Pittsburgh

Contracting Officer
100 Ross Street
2nd Floor Suite 200
Pittsburgh, PA 15219
(412) 456-5248
Fax: (412) 456-5007
www.hacp.org

May 18, 2015

Underground Gas Line Certification and Detection Rebid IFB#300-12-15 Rebid

ADDENDUM NO.1

This addendum issued May 18, 2015 becomes in its entirety a part of the Invitation for Bid IFB #300-12-15 Rebid as is fully set forth herein:

Item 1: Q. When looking through the bid -page 33 is a new page that lists additional locations that were not on the original bid – page 29 is the list that was on the original bid.- The locations don't all seem to match. Can you please clarify which locations we are bidding on.

A. Please see Attachment A to this addendum.

Item 2: The proposal due date, the time and location remain unchanged at May 29, 2015 at 11:00 AM at the HACP Procurement Dept., 100 Ross St. 2nd Floor, Suite 200, Pittsburgh, PA 15219.

END OF ADDENDUM NO. 1


Mr. Kim Detrick
Procurement Director/Contracting Officer

May 18, 2015
Date

Attachment A

Revised Technical Specifications Attachment 2

**(IFB #300-12-15Rebid Underground Gas Line
Certification and Detection Rebid**

**ATTACHMENT 2
TECHNICAL SPECIFICATIONS**

REVISED
5-18-15

Scope of Work

- Contractor should have two (2) Operator Certifications, one for leak detection, and one for location, atmospheric corrosion, flame ionization and main location under Federal regulations section 191 & 192.
- Work will be performed at the following HACP locations:
 - Bedford Dwellings
 - Arlington Heights
 - Allegheny Dwellings
 - Northview Heights
 - PA Bidwell
 - Pressley
 - Homewood North
 - Murray Towers
 - Glen Hazel Community
 - Glen Hazel High-rise
 - Mazza Pavilion
 - Caliguiri High-rise
 - Finello Pavilion
 - Morse Gardens
 - Carrick Regency
 - Gualtieri Manor
- Work will begin immediately after scheduling call is made and all work will be completed within forty-five (45) days.
- Work will consist of approximately 16,000' to 18,000' of medium of low pressure underground gas lines and risers, with approximately 220 services.
- HACP will provide blue prints, as lines will need to be identified, traced and tested.
- HACP will be provided all test results.
- Any deficiencies will be noted on the written report.
- All work to be scheduled through a Facility Services Supervisor.