



Housing Authority of the City of Pittsburgh

Contracting Officer
100 Ross Street
2nd Floor Suite 200
Pittsburgh, PA 15219
(412) 456-5248
Fax: (412) 456-5007
www.hacp.org

May 9, 2017

Window Removal and Installation at Various Units in Northview Heights Rebid IFB #300-09-17 Rebid


ADDENDUM NO.1

This addendum issued May 9, 2017 becomes in its entirety a part of the Invitation for Bid for IFB #300-09-17 Rebid as is fully set forth herein:


- Item 1:** **Q:** Is Contractor expected to wrap exterior trim?
 A: Yes, contractor to wrap or complete close on gaps with coil stock.
- Item 2:** **Q:** Is Contractor expected to paint inner trim?
 A: No, all trim and caulking, interior or exterior to match all new window trim
on site (brown).
- Item 3:** **Q:** Is contractor responsible for purchasing windows and/or any materials
(paint and/or aluminum wrap) for trim treatment?
 A: Yes, paints not to be used.
- Item 4:** **Q:** Does make of windows matter?
 A: No.
- Item 5:** **Q:** Can we purchase a dumpster and leave it on site until full?
 A: Yes.
- Item 6:** **Q:** Does contractor need to be lead certified?
 A: Yes.

Item 7: The proposal due date is changed to May 16, 2017 and the time and location remain unchanged at 1:00 PM at the HACP Procurement Dept., 100 Ross St. 2nd Floor, Suite 200, Pittsburgh, PA 15219.

END OF ADDENDUM NO. 1



Mr. Kim Detrick
Procurement Director/Contracting Officer



Date