



Housing Authority of the City of Pittsburgh

Contracting Officer
100 Ross Street
2nd Floor Suite 200
Pittsburgh, PA 15219
(412) 456-5248
Fax: (412) 456-5007
www.hacp.org

June 27, 2018

Window Replacement at 2825 Murray Towers #302

ADDENDUM NO.4

This addendum issued June 27, 2018 becomes in its entirety a part of the 3 Quote Bid as is fully set forth herein:


Item 1: Q: Can you tell me the brand of the current windows?
A: Pella Impervia


Item 2: Q: Is nail flange required?
A: No

Item 3: Q: Glass type?
A: Advance Low E w/Argon

Item 4: The proposal due date, time, and location remain unchanged at July 17, 2018, at 11:00 AM at the HACP Procurement Dept., 100 Ross St. 2nd Floor, Suite 200, Pittsburgh, PA 15219.

END OF ADDENDUM NO. 4


Mr. Kim Detrick
Procurement Director/Chief Contracting Officer


Date