



Housing Authority of the City of Pittsburgh

Contracting Officer
100 Ross Street
2nd Floor Suite 200
Pittsburgh, PA 15219
(412) 456-5248
Fax: (412) 456-5007
www.hacp.org

January 7, 2019

Removal of Asbestos Containing Material in Northview Heights (Forced Accounts) IFB #300-41-18

ADDENDUM NO.1

This addendum issued January 7, 2019 becomes in its entirety a part of the Request for Proposals IFB #300-41-18 as is fully set forth herein:

Item 1: Q: How many sq. ft. of material?
A: **there could be several layers of non ACM materials and one layer of ACM tile and mastic**

Item 2: Q: Is there mastic on the underlayment on the sub-floor?
A: **until tested for ACM, there is mastic on wooden sub floors. Contractor will remove the bulk of mastic from sub floor and encapsulate**

Item 3: Q: What is the schedule?
A: **once selected contractor is awarded contract, we will schedule**

Item 4: Q: Start date for the abatement?
A: **ten days after contractor submits for county permits**


Item 5: Q: Is there a phasing?
A: **Yes we will turnover five (5) units at a time**

Item 6: Q: Are there any drawings?
A: **no**

Item 7: Q: Final air is by who?
A: **Final air clearance will be performed by third party**

Item 8: The proposal due date is changed to January 15, 2019, time and location remain unchanged at 10:00 AM, at the HACP Procurement Dept., 100 Ross St. 2nd Floor, Suite 200, Pittsburgh, PA 15219.

END OF ADDENDUM NO. 1


Mr. Kim Detrick
Procurement Director/Chief Contracting Officer

1-7-19
Date