



Housing Authority of the City of Pittsburgh

Contracting Officer
100 Ross Street
2nd Floor Suite 200
Pittsburgh, PA 15219
(412) 456-5248
Fax: (412) 456-5007
www.hacp.org

January 29, 2019
Misc. Concrete Leveling Services Authority Wide
IFB #300-02-19

ADDENDUM NO.2

This addendum issued January 29, 2019 becomes in its entirety a part of the Invitation for Bid IFB #300-02-19 as is fully set forth herein:

- Item 1:** Q: Is there a minimum sq foot / job?
A: **No minimal - it varies per job.**
- Item 2:** Q: Aside from leveling, will there be any demolition and redo ?
A: **Yes, demolition, prep. (forming and base prep)**
- Item 3:** Q: Is there approximate maximum depth of repairs?
A: **No it will vary per job.**
- Item 4:** Q: What is the anticipated frequency of jobs?
A: **Very frequent – a lot of jobs Authority Wide.**
- Item 5:** Q: -Will projects be batched?
A: **Yes**
- Item 6:** Q: -Is it possible to see any actual sites where work will be done?
A: **Yes – Site visit will happen before work is done**
- Item 7:** Q: Demo and replace concrete steps price per square foot?
A: **Yes**
- Item 8:** Q: Demo and replace concrete sidewalk and/or slabs price per square foot?
A: **Yes**
- Item 8:** Q: Demo and replace concrete handicap ramps with detectable mats price per square foot?
A: **Yes**

Item 9: Q: Demo and replace concrete curbing per linear foot at different depths and widths?
A: Yes - as per City specifications

Item 10: Q: Requirements for different grades of concrete example 4000 vs 3200 PSI?
A: The majority of work 4000. (3500 for footer)


Item 11: Q: Requirements for different concrete reinforcement?
A: Yes as per specific drawing plans etc....

Item 12: Q: Decorative concrete (example stamped, exposed aggregate) vs standard finish concrete?
A: Standard - except for exposed aggregate where applicable.

Item 13: Q: Situations regarding overlaying of existing concrete?
A: Usually we don't. If acceptable in plans.

Item 14: The proposal due date is changed to February 8, 2019. Time and location remain unchanged at 11:00 AM, at the HACP Procurement Dept., 100 Ross St. 2nd Floor, Suite 200, Pittsburgh, PA 15219.

END OF ADDENDUM NO. 2


Mr. Kim Detrick
Procurement Director/Chief Contracting Officer

1-29-19
Date