

Housing Authority of the City of Pittsburgh

Contracting Officer
100 Ross Street
2nd Floor Suite 200
Pittsburgh, PA 15219
(412) 456-5248
Fax: (412) 456-5007
www.hacp.org

Natural Gas Inspection Program Authority Wide 3 Quote Bid

ADDENDUM NO.4

This addendum issued January 29, 2019 becomes in its entirety a part of the 3 Quote Bid as is fully set forth herein:

Item 1: Q: Looking at the quote request, I'm seeing that the work includes locating 18,000' of underground gas lines with 220 services. Are the services additional to the 18,000' of main line or included in it?

A: All together

Item 2: Q: When a leak is detected, what would be our next step in the process?

A: Notify HACP.

Item 3: Q: Do your plastic lines have wire laid with them and some sort of location box to help locate?


A: Yes

Item 4: Q: It also says lines will be tested. Why are you testing these lines? Who would be responsible to light the appliances if we had to shut the line down?

A: The gas is never turned off during this process. To be compliant with federal regulations.

Item 5: The proposal due date time, and location remain unchanged at February 4, 2019 at 11:00 AM, at the HACP Procurement Dept., 100 Ross St. 2nd Floor, Suite 200, Pittsburgh, PA 15219.

END OF ADDENDUM NO. 4


Mr. Kim Detrick

Procurement Director/Chief Contracting Officer

1-29-19

Date