



Housing Authority of the City of Pittsburgh

Contracting Officer
100 Ross Street
2nd Floor Suite 200
Pittsburgh, PA 15219
(412) 456-5248
Fax: (412) 456-5007
www.hacp.org

May 13, 2019

Northview Heights Building #74 Upgrades IFB #600-10-19

ADDENDUM NO.2

This addendum issued May 13, 2019 becomes in its entirety a part of the Invitation for Bids IFB #600-10-19 as is fully set forth herein:

Item 1: **Q:** DWG A-6 Door Schedule Notes 6 and 7 state to refer to the electrical drawings for more info on the key-fob system, however there is no details or symbols related to the key-fob system on the electrical drawings, only the vide entry system.

A:

1. **Add the following New Work Keyed Note to drawings E100 (keyed note 7) and E101 (keyed note 6). Add the keyed note symbol adjacent to the existing location of New Work Keyed Notes 5 and 6:**

 “See specification section 16702 – Tenant Door Entry Keying System – for details concerning the FOB (keyless entry devices) and all items related to the door entry system requirements. This system shall be compatible with the present hardware that the HACP provides.”
2. **On drawing E100, modify New Work Keyed Note 6 as follows – change the specification section reference in the last sentence of the note from section 13825 to sections 16701 and 16702.**
3. **On drawing E101, modify New Work Keyed Note 4 as follows – change the specification section reference in the last sentence of the note from section 13825 to sections 16701 and 16702**

Item 2: Q: DWG A-6 has multiple doors noted as getting electric strikes but no key-fob readers. Are there existing key-fob readers in these locations or will the electrical contract be required to provide readers for all doors getting electric strikes?


A:

1. The requirement for the key fob access is delineated in Specification Section 16702. All doors in the door schedule on drawing A-6, receiving electric strikes, shall have access as described in Section 16702.
2. In Specification Section 16702 – add the following paragraph:

2.5. D. Provide a minimum of 50 (fifty) FOBs to the HACP – for programming by their internal staff at the completion of the project. The HACP Locksmith shall be integral to the review/approval process for these components and all features of the system that will be their responsibility.

Item 3: The proposal due date, time, and location remain unchanged at May 23, 2019, at 11:00 AM, at the HACP Procurement Dept., 100 Ross St. 2nd Floor, Suite 200, Pittsburgh, PA 15219.

END OF ADDENDUM NO. 2


Mr. Kim Detrick
Procurement Director/Chief Contracting Officer

5-13-19
Date