



## Housing Authority of the City of Pittsburgh

Contracting Officer  
100 Ross Street  
2<sup>nd</sup> Floor Suite 200  
Pittsburgh, PA 15219  
(412) 456-5248  
Fax: (412) 456-5007  
www.hacp.org

July 8, 2019

### Homewood Window Replacements, AMP-20 IFB #600-14-19

#### ADDENDUM NO.3

This addendum issued July 8, 2019 becomes in its entirety a part of the Invitation for Bids IFB #600-14-19 as is fully set forth herein:

**Item 1:** Q: The drawing of ours that is listed in the specs shows a single point release latch that we no longer manufacture with. Attached is our drawing of our upgrade.

A: Upgrade screen drawing and specification have been received.

**Item 1:** Q: Are these security screens to be top or center hinge?

A: Screens should be center hinged.

**Item 1:** Q: Window "A" type, what do you require the operation to be?


A: Window "A" is a sliding window – used only on the upper level windows.  
This window will never receive a security screen.

**Item 1:** Q: Will these be mounted using a Sub-frame?

A: The screens should be mounted with a sub-frame.

**Item 3:** The proposal due date is changed to July 17, 2019, time and location remain unchanged at 2:00 P.M., at the HACP Procurement Dept., 100 Ross St. 2nd Floor, Suite 200, Pittsburgh, PA 15219.

END OF ADDENDUM NO. 3

  
Mr. Kim Detrick

Procurement Director/Chief Contracting Officer

7-8-19  
Date