



Housing Authority of the City of Pittsburgh

Contracting Officer
100 Ross Street
2nd Floor Suite 200
Pittsburgh, PA 15219
(412) 456-5248
Fax: (412) 456-5007
www.hacp.org

March 2, 2020

Northview Heights Building #74 Upgrades Rebid IFB #600-42-19-REBID

ADDENDUM NO.1

This addendum issued March 2, 2020 becomes in its entirety a part of the Invitation for Bids IFB #600-42-19-REBID as is fully set forth herein:

Item 1: Q: Page A6 makes a distinction between "exterior" entry doors and single tenant entry doors. Our door vendor would like confirmation that this distinction excludes the tenant entry doors from bituminous black coating, and are not required to be grouted. Please Confirm.

A: All exterior hollow metal door frames shall receive the bituminous coating and grout. The interior tenant entry doors do not. See jamb and head details provided in the bid document.

Item 2: The bid due date, time, and location remain unchanged at March 9, 2020, at 2:00 PM, at the HACP Procurement Dept., 100 Ross St. 2nd Floor, Suite 200, Pittsburgh, PA 15219.

END OF ADDENDUM NO. 1

Mr. Kim Detrick
Procurement Director/Chief Contracting Officer

3-2-2020

Date