



Housing Authority of the City of Pittsburgh

Contracting Officer
100 Ross Street, 2nd Floor Suite 200
Pittsburgh, PA 15219
(412) 456-5116
www.hacp.org

November 18, 2021

Northview Heights Roof Replacement Project IFB #600-31-21

ADDENDUM NO. 4

This addendum issued November 18, 2021 becomes in its entirety a part of the IFB #600-31-21 as is fully set forth herein:

Item 1: Q: Can you please verify that there is currently no insulation board on the roofs and that the roofs currently only have one layer of roofing material?

A: There is no insulation shown on the original Drawings, which indicate 7/8" T & G Sheathing (1/2' plywood – option) and a built-up roof. It looks like from the pic of the "core drill" there was some sort of protection board under the existing top surface roofing material. I can't verify if the original roofing material was removed.

Item 2: The bid due date, time, and location remain unchanged at 10:00 AM on November 30, 2021, at the HACP Procurement Dept., 100 Ross St. 2nd Floor, Suite 200, Pittsburgh, PA 15219.

Item 3: The Housing Authority of the City of Pittsburgh will **only be accepting physical bids dropped off in person from 8:00 AM until the closing time of 10:00 AM on November 30, 2021** in the lobby of 100 Ross St. Pittsburgh, PA 15219. Bids may be submitted via Dropbox at <https://www.dropbox.com/request/thgOVKEK6nOmZrQhSsA> and may still be mailed via USPS at which time they will be Time and Date Stamped at 100 Ross Street 2nd Floor, Suite 200, Pittsburgh, PA 15219. All bids must be received at the above address no later than November 30, 2021 at 10:00 AM regardless of the selected delivery mechanism.

END OF ADDENDUM NO. 4

Kim Detrick

Kim Detrick (Nov 18, 2021 12:53 EST)

Mr. Kim Detrick
Procurement Director/Chief Contracting Officer

Nov 18, 2021

Date