


Quote Request

Professional Lead-Based Paint Risk Assessment for the Manchester Neighborhood

Quotes due December 21, 2021 at 10:00 AM



Email bids to Brandon.Havranek@hacp.org

Scope of Work

Due to the potential health hazard presented by lead contaminants, The Housing Authority of the City of Pittsburgh (HACP) seeks to engage a qualified vendor to perform Professional Environmental Services for a Lead-Based Paint (LBP) Risk Assessment stated herein for properties located in the Manchester neighborhood of the City of Pittsburgh, Allegheny County, Pennsylvania.

The selected vendor shall conduct a Lead Risk Assessment which will include field inspections/sampling activities to be performed by a Certified Lead-Risk Assessor in accordance with EPA and HUD Regulations & Guidelines. Please see **Attachment A** for a property list.

Testing will measure concentrations of all deteriorated interior and exterior painted, varnished and friction surfaces through X-Ray Fluorescence (XRF) analysis; dust sampling through Lead Dust Wipe Sampling of interior floors/sills. Dust sampling is to be performed in accordance with ASTM Standards. For irregular surfaces or areas not accessible with an XRF, paint chip samples are to be collected and analyzed. Testing will be conducted in apartment units as well as common areas. In addition, composite soil samples will be collected from areas with bare soil (if present), along roof drip lines, high contact areas, and play areas.

Dust sample analyses are to be performed by a National Lead Laboratory Accreditation Program (NLLAP) laboratory.

Additional samples may be required as needed to sufficiently identify the extent of LBP hazards.

The selected vendor must generate a final report which will include the sample results, the locations of LBP hazards, hazardous control options and a cost estimate based on the results from the Risk Assessment.

The selected vendor shall review the previously conducted report of areas previously identified to potentially contain LBP. Please see **Attachment B** for the Lead-Based Paint Report completed by ATC Group Services, Inc. in September 2020.

All services performed must be in compliance with all applicable local, state, and federal laws and regulations including, but not limited to, Handicap Accessibility (Section 504), Americans with

For more information or questions, please contact Brandon Havranek at 412-643-2869 or Brandon.Havranek@hacp.org

Quote Request

Professional Lead-Based Paint Risk Assessment for the Manchester Neighborhood

Disabilities Act (ADA), Uniform Federal Accessibility Standards (UFAS), Davis-Bacon and minimum wage requirements, and Federal procurement requirements. In addition, all services must be performed in compliance with all applicable Commonwealth of Pennsylvania laws and regulations and local building code requirements.

The period of performance will commence upon the receipt of the Notice to Proceed and should be completed within 60 days thereafter. HACP is amenable to adjustments in the delivery schedule due to unforeseen weather conditions.

For more information or questions, please contact Brandon Havranek at 412-643-2869 or Brandon.Havranek@hacp.org

Quote Request

Professional Lead-Based Paint Risk Assessment for the Manchester Neighborhood

Quotes due 12/21/2021 at 10:00 AM

Total Cost: \$ _____

Total Cost: \$ _____
(in words)

**Contract award will be based on lowest responsive and responsible bid
amount**

(Please print clearly)

Company Name: _____

Address: _____
(of company)

Signature: _____

Print Name: _____
(of person signing)

Phone Number: _____ Fax: _____

Email: _____

For more information or questions, please contact Brandon Havranek at
412-643-2869 or Brandon.Havranek@hacp.org

Quote Request

**Professional Lead-Based Paint Risk Assessment for the Manchester
Neighborhood**

Attachment A – Property List

For more information or questions, please contact Brandon Havranek at
412-643-2869 or Brandon.Havranek@hacp.org

Address	Unit Type	Bedroom Size	Year Built
1327 Columbus Ave	Single Family Home	3 bed, 2 bath	1900
1325 Columbus Ave	Single Family Home	3 bed, 2 bath	1900
1323 Columbus Ave	Single Family Home	3 bed, 2 bath	1900
1100 Sheffield Street (15 units)	Multifamily, Unit #101	1 bed, 1 bath	1872
	Multifamily, Unit #102	1 bed, 1 bath	
	Multifamily, Unit #103	1 bed, 1 bath	
	Multifamily, Unit #104	1 bed, 1 bath	
	Multifamily, Unit #201	1 bed, 1 bath	
	Multifamily, Unit #202	1 bed, 1 bath	
	Multifamily, Unit #203	1 bed, 1 bath	
	Multifamily, Unit #204	1 bed, 1 bath	
	Multifamily, Unit #301	1 bed, 1 bath	
	Multifamily, Unit #302	1 bed, 1 bath	
	Multifamily, Unit #303	1 bed, 1 bath	
	Multifamily, Unit #304	1 bed, 1 bath	
	Multifamily, Unit #401	1 bed, 1 bath	
	Multifamily, Unit #402	1 bed, 1 bath	
	Multifamily, Unit #403	1 bed, 1 bath	
1111 Sheffield Street (3 units)	Multifamily, Unit #100	2 bed, 1 bath	1900
	Multifamily, Unit #200	2 bed, 1 bath	
	Multifamily, Unit #201	2 bed, 1 bath	
1130 Sheffield Street (3 units)	Multifamily, Unit #1	3 bed, 1 bath	1965
	Multifamily, Unit #2	3 bed, 1 bath	
	Multifamily, Unit #3	2 bed, 1 bath	
1132 Sheffield Street (3 units)	Multifamily, Unit #1	3 bed, 1 bath	1965
	Multifamily, Unit #2	3 bed, 1 bath	
	Multifamily, Unit #3	2 bed, 1 bath	
1134 Sheffield Street (2 units)	Multifamily, Unit A	4 bed, 1.5 bath	1965
	Multifamily, Unit B	4 bed, 1.5 bath	
1529 Sedgwick Street (2 units)	Multifamily, Unit #1	2 bed, 1 bath	1874
	Multifamily, Unit #2	1 bed, 1 bath	
1208 Liverpool Street (2 units)	Multifamily, Unit #1	3 bed, 1 bath	1915
	Multifamily, Unit #2	2 bed, 1 bath	
1315 Liverpool Street (8 units)	Multifamily, Unit #1	1 bed, 1 bath	1900
	Multifamily, Unit #2	1 bed, 1 bath	
	Multifamily, Unit #3	1 bed, 1 bath	
	Multifamily, Unit #4	1 bed, 1 bath	
	Multifamily, Unit #5	1 bed, 1 bath	
	Multifamily, Unit #6	1 bed, 1 bath	
	Multifamily, Unit #7	1 bed, 1 bath	
	Multifamily, Unit #8	1 bed, 1 bath	

Quote Request

**Professional Lead-Based Paint Risk Assessment for the Manchester
Neighborhood**

Attachment B – Lead-Based Paint Report

For more information or questions, please contact Brandon Havranek at
412-643-2869 or Brandon.Havranek@hacp.org

September 1, 2020

Mackenzie Pleskvoic
Development Manager
Housing Authority City of
Pittsburgh 100 Ross Street, 2ND
Floor Pittsburgh, PA 15219

Re: Lead Screening Report Manchester
Pittsburgh, Allegheny County, PA

Dear Ms. Pleskvoic,

Per your request,

ATC Group Services LLC (ATC) conducted a lead testing of the following 56 units in Manchester:

- 1441 Adams Street
- 1443 Adams Street
- 1431 Nixon Street
- 1429 Nixon Street
- 1424 Nixon Street
- 1422 Nixon Street
- 1208 Liverpool Street
- 1134 Sheffield Street
- 1132 Sheffield Street
- 1130 Sheffield Street
- 1111 Sheffield Street
- 1529 Sedgwick Street
- 1315 Liverpool Street
- 1100 Sheffield Street
- 1017 Pennsylvania Avenue
- 1019 Pennsylvania Avenue
- 1101 Pennsylvania Avenue
- 1103 Pennsylvania Avenue
- 1105 Pennsylvania Avenue
- 1104 W North Street
- 1106 W North Street
- 1108 W North Street
- 1107 Sheffield Street

- 1109 Sheffield Street
- 1131 Sheffield Street
- 1133 Sheffield Street
- 1223 Sheffield Street
- 1225 Sheffield Street
- 1331 N Franklin Street
- 1329 N Franklin Street
- 1207 Juniata Street
- 1205 Juniata Street
- 1323 Columbus Avenue
- 1327 Columbus Avenue
- 1325 Columbus Avenue
- 1331 Adams Street
- 1337 Adams Street
- 1341 Adams Street
- 1402 Adams Street
- 1404 Adams Street
- 1406 Adams Street
- 1439 Adams Street
- 1227 Sheffield Street
- 1229 Sheffield Street
- 1241 Sheffield Street
- 1242 W North Avenue
- 1403 Page Street
- 1405 Page Street
- 1406 W North Avenue
- 1412 W North Avenue
- 1303 Fulton Street
- 1305 Fulton Street
- 1307 Fulton Street
- 1315 Pennsylvania Avenue
- 1335 N Franklin Street
- 1333 N Franklin Street

The scope and methodology of the lead in paint and lead in soil testing is attached.

RECOMMENDATIONS

Elevated lead in paint readings were identified in the following units:

1327, 1325 and 1323 Columbus Avenue and 1529 Sedgwick Street – Unit 1.

Recommended lead abatement includes painting, repair and/or cleaning. Abatement requirements must be detailed for contractors in technical specifications. Repair and cleaning work must be conducted by certified lead abatement contractors. Abatement Specifications must be prepared in accordance with all applicable federal, state, and local government regulations pertaining to lead based paint and other lead containing wastes.

Elevated lead in the soil in excess of 400 ppm (designated maximum level in play areas - US EPA-Lead hazard training 2004) was identified outdoors of the following units:

1327, 1325 and 1323 Columbus Avenue and 1100 Sheffield Street

Lead contaminated soil abatement efforts include cleaning, removing, replacing, or covering contaminated soil. Interim abatement measures include covering contaminated soil with non-contaminated soil, mulch, sod, or grass. Permanent efforts include removing contaminated soils and/or covering contaminated soil with asphalt or concrete. Contaminated soil can also be cleaned by physically encapsulating contaminants and/or chemically reducing contaminant mobility, or extraction.

WARRANTY

The investigation and conclusions presented herein are based upon the subjective evaluation of limited data. They may not represent all conditions at the subject site as they reflect the information gathered from specific locations. ATC warrants that the findings and conclusions contained herein have been promulgated in accordance with generally accepted environmental investigation methodology and only for the site described in this report.

The lead sampling and analysis has been developed to provide the client with information regarding select parameter concentrations in the water samples collected at the subject property. It is necessarily limited to the conditions observed and to the information available at the time of the work.

Due to the limited nature of the work, there is a possibility that there may exist conditions which could not be identified within the scope of the assessment or which were not apparent at the time of report preparation. It is also possible that the testing methods employed at the time of the report may later be superseded by other methods. ATC does not accept responsibility for changes in the state of the art, nor for changes in the regulations. ATC believes that the findings and conclusions provided in this report are reasonable. However, no other warranties are implied or expressed.

This report for the above referenced property represents the product of ATC's professional expertise and judgment in the environmental and industrial hygiene consulting industry. This report is certified to, can be relied upon by, and has been prepared for the exclusive use of the client.

Respectfully Submitted,



Jared Anthony
Division Manager, Building Sciences

Table of Contents

Lead Based Paint Survey	5
Lead in Soils Survey	173
Attachment A	176
Attachment A	213
XRF Training Certificate	226

LEAD BASED PAINT SURVEY:

Lead paint samples were taken utilizing an Olympus Brand, Model Delta Professional (Lead Paint Analyzer), X-Ray Fluorescence Type (XRF), direct reading/data-logging instrument. The RMD XRF takes direct LBP samples without damaging the existing condition of the paint. The calibration procedure for the XRF is 3 positive calibration readings using the 1.0 mg/cm² calibration block and 3 negative readings at the beginning and end of the survey.

Sample results are electronically stored and downloaded into a spreadsheet format. A comprehensive list of all samples taken are listed in the "Lead Based Paint (LBP) Results Table".

The areas in the homes inspected for lead-based paint included walls, windowsills, stairways, and doors. Water samples and roofing materials were not sampled.

All samples that indicate a sample lead content of greater than 1.0 mg/cm² have been marked as "Fail". According to the U.S. Department of Housing and Urban Development (HUD), any paint containing a lead content of greater than 1.0 mg/cm² (or 0.5 percent by weight) is considered to be "LBP".

Of all the samples tested for the Manchester Project, only seven (7) samples were found to be positive with lead paint. These samples were found at 1327, 1325 and, 1323 Columbus Avenue – white paint on main door jambs and windowsills; 1529 Sedgwick Street-Unit 1 – Yellow paint on main door jambs.

Table 1. Lead Based Paint Test Results Table

	1017 Pennsylvania Avenue	
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall	Pass
009	C 1 st Floor Dining Room Windowsill	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	D 1 st Floor Dining Room Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 2. Lead Based Paint Test Results Table

	1019 Pennsylvania Avenue	
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	C 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	2 nd Floor Room 1 Wall 3	Pass
036	2 nd Floor Room 1 Wall 4	Pass
037	2 nd Floor Room 2 Wall 3	Pass
038	2 nd Floor Room 2 Wall 4	Pass
039	3 rd Floor Room Wall 2	Pass
040	3 rd Floor Room Wall 3	Pass

Table 3. Lead Based Paint Test Results Table

1101 Pennsylvania Avenue		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall	Pass
009	C 1 st Floor Dining Room Windowsill	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	D 1 st Floor Dining Room Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 4. Lead Based Paint Test Results Table

1103 Pennsylvania Avenue		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall 1	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass

022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 5. Lead Based Paint Test Results Table

1105 Pennsylvania Avenue		
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room21 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 6-1. Lead Based Paint Test Results Table

1104 W North Avenue		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Access Door	Pass
027	1 st Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass

Table 6-2. Lead Based Paint Test Results Table

1106 W North Avenue		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall 2	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 7. Lead Based Paint Test Results Table

1108 W North Avenue		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 8. Lead Based Paint Test Results Table

1109 Sheffield Street		
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room 1 Door	Pass
027	3 rd Floor Room 2 Door	Pass
028	3 rd Floor Bathroom Door	Pass
029	3 rd Floor Room 1 Windowsill	Pass
030	3 rd Floor Room 2 Windowsill	Pass
031	3 rd Floor Bathroom Windowsill	Pass
032	3 rd Floor Room 1 Wall 1	Pass
033	3 rd Floor Room 1 Wall 2	Pass
034	3 rd Floor Room 2 Wall 1	Pass
035	3 rd Floor Room 2 Wall 2	Pass
036	3 rd Floor Bathroom Wall 1	Pass
037	3 rd Floor Bathroom Wall 2	Pass
038	1 st Floor Stairway wall	Pass
039	2 nd Floor Stairway wall	Pass
040	B 1 st Floor Living Room Wall	Pass
041	D 1 st Floor Living Room Wall	Pass
042	A 1 st Floor Kitchen Wall	Pass

043	D 1 st Floor Kitchen Wall	Pass
044	C 1 st Floor Bathroom Wall	Pass
045	2 nd Floor Room 1 Wall 3	Pass
046	2 nd Floor Room 1 Wall 4	Pass
047	2 nd Floor Room 2 Wall 3	Pass
048	2 nd Floor Room 2 Wall 4	Pass
049	3 rd Floor Room 1 Wall 3	Pass
050	3 rd Floor Room 1 Wall 4	Pass
051	3 rd Floor Room 2 Wall 3	Pass
052	3 rd Floor Room 2 Wall 4	Pass

Table 9. Lead Based Paint Test Results Table

	1107 Sheffield Street	
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 10. Lead Based Paint Test Results Table

1131 Sheffield Street		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room 1 Door	Pass
027	3 rd Floor Room 2 Door	Pass
028	3 rd Floor Bathroom Door	Pass
029	3 rd Floor Room 1 Windowsill	Pass
030	3 rd Floor Room 2 Windowsill	Pass
031	3 rd Floor Room 1 Wall 1	Pass
032	3 rd Floor Room 1 Wall 2	Pass
033	3 rd Floor Room 2 Wall 1	Pass
034	3 rd Floor Room 2 Wall 2	Pass
035	3 rd Floor Bathroom Wall 1	Pass
036	3 rd Floor Bathroom Wall 2	Pass
037	1 st Floor Stairway wall	Pass
038	2 nd Floor Stairway wall	Pass
039	B 1 st Floor Living Room Wall	Pass
040	D 1 st Floor Living Room Wall	Pass
041	A 1 st Floor Kitchen Wall	Pass
042	D 1 st Floor Kitchen Wall	Pass
043	C 1 st Floor Bathroom Wall	Pass

044	2 nd Floor Room 1 Wall 3	Pass
045	2 nd Floor Room 1 Wall 4	Pass
046	2 nd Floor Room 2 Wall 3	Pass
047	2 nd Floor Room 2 Wall 4	Pass
048	3 rd Floor Room 1 Wall 3	Pass
049	3 rd Floor Room 1 Wall 4	Pass
050	3 rd Floor Room 2 Wall 3	Pass
051	3 rd Floor Room 2 Wall 4	Pass

Table 11. Lead Based Paint Test Results Table

1133 Sheffield Street		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 12. Lead Based Paint Test Results Table

1223 Sheffield Street		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 13. Lead Based Paint Test Results Table

	1225 Sheffield Street	
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass
015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass

021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Access Door	Pass
027	1 st Floor Stairway wall	Pass
028	B 1 st Floor Living Room Wall	Pass
029	D 1 st Floor Living Room Wall	Pass
030	A 1 st Floor Kitchen Wall	Pass
031	D 1 st Floor Kitchen Wall	Pass
032	C 1 st Floor Bathroom Wall	Pass
033	2 nd Floor Room 1 Wall 3	Pass
034	2 nd Floor Room 1 Wall 4	Pass
035	2 nd Floor Room 2 Wall 3	Pass
036	2 nd Floor Room 2 Wall 4	Pass

Table 14. Lead Based Paint Test Results Table

1227 Sheffield Street		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room 1 Door	Pass
027	3 rd Floor Room 2 Door	Pass
028	3 rd Floor Bathroom Door	Pass
029	3 rd Floor Room 1 Windowsill	Pass
030	3 rd Floor Room 2 Windowsill	Pass
031	3 rd Floor Room 1 Wall 1	Pass
032	3 rd Floor Room 1 Wall 2	Pass
033	3 rd Floor Room 2 Wall 1	Pass
034	3 rd Floor Room 2 Wall 2	Pass
035	3 rd Floor Bathroom Wall 1	Pass

036	3 rd Floor Bathroom Wall 2	Pass
037	1 st Floor Stairway wall	Pass
038	2 nd Floor Stairway wall	Pass
039	B 1 st Floor Living Room Wall	Pass
040	D 1 st Floor Living Room Wall	Pass
041	A 1 st Floor Kitchen Wall	Pass
042	D 1 st Floor Kitchen Wall	Pass
043	C 1 st Floor Bathroom Wall	Pass
044	2 nd Floor Room 1 Wall 3	Pass
045	2 nd Floor Room 1 Wall 4	Pass
046	2 nd Floor Room 2 Wall 3	Pass
047	2 nd Floor Room 2 Wall 4	Pass
048	3 rd Floor Room 1 Wall 3	Pass
049	3 rd Floor Room 1 Wall 4	Pass
050	3 rd Floor Room 2 Wall 3	Pass
051	3 rd Floor Room 2 Wall 4	Pass

Table 15. Lead Based Paint Test Results Table

1229 Sheffield Street		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room 1 Door	Pass
027	3 rd Floor Room 2 Door	Pass
028	3 rd Floor Bathroom Door	Pass
029	3 rd Floor Room 1 Windowsill	Pass
030	3 rd Floor Room 2 Windowsill	Pass
031	3 rd Floor Bathroom Windowsill	Pass
032	3 rd Floor Room 1 Wall 1	Pass
033	3 rd Floor Room 1 Wall 2	Pass
034	3 rd Floor Room 2 Wall 1	Pass
035	3 rd Floor Room 2 Wall 2	Pass

036	3 rd Floor Bathroom Wall 1	Pass
037	3 rd Floor Bathroom Wall 2	Pass
038	1 st Floor Stairway wall	Pass
039	2 nd Floor Stairway wall	Pass
040	B 1 st Floor Living Room Wall	Pass
041	D 1 st Floor Living Room Wall	Pass
042	A 1 st Floor Kitchen Wall	Pass
043	D 1 st Floor Kitchen Wall	Pass
044	C 1 st Floor Bathroom Wall	Pass
045	2 nd Floor Room 1 Wall 3	Pass
046	2 nd Floor Room 1 Wall 4	Pass
047	2 nd Floor Room 2 Wall 3	Pass
048	2 nd Floor Room 2 Wall 4	Pass
049	3 rd Floor Room 1 Wall 3	Pass
050	3 rd Floor Room 1 Wall 4	Pass
051	3 rd Floor Room 2 Wall 3	Pass
052	3 rd Floor Room 2 Wall 4	Pass

Table 16. Lead Based Paint Test Results Table

	1327 Columbus Avenue	
Sample #	Location	Pass/Fail
001	A 1st Floor White Paint on Main Door Jambs	Fail
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room White Paint on Windowsill	Fail
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass
015	2 nd Floor Room 2 Door	Pass

016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room 1 Door	Pass
027	3 rd Floor Bathroom Door	Pass
028	3 rd Floor Room 1 Windowsill	Pass
029	3 rd Floor Bathroom Windowsillsill	Pass
030	3 rd Floor Room 1 Wall 1	Pass
031	3 rd Floor Room 1 Wall 2	Pass
032	3 rd Floor Bathroom Wall 1	Pass
033	3 rd Floor Bathroom Wall 2	Pass
034	1 st Floor Stairway wall	Pass
035	2 nd Floor Stairway wall	Pass

036	B 1 st Floor Living Room Wall	Pass
037	D 1 st Floor Living Room Wall	Pass
038	A 1 st Floor Kitchen Wall	Pass
039	D 1 st Floor Kitchen Wall	Pass
040	C 1 st Floor Bathroom Wall	Pass
041	2 nd Floor Room 1 Wall 3	Pass
042	2 nd Floor Room 1 Wall 4	Pass
043	2 nd Floor Room 2 Wall 3	Pass
044	2 nd Floor Room 2 Wall 4	Pass
045	3 rd Floor Room 1 Wall 3	Pass
046	3 rd Floor Room 1 Wall 4	Pass
047	3 rd Floor Room 2 Wall 3	Pass
048	3 rd Floor Room 2 Wall 4	Pass

Table 17. Lead Based Paint Test Results Table

1325 Columbus Avenue		
Sample #	Location	Pass/Fail
001	A 1st Floor White Paint on Main Door Jambs	Fail
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room White Paint on Windowsill	Fail
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass
015	2 nd Floor Room 2 Door	Pass

016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsillsill	Pass
018	2 nd Floor Room 2 Windowsillsill	Pass
019	2 nd Floor Bathroom Windowsillsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room 1 Door	Pass
027	3 rd Floor Bathroom Door	Pass
028	3 rd Floor Room 1 Windowsill	Pass
029	3 rd Floor Bathroom Windowsill	Pass
030	3 rd Floor Room 1 Wall 1	Pass
031	3 rd Floor Room 1 Wall 2	Pass
032	3 rd Floor Bathroom Wall 1	Pass
033	3 rd Floor Bathroom Wall 2	Pass
034	1 st Floor Stairway wall	Pass
035	2 nd Floor Stairway wall	Pass

036	B 1 st Floor Living Room Wall	Pass
037	D 1 st Floor Living Room Wall	Pass
038	A 1 st Floor Kitchen Wall	Pass
039	D 1 st Floor Kitchen Wall	Pass
040	C 1 st Floor Bathroom Wall	Pass
041	2 nd Floor Room 1 Wall 3	Pass
042	2 nd Floor Room 1 Wall 4	Pass
043	2 nd Floor Room 2 Wall 3	Pass
044	2 nd Floor Room 2 Wall 4	Pass
045	3 rd Floor Room 1 Wall 3	Pass
046	3 rd Floor Room 1 Wall 4	Pass

Table 18. Lead Based Paint Test Results Table

1323 Columbus Avenue		
Sample #	Location	Pass/Fail
001	A 1st Floor White Paint on Main Door Jambs	Fail
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room White Paint on Windowsill	Fail
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsillsill	Pass
018	2 nd Floor Room 2 Windowsillsill	Pass
019	2 nd Floor Bathroom Windowsillsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room 1 Door	Pass
027	3 rd Floor Bathroom Door	Pass
028	3 rd Floor Room 1 Windowsillsill	Pass
029	3 rd Floor Bathroom Windowsillsill	Pass
030	3 rd Floor Room 1 Wall 1	Pass
031	3 rd Floor Room 1 Wall 2	Pass
032	3 rd Floor Bathroom Wall 1	Pass
033	3 rd Floor Bathroom Wall 2	Pass
034	1 st Floor Stairway wall	Pass
035	2 nd Floor Stairway wall	Pass

036	B 1 st Floor Living Room Wall	Pass
037	D 1 st Floor Living Room Wall	Pass
038	A 1 st Floor Kitchen Wall	Pass
039	D 1 st Floor Kitchen Wall	Pass
040	C 1 st Floor Bathroom Wall	Pass
041	2 nd Floor Room 1 Wall 3	Pass
042	2 nd Floor Room 1 Wall 4	Pass
043	2 nd Floor Room 2 Wall 3	Pass
044	2 nd Floor Room 2 Wall 4	Pass
045	3 rd Floor Room 1 Wall 3	Pass
046	3 rd Floor Room 1 Wall 4	Pass

Table 19. Lead Based Paint Test Results Table

	1337 Adams Street	
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 20. Lead Based Paint Test Results Table

1341 Adams Street		
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 21. Lead Based Paint Test Results Table

1402 Adams Street		
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 22. Lead Based Paint Test Results Table

1331 Adams Street		
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room 1 Door	Pass
027	3 rd Floor Room 2 Door	Pass
028	3 rd Floor Bathroom Door	Pass
029	3 rd Floor Room 1 Windowsill	Pass
030	3 rd Floor Room 2 Windowsill	Pass
031	3 rd Floor Bathroom Windowsill	Pass
032	3 rd Floor Room 1 Wall 1	Pass
033	3 rd Floor Room 1 Wall 2	Pass
034	3 rd Floor Room 2 Wall 1	Pass
035	3 rd Floor Room 2 Wall 2	Pass
036	3 rd Floor Bathroom Wall 1	Pass

037	3 rd Floor Bathroom Wall 2	Pass
038	1 st Floor Stairway wall	Pass
039	2 nd Floor Stairway wall	Pass
040	B 1 st Floor Living Room Wall	Pass
041	D 1 st Floor Living Room Wall	Pass
042	A 1 st Floor Kitchen Wall	Pass
043	D 1 st Floor Kitchen Wall	Pass
044	C 1 st Floor Bathroom Wall	Pass
045	2 nd Floor Room 1 Wall 3	Pass
046	2 nd Floor Room 1 Wall 4	Pass
047	2 nd Floor Room 2 Wall 3	Pass
048	2 nd Floor Room 2 Wall 4	Pass
049	3 rd Floor Room 1 Wall 3	Pass
050	3 rd Floor Room 1 Wall 4	Pass
051	3 rd Floor Room 2 Wall 3	Pass
052	3 rd Floor Room 2 Wall 4	Pass

Table 23. Lead Based Paint Test Results Table

	1404 Adams Street	
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Access Door	Pass
027	1 st Floor Stairway wall	Pass
028	B 1 st Floor Living Room Wall	Pass
029	D 1 st Floor Living Room Wall	Pass
030	A 1 st Floor Kitchen Wall	Pass
031	D 1 st Floor Kitchen Wall	Pass
032	C 1 st Floor Bathroom Wall	Pass
033	2 nd Floor Room 1 Wall 3	Pass
034	2 nd Floor Room 1 Wall 4	Pass
035	2 nd Floor Room 2 Wall 3	Pass
036	2 nd Floor Room 2 Wall 4	Pass

Table 24. Lead Based Paint Test Results Table

1241 Sheffield Street		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Access Door	Pass
027	1 st Floor Stairway wall	Pass
028	B 1 st Floor Living Room Wall	Pass
029	D 1 st Floor Living Room Wall	Pass
030	A 1 st Floor Kitchen Wall	Pass
031	D 1 st Floor Kitchen Wall	Pass
032	C 1 st Floor Bathroom Wall	Pass
033	2 nd Floor Room 1 Wall 3	Pass
034	2 nd Floor Room 1 Wall 4	Pass
035	2 nd Floor Room 2 Wall 3	Pass
036	2 nd Floor Room 2 Wall 4	Pass

Table 25. Lead Based Paint Test Results Table

1242 W North Avenue		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room 1 Door	Pass
027	3 rd Floor Room 2 Door	Pass
028	3 rd Floor Bathroom Door	Pass
029	3 rd Floor Room 1 Windowsill	Pass
030	3 rd Floor Room 2 Windowsill	Pass
031	3 rd Floor Bathroom Windowsill	Pass
032	3 rd Floor Room 1 Wall 1	Pass
033	3 rd Floor Room 1 Wall 2	Pass
034	3 rd Floor Room 2 Wall 1	Pass
035	3 rd Floor Room 2 Wall 2	Pass
036	3 rd Floor Bathroom Wall 1	Pass

037	3 rd Floor Bathroom Wall 2	Pass
038	1 st Floor Stairway wall	Pass
039	2 nd Floor Stairway wall	Pass
040	B 1 st Floor Living Room Wall	Pass
041	D 1 st Floor Living Room Wall	Pass
042	A 1 st Floor Kitchen Wall	Pass
043	D 1 st Floor Kitchen Wall	Pass
044	C 1 st Floor Bathroom Wall	Pass
045	2 nd Floor Room 1 Wall 3	Pass
046	2 nd Floor Room 1 Wall 4	Pass
047	2 nd Floor Room 2 Wall 3	Pass
048	2 nd Floor Room 2 Wall 4	Pass
049	3 rd Floor Room 1 Wall 3	Pass
050	3 rd Floor Room 1 Wall 4	Pass
051	3 rd Floor Room 2 Wall 3	Pass
052	3 rd Floor Room 2 Wall 4	Pass

Table 26. Lead Based Paint Test Results Table

	1403 Page Street	
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass

038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 27. Lead Based Paint Test Results Table

	1405 Page Street	
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 28. Lead Based Paint Test Results Table

	1406 W North Avenue	
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 29. Lead Based Paint Test Results Table

1412 W North Avenue		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Access Door	Pass
027	1 st Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass

Table 30. Lead Based Paint Test Results Table

	1303 Fulton Street	
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room 1 Door	Pass
027	3 rd Floor Room 2 Door	Pass
028	3 rd Floor Bathroom Door	Pass
029	3 rd Floor Room 1 Windowsill	Pass
030	3 rd Floor Room 2 Windowsill	Pass
031	3 rd Floor Bathroom Windowsill	Pass
032	3 rd Floor Room 1 Wall 1	Pass
033	3 rd Floor Room 1 Wall 2	Pass
034	3 rd Floor Room 2 Wall 1	Pass
035	3 rd Floor Room 2 Wall 2	Pass

036	3 rd Floor Bathroom Wall 1	Pass
037	3 rd Floor Bathroom Wall 2	Pass
038	1 st Floor Stairway wall	Pass
039	2 nd Floor Stairway wall	Pass
040	B 1 st Floor Living Room Wall	Pass
041	D 1 st Floor Living Room Wall	Pass
042	A 1 st Floor Kitchen Wall	Pass
043	D 1 st Floor Kitchen Wall	Pass
044	C 1 st Floor Bathroom Wall	Pass
045	2 nd Floor Room 1 Wall 3	Pass
046	2 nd Floor Room 1 Wall 4	Pass
047	2 nd Floor Room 2 Wall 3	Pass
048	2 nd Floor Room 2 Wall 4	Pass
049	3 rd Floor Room 1 Wall 3	Pass
050	3 rd Floor Room 1 Wall 4	Pass
051	3 rd Floor Room 2 Wall 3	Pass
052	3 rd Floor Room 2 Wall 4	Pass

Table 31. Lead Based Paint Test Results Table

	1305 Fulton Street	
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room 1 Door	Pass
027	3 rd Floor Room 2 Door	Pass
028	3 rd Floor Bathroom Door	Pass
029	3 rd Floor Room 1 Windowsill	Pass
030	3 rd Floor Room 2 Windowsill	Pass
031	3 rd Floor Bathroom Windowsill	Pass
032	3 rd Floor Room 1 Wall 1	Pass
033	3 rd Floor Room 1 Wall 2	Pass
034	3 rd Floor Room 2 Wall 1	Pass
035	3 rd Floor Room 2 Wall 2	Pass

036	3 rd Floor Bathroom Wall 1	Pass
037	3 rd Floor Bathroom Wall 2	Pass
038	1 st Floor Stairway wall	Pass
039	2 nd Floor Stairway wall	Pass
040	B 1 st Floor Living Room Wall	Pass
041	D 1 st Floor Living Room Wall	Pass
042	A 1 st Floor Kitchen Wall	Pass
043	D 1 st Floor Kitchen Wall	Pass
044	C 1 st Floor Bathroom Wall	Pass
045	2 nd Floor Room 1 Wall 3	Pass
046	2 nd Floor Room 1 Wall 4	Pass
047	2 nd Floor Room 2 Wall 3	Pass
048	2 nd Floor Room 2 Wall 4	Pass
049	3 rd Floor Room 1 Wall 3	Pass
050	3 rd Floor Room 1 Wall 4	Pass
051	3 rd Floor Room 2 Wall 3	Pass
052	3 rd Floor Room 2 Wall 4	Pass

Table 32. Lead Based Paint Test Results Table

1307 Fulton Street		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Access Door	Pass
027	1 st Floor Stairway wall	Pass
028	B 1 st Floor Living Room Wall	Pass
029	D 1 st Floor Living Room Wall	Pass
030	A 1 st Floor Kitchen Wall	Pass
031	D 1 st Floor Kitchen Wall	Pass
032	C 1 st Floor Bathroom Wall	Pass
033	2 nd Floor Room 1 Wall 3	Pass

034	2 nd Floor Room 1 Wall 4	Pass
035	2 nd Floor Room 2 Wall 3	Pass
036	2 nd Floor Room 2 Wall 4	Pass

Table 33. Lead Based Paint Test Results Table

	1315 Pennsylvania Avenue	
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 34. Lead Based Paint Test Results Table

	1335 N Franklin Street	
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room 1 Door	Pass
027	3 rd Floor Room 2 Door	Pass
028	3 rd Floor Bathroom Door	Pass
029	3 rd Floor Room 1 Windowsill	Pass
030	3 rd Floor Room 2 Windowsill	Pass
031	3 rd Floor Bathroom Windowsill	Pass
032	3 rd Floor Room 1 Wall 1	Pass
033	3 rd Floor Room 1 Wall 2	Pass
034	3 rd Floor Room 2 Wall 1	Pass
035	3 rd Floor Room 2 Wall 2	Pass

036	3 rd Floor Bathroom Wall 1	Pass
037	3 rd Floor Bathroom Wall 2	Pass
038	1 st Floor Stairway wall	Pass
039	2 nd Floor Stairway wall	Pass
040	B 1 st Floor Living Room Wall	Pass
041	D 1 st Floor Living Room Wall	Pass
042	A 1 st Floor Kitchen Wall	Pass
043	D 1 st Floor Kitchen Wall	Pass
044	C 1 st Floor Bathroom Wall	Pass
045	2 nd Floor Room 1 Wall 3	Pass
046	2 nd Floor Room 1 Wall 4	Pass
047	2 nd Floor Room 2 Wall 3	Pass
048	2 nd Floor Room 2 Wall 4	Pass
049	3 rd Floor Room 1 Wall 3	Pass
050	3 rd Floor Room 1 Wall 4	Pass
051	3 rd Floor Room 2 Wall 3	Pass
052	3 rd Floor Room 2 Wall 4	Pass

Table 35. Lead Based Paint Test Results Table

1333 N Franklin Street		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room 1 Door	Pass
027	3 rd Floor Room 2 Door	Pass
028	3 rd Floor Bathroom Door	Pass
029	3 rd Floor Room 1 Windowsill	Pass
030	3 rd Floor Room 2 Windowsill	Pass
031	3 rd Floor Bathroom Windowsill	Pass
032	3 rd Floor Room 1 Wall 1	Pass
033	3 rd Floor Room 1 Wall 2	Pass
034	3 rd Floor Room 2 Wall 1	Pass
035	3 rd Floor Room 2 Wall 2	Pass

036	3 rd Floor Bathroom Wall 1	Pass
037	3 rd Floor Bathroom Wall 2	Pass
038	1 st Floor Stairway wall	Pass
039	2 nd Floor Stairway wall	Pass
040	B 1 st Floor Living Room Wall	Pass
041	D 1 st Floor Living Room Wall	Pass
042	A 1 st Floor Kitchen Wall	Pass
043	D 1 st Floor Kitchen Wall	Pass
044	C 1 st Floor Bathroom Wall	Pass
045	2 nd Floor Room 1 Wall 3	Pass
046	2 nd Floor Room 1 Wall 4	Pass
047	2 nd Floor Room 2 Wall 3	Pass
048	2 nd Floor Room 2 Wall 4	Pass
049	3 rd Floor Room 1 Wall 3	Pass
050	3 rd Floor Room 1 Wall 4	Pass
051	3 rd Floor Room 2 Wall 3	Pass
052	3 rd Floor Room 2 Wall 4	Pass

Table 36. Lead Based Paint Test Results Table

1331 N Franklin Street		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Access Door	Pass
027	1 st Floor Stairway wall	Pass
028	B 1 st Floor Living Room Wall	Pass
029	D 1 st Floor Living Room Wall	Pass
030	A 1 st Floor Kitchen Wall	Pass
031	D 1 st Floor Kitchen Wall	Pass
032	C 1 st Floor Bathroom Wall	Pass
033	2 nd Floor Room 1 Wall 3	Pass
034	2 nd Floor Room 1 Wall 4	Pass
035	2 nd Floor Room 2 Wall 3	Pass
036	2 nd Floor Room 2 Wall 4	Pass

Table 37. Lead Based Paint Test Results Table

1329 N Franklin Street		
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 38. Lead Based Paint Test Results Table

	1205 Juniata Street	
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Access Door	Pass
027	1 st Floor Stairway wall	Pass
028	B 1 st Floor Living Room Wall	Pass
029	D 1 st Floor Living Room Wall	Pass
030	A 1 st Floor Kitchen Wall	Pass
031	D 1 st Floor Kitchen Wall	Pass
032	C 1 st Floor Bathroom Wall	Pass
033	2 nd Floor Room 1 Wall 3	Pass
034	2 nd Floor Room 1 Wall 4	Pass
035	2 nd Floor Room 2 Wall 3	Pass
036	2 nd Floor Room 2 Wall 4	Pass

Table 39. Lead Based Paint Test Results Table

	1207 Juniata Street	
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 40. Lead Based Paint Test Results Table

	1406 Adams Street	
Sample #	Location	Pass /Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Access Door	Pass
027	1 st Floor Stairway wall	Pass
028	B 1 st Floor Living Room Wall	Pass
029	D 1 st Floor Living Room Wall	Pass
030	A 1 st Floor Kitchen Wall	Pass
031	D 1 st Floor Kitchen Wall	Pass
032	C 1 st Floor Bathroom Wall	Pass
033	2 nd Floor Room 1 Wall 3	Pass
034	2 nd Floor Room 1 Wall 4	Pass
035	2 nd Floor Room 2 Wall 3	Pass
036	2 nd Floor Room 2 Wall 4	Pass

Table 41. Lead Based Paint Test Results Table

1439 Adams Street		
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 42. Lead Based Paint Test Results Table

1441 Adams Street		
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 43. Lead Based Paint Test Results Table

	1443 Adams Street	
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 44. Lead Based Paint Test Results Table

1431 Nixon Street		
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 45. Lead Based Paint Test Results Table

	1429 Nixon Street	
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Access Door	Pass
027	1 st Floor Stairway wall	Pass
028	B 1 st Floor Living Room Wall	Pass
029	D 1 st Floor Living Room Wall	Pass
030	A 1 st Floor Kitchen Wall	Pass
031	D 1 st Floor Kitchen Wall	Pass
032	C 1 st Floor Bathroom Wall	Pass
033	2 nd Floor Room 1 Wall 3	Pass
034	2 nd Floor Room 1 Wall 4	Pass
035	2 nd Floor Room 2 Wall 3	Pass
036	2 nd Floor Room 2 Wall 4	Pass

Table 46. Lead Based Paint Test Results Table

1424 Nixon Street		
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Room Wall 1	Pass
027	3 rd Floor Room Closet Door	Pass
028	3 rd Floor Room Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 1 st Floor Living Room Wall	Pass
032	D 1 st Floor Living Room Wall	Pass
033	A 1 st Floor Kitchen Wall	Pass
034	D 1 st Floor Kitchen Wall	Pass
035	C 1 st Floor Bathroom Wall	Pass
036	2 nd Floor Room 1 Wall 3	Pass
037	2 nd Floor Room 1 Wall 4	Pass
038	2 nd Floor Room 2 Wall 3	Pass
039	2 nd Floor Room 2 Wall 4	Pass
040	3 rd Floor Room Wall 2	Pass

Table 47. Lead Based Paint Test Results Table

	1422 Nixon Street	
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	B 1st Floor Back Door	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Dining Room Wall 1	Pass
009	D 1 st Floor Dining Room Wall 2	Pass
010	B 1 st Floor Bathroom Door	Pass
011	B 1 st Floor Bathroom Wall	Pass
012	B Basement Door	Pass
013	B Basement Wall	Pass
014	2 nd Floor Room 1 Door	Pass

015	2 nd Floor Room 2 Door	Pass
016	2 nd Floor Bathroom Door	Pass
017	2 nd Floor Room 1 Windowsill	Pass
018	2 nd Floor Room 2 Windowsill	Pass
019	2 nd Floor Bathroom Windowsill	Pass
020	2 nd Floor Room 1 Wall 1	Pass
021	2 nd Floor Room 1 Wall 2	Pass
022	2 nd Floor Room 2 Wall 1	Pass
023	2 nd Floor Room 2 Wall 2	Pass
024	2 nd Floor Bathroom Wall 1	Pass
025	2 nd Floor Bathroom Wall 2	Pass
026	3 rd Floor Access Door	Pass
027	1 st Floor Stairway wall	Pass
028	B 1 st Floor Living Room Wall	Pass
029	D 1 st Floor Living Room Wall	Pass
030	A 1 st Floor Kitchen Wall	Pass
031	D 1 st Floor Kitchen Wall	Pass
032	C 1 st Floor Bathroom Wall	Pass
033	2 nd Floor Room 1 Wall 3	Pass

034	2 nd Floor Room 1 Wall 4	Pass
035	2 nd Floor Room 2 Wall 3	Pass
036	2 nd Floor Room 2 Wall 4	Pass

Table 48. Lead Based Paint Test Results Table

1208 Liverpool Street		
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	C 1 st Floor Stairway Wall	Pass
003	C Basement Door	Pass
004	B Basement Wall	Pass
005	C 2 nd Floor Kitchen Wall	Pass
006	A 2 nd Floor Kitchen Windowsill	Pass
007	C 2 nd Floor Living Room Wall 1	Pass
008	A 2 nd Floor Living Room Windowsill	Pass
009	C 2 nd Floor Laundry Room Wall 1	Pass
010	A 2 nd Floor Laundry Room Windowsill	Pass
011	2 nd Floor Bathroom Door	Pass
012	2 nd Floor Bathroom Windowsill	Pass
013	3 rd Floor Room 1 Door	Pass

014	3 rd Floor Room 2 Door	Pass
015	3 rd Floor Room 3 Door	Pass
016	3 rd Floor Room 1 Windowsill	Pass
017	3 rd Floor Room 2 Windowsill	Pass
018	3 rd Floor Room 3 Windowsill	Pass
019	3 rd Floor Room 1 Wall 1	Pass
020	3 rd Floor Room 1 Wall 2	Pass
021	3 rd Floor Room 2 Wall 1	Pass
022	3 rd Floor Room 2 Wall 2	Pass
023	3 rd Floor Room 3 Wall 1	Pass
024	3 rd Floor Room 3 Wall 2	Pass
025	3 rd Floor Bathroom Wall 1	Pass
026	3 rd Floor Bathroom Wall 2	Pass
027	3 rd Floor Bathroom Door	Pass
028	3 rd Floor Bathroom Windowsill	Pass
029	1 st Floor Stairway wall	Pass
030	2 nd Floor Stairway wall	Pass
031	B 2 nd Floor Living Room Wall 2	Pass
032	D 2 nd Floor Living Room Wall 3	Pass
033	A 2 nd Floor Kitchen Wall	Pass
034	D 2 nd Floor Kitchen Wall	Pass

035	2 nd Floor Bathroom Wall 1	Pass
036	2 nd Floor Bathroom Wall 2	Pass
037	3 rd Floor Room 1 Wall 3	Pass
038	3 rd Floor Room 1 Wall 4	Pass
039	3 rd Floor Room 2 Wall 3	Pass
040	3 rd Floor Room 2 Wall 4	Pass
041	3 rd Floor Room 3 Wall 3	Pass
042	3 rd Floor Room 3 Wall 4	Pass

Table 49. Lead Based Paint Test Results Table

1134 Sheffield Street – Unit A		
Sample #	Location	Pass/Fail
001	A 1st Floor Main Door	Pass
002	A 1st Floor Living Room Windowsill 1	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill 2	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	C 1 st Floor Laundry Room Wall 1	Pass
009	D 1 st Floor Laundry Room Wall 2	Pass
010	B Basement Door	Pass
011	2 nd Floor Room 1 Door	Pass

012	2 nd Floor Room 2 Door	Pass
013	2 nd Floor Bathroom Door	Pass
014	2 nd Floor Room 1 Windowsill	Pass
015	2 nd Floor Room 2 Windowsill	Pass
016	2 nd Floor Bathroom Windowsill	Pass
017	2 nd Floor Room 1 Wall 1	Pass
018	2 nd Floor Room 1 Wall 2	Pass
019	2 nd Floor Room 2 Wall 1	Pass
020	2 nd Floor Room 2 Wall 2	Pass
021	2 nd Floor Bathroom Wall 1	Pass
022	2 nd Floor Bathroom Wall 2	Pass
023	3 rd Floor Room 1 Door	Pass
024	3 rd Floor Room 2 Door	Pass
025	3 rd Floor Bathroom Door	Pass
026	3 rd Floor Room 1 Windowsill	Pass
027	3 rd Floor Room 2 Windowsill	Pass
028	3 rd Floor Bathroom Windowsill	Pass
029	3 rd Floor Room 1 Wall 1	Pass
030	3 rd Floor Room 1 Wall 2	Pass
031	3 rd Floor Room 2 Wall 1	Pass
032	3 rd Floor Room 2 Wall 2	Pass

033	3 rd Floor Bathroom Wall 1	Pass
034	3 rd Floor Bathroom Wall 2	Pass
035	1 st Floor Stairway wall	Pass
036	2 nd Floor Stairway wall	Pass
037	B 1 st Floor Living Room Wall	Pass
038	D 1 st Floor Living Room Wall	Pass
039	A 1 st Floor Kitchen Wall	Pass
040	D 1 st Floor Kitchen Wall	Pass
041	2 nd Floor Room 1 Wall 3	Pass
042	2 nd Floor Room 1 Wall 4	Pass
043	2 nd Floor Room 2 Wall 3	Pass
044	2 nd Floor Room 2 Wall 4	Pass
045	3 rd Floor Room 1 Wall 3	Pass
046	3 rd Floor Room 1 Wall 4	Pass
047	3 rd Floor Room 2 Wall 3	Pass
048	3 rd Floor Room 2 Wall 4	Pass

Table 50. Lead Based Paint Test Results Table

1134 Sheffield Street – Unit B		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	A 1st Floor Living Room Windowsill 1	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill 2	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	A 1 st Floor Kitchen Windowsill	Pass
008	2 nd Floor Room 1 Door	Pass

009	2 nd Floor Room 2 Door	Pass
010	2 nd Floor Bathroom Door	Pass
011	2 nd Floor Room 1 Windowsill	Pass
012	2 nd Floor Room 2 Windowsill	Pass
013	2 nd Floor Bathroom Windowsill	Pass
014	2 nd Floor Room 1 Wall 1	Pass
015	2 nd Floor Room 1 Wall 2	Pass
016	2 nd Floor Room 2 Wall 1	Pass
017	2 nd Floor Room 2 Wall 2	Pass
018	2 nd Floor Bathroom Wall 1	Pass
019	2 nd Floor Bathroom Wall 2	Pass
020	3 rd Floor Room 1 Door	Pass
021	3 rd Floor Room 2 Door	Pass
022	3 rd Floor Bathroom Door	Pass
023	3 rd Floor Room 1 Windowsill	Pass
024	3 rd Floor Room 2 Windowsill	Pass
025	3 rd Floor Bathroom Windowsill	Pass
026	3 rd Floor Room 1 Wall 1	Pass
027	3 rd Floor Room 1 Wall 2	Pass
028	3 rd Floor Room 2 Wall 1	Pass

029	3 rd Floor Room 2 Wall 2	Pass
030	3 rd Floor Closet Door	Pass
031	3 rd Floor Closet Wall	Pass
032	1 st Floor Stairway wall	Pass
033	2 nd Floor Stairway wall	Pass
034	B 1 st Floor Living Room Wall	Pass
035	D 1 st Floor Living Room Wall	Pass
036	A 1 st Floor Kitchen Wall	Pass
037	D 1 st Floor Kitchen Wall	Pass
038	2 nd Floor Room 1 Wall 3	Pass
039	2 nd Floor Room 1 Wall 4	Pass
040	2 nd Floor Room 2 Wall 3	Pass
041	2 nd Floor Room 2 Wall 4	Pass
042	3 rd Floor Room 1 Wall 3	Pass
043	3 rd Floor Room 1 Wall 4	Pass
044	3 rd Floor Room 2 Wall 3	Pass
045	3 rd Floor Room 2 Wall 4	Pass

Table 51. Lead Based Paint Test Results Table

1132 Sheffield Street – Unit 1		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door	Pass
002	A 1st Floor Living Room Windowsill 1	Pass
003	A 1 st Floor Living Room Wall	Pass
004	A 1 st Floor Living Room Windowsill 2	Pass
005	C 1 st Floor Living Room Wall	Pass
006	B 1 st Floor Kitchen Wall	Pass
007	B 1 st Floor Kitchen Windowsill	Pass
008	B 1 st Floor Basement Door	Pass
009	B 1 st Floor Basement Wall	Pass
010	D 1 st Floor Room 1 Door	Pass

011	D 1 st Floor Room 2 Door	Pass
012	B 1 st Floor Room 3 Door	Pass
013	D 1 st Floor Room 1 Windowsill	Pass
014	D 1 st Floor Room 2 Windowsill	Pass
015	B 1 st Floor Room 3 Windowsill	Pass
016	B 1 st Floor Room 1 Wall 1	Pass
017	D 1 st Floor Room 1 Wall 2	Pass
018	B 1 st Floor Room 2 Wall 1	Pass
019	D 1 st Floor Room 2 Wall 2	Pass
020	B 1 st Floor Room 3 Wall 1	Pass
021	D 1 st Floor Room 3 Wall 2	Pass
022	B 1 st Floor Bathroom Wall 1	Pass
023	D 1 st Floor Bathroom Wall 2	Pass
024	D 1 st Floor Bathroom Door	Pass
025	D 1 st Floor Bathroom Windowsill	Pass
026	B 1 st Floor Living Room Wall	Pass
027	D 1 st Floor Living Room Wall	Pass
028	A 1 st Floor Kitchen Wall	Pass
029	D 1 st Floor Kitchen Wall	Pass

030	A 1 st Floor Room 1 Wall 3	Pass
031	C 1 st Floor Room 1 Wall 4	Pass
032	A 1 st Floor Room 2 Wall 3	Pass
033	C 1 st Floor Room 2 Wall 4	Pass
034	A 1 st Floor Room 3 Wall 3	Pass
035	C 1 st Floor Room 3 Wall 4	Pass

Table 52. Lead Based Paint Test Results Table

1132 Sheffield Street – Unit 2		
Sample #	Location	Pass/ Fail
001	A 2 nd Floor Main Door	Pass
002	A 2 nd Floor Living Room Windowsill 1	Pass
003	A 2 nd Floor Living Room Wall	Pass
004	A 2 nd Floor Living Room Windowsill 2	Pass
005	C 2 nd Floor Living Room Wall	Pass
006	B 2 nd Floor Kitchen Wall	Pass
007	B 2 nd Floor Kitchen Windowsill	Pass
008	D 2 nd Floor Room 1 Door	Pass

009	D 2 nd Floor Room 2 Door	Pass
010	B 2 nd Floor Room 3 Door	Pass
011	D 2 nd Floor Room 1 Windowsill	Pass
012	D 2 nd Floor Room 2 Windowsill	Pass
013	B 2 nd Floor Room 3 Windowsill	Pass
014	D 2 nd Floor Room 1 Wall 1	Pass
015	B 2 nd Floor Room 1 Wall 2	Pass
016	D 2 nd Floor Room 2 Wall 1	Pass
017	B 2 nd Floor Room 2 Wall 2	Pass
018	D 2 nd Floor Room 3 Wall 1	Pass
019	B 2 nd Floor Room 3 Wall 2	Pass
020	D 2 nd Floor Bathroom Wall 1	Pass
021	B 2 nd Floor Bathroom Wall 2	Pass
022	D 2 nd Floor Bathroom Door	Pass
023	D 2 nd Floor Bathroom Windowsill	Pass
024	B 2 nd Floor Living Room Wall 2	Pass
025	D 2 nd Floor Living Room Wall 3	Pass
026	A 2 nd Floor Kitchen Wall	Pass
027	D 2 nd Floor Kitchen Wall	Pass
028	A 2 nd Floor Room 1 Wall 3	Pass

029	C 2 nd Floor Room 1 Wall 4	Pass
030	A 2 nd Floor Room 2 Wall 3	Pass
031	C 2 nd Floor Room 2 Wall 4	Pass
032	A 2 nd Floor Room 3 Wall 3	Pass
033	C 2 nd Floor Room 3 Wall 4	Pass

Table 53. Lead Based Paint Test Results Table

1132 Sheffield Street – Unit 3		
Sample #	Location	Pass/ Fail
001	A 3 rd Floor Main Door	Pass
002	A 3 rd Floor Living Room Windowsill 1	Pass
003	A 3 rd Floor Living Room Wall	Pass
004	A 3 rd Floor Living Room Windowsill 2	Pass
005	C 3 rd Floor Living Room Wall	Pass
006	B 3 rd Floor Kitchen Wall	Pass
007	B 3 rd Floor Kitchen Windowsill	Pass
008	D 3 rd Floor Room 1 Door	Pass

009	D3 rd Floor Room 2 Door	Pass
010	D 3 rd Floor Room 1 Windowsill	Pass
011	D 3 rd Floor Room 2 Windowsill	Pass
012	D 3 rd Floor Room 1 Wall 1	Pass
013	B 3 rd Floor Room 1 Wall 2	Pass
014	D 3 rd Floor Room 2 Wall 1	Pass
015	B 3 rd Floor Room 2 Wall 2	Pass
016	D 3 rd Floor Bathroom Wall 1	Pass
017	B 3 rd Floor Bathroom Wall 2	Pass
018	D 3 rd Floor Bathroom Door	Pass
019	D 3 rd Floor Bathroom Windowsill	Pass
020	B 3 rd Floor Living Room Wall 2	Pass
021	D 3 rd Floor Living Room Wall 3	Pass
022	A 3 rd Floor Kitchen Wall	Pass
023	D 3 rd Floor Kitchen Wall	Pass
024	A 3 rd Floor Room 1 Wall 3	Pass
025	C 3 rd Floor Room 1 Wall 4	Pass
026	A 3 rd Floor Room 2 Wall 3	Pass
027	C 3 rd Floor Room 2 Wall 4	Pass

Table 54. Lead Based Paint Test Results Table

	1315 Liverpool Street	
Sample #	Location	Pass/ Fail
001	Unit 1 Main Door	Pass
002	Unit 1 Living Room Windowsill	Pass
003	Unit 1 Living Room Wall 1	Pass
004	Unit 1 Living Room Wall 2	Pass
005	Unit 1 Kitchen Wall 1	Pass
006	Unit 1 Kitchen Wall 2	Pass
007	Unit 1 Bedroom Door	Pass
008	Unit 1 Bedroom Windowsill	Pass
009	Unit 1 Bedroom Wall 1	Pass
010	Unit 1 Bedroom Wall 2	Pass
011	Unit 1 Bathroom Door	Pass
012	Unit 1 Bathroom Wall 1	Pass
013	Unit 1 Bathroom Wall 2	Pass
014	Unit 1 Living Room Wall 3	Pass
015	Unit 1 Living Room Wall 4	Pass
016	Unit 1 Bedroom Wall 3	Pass
017	Unit 1 Bedroom Wall 4	Pass

001	Unit 2 Main Door	Pass
002	Unit 2 Living Room Windowsill	Pass
003	Unit 2 Living Room Wall 1	Pass
004	Unit 2 Living Room Wall 2	Pass
005	Unit 2 Kitchen Wall 1	Pass
006	Unit 2 Kitchen Wall 2	Pass
007	Unit 2 Bedroom Door	Pass
008	Unit 2 Bedroom Windowsill	Pass
009	Unit 2 Bedroom Wall 1	Pass
010	Unit 2 Bedroom Wall 2	Pass
011	Unit 2 Bathroom Door	Pass
012	Unit 2 Bathroom Wall 1	Pass
013	Unit 2 Bathroom Wall 2	Pass
014	Unit 2 Living Room Wall 3	Pass
015	Unit 2 Living Room Wall 4	Pass
016	Unit 2 Bedroom Wall 3	Pass
017	Unit 2 Bedroom Wall 4	Pass

001	Unit 3 Main Door	Pass
002	Unit 3 Living Room Windowsill	Pass
003	Unit 3 Living Room Wall 1	Pass
004	Unit 3 Living Room Wall 2	Pass
005	Unit 3 Kitchen Wall 1	Pass
006	Unit 3 Kitchen Wall 2	Pass
007	Unit 3 Bedroom Door	Pass
008	Unit 3 Bedroom Windowsill	Pass
009	Unit 3 Bedroom Wall 1	Pass
010	Unit 3 Bedroom Wall 2	Pass
011	Unit 3 Bathroom Door	Pass
012	Unit 3 Bathroom Wall 1	Pass
013	Unit 3 Bathroom Wall 2	Pass
014	Unit 3 Living Room Wall 3	Pass
015	Unit 3 Living Room Wall 4	Pass
016	Unit 3 Bedroom Wall 3	Pass
017	Unit 3 Bedroom Wall 4	Pass

001	Unit 4 Main Door	Pass
002	Unit 4 Living Room Windowsill	Pass
003	Unit 4 Living Room Wall 1	Pass
004	Unit 4 Living Room Wall 2	Pass
005	Unit 4 Kitchen Wall 1	Pass
006	Unit 4 Kitchen Wall 2	Pass
007	Unit 4 Bedroom Door	Pass
008	Unit 4 Bedroom Windowsill	Pass
009	Unit 4 Bedroom Wall 1	Pass
010	Unit 4 Bedroom Wall 2	Pass
011	Unit 4 Bathroom Door	Pass
012	Unit 4 Bathroom Wall 1	Pass
013	Unit 4 Bathroom Wall 2	Pass
014	Unit 4 Living Room Wall 3	Pass
015	Unit 4 Living Room Wall 4	Pass
016	Unit 4 Bedroom Wall 3	Pass
017	Unit 4 Bedroom Wall 4	Pass

001	Unit 5 Main Door	Pass
002	Unit 5 Living Room Windowsill	Pass
003	Unit 5 Living Room Wall 1	Pass
004	Unit 5 Living Room Wall 2	Pass
005	Unit 5 Kitchen Wall 1	Pass
006	Unit 5 Kitchen Wall 2	Pass
007	Unit 5 Bedroom Door	Pass
008	Unit 5 Bedroom Windowsill	Pass
009	Unit 5 Bedroom Wall 1	Pass
010	Unit 5 Bedroom Wall 2	Pass
011	Unit 5 Bathroom Door	Pass
012	Unit 5 Bathroom Wall 1	Pass
013	Unit 5 Bathroom Wall 2	Pass
014	Unit 5 Living Room Wall 3	Pass
015	Unit 5 Living Room Wall 4	Pass
016	Unit 5 Bedroom Wall 3	Pass
017	Unit 5 Bedroom Wall 4	Pass

001	Unit 6 Main Door	Pass
002	Unit 6 Living Room Windowsill	Pass
003	Unit 6 Living Room Wall 1	Pass
004	Unit 6 Living Room Wall 2	Pass
005	Unit 6 Kitchen Wall 1	Pass
006	Unit 6 Kitchen Wall 2	Pass
007	Unit 6 Bedroom Door	Pass
008	Unit 6 Bedroom Windowsill	Pass
009	Unit 6 Bedroom Wall 1	Pass
010	Unit 6 Bedroom Wall 2	Pass
011	Unit 6 Bathroom Door	Pass
012	Unit 6 Bathroom Wall 1	Pass
013	Unit 6 Bathroom Wall 2	Pass
014	Unit 6 Living Room Wall 3	Pass
015	Unit 6 Living Room Wall 4	Pass
016	Unit 6 Bedroom Wall 3	Pass
017	Unit 6 Bedroom Wall 4	Pass

001	Unit 7 Main Door	Pass
002	Unit 7 Living Room Windowsill	Pass
003	Unit 7 Living Room Wall 1	Pass
004	Unit 7 Living Room Wall 2	Pass
005	Unit 7 Kitchen Wall 1	Pass
006	Unit 7 Kitchen Wall 2	Pass
007	Unit 7 Bedroom Door	Pass
008	Unit 7 Bedroom Windowsill	Pass
009	Unit 7 Bedroom Wall 1	Pass
010	Unit 7 Bedroom Wall 2	Pass
011	Unit 7 Bathroom Door	Pass
012	Unit 7 Bathroom Wall 1	Pass
013	Unit 7 Bathroom Wall 2	Pass
014	Unit 7 Living Room Wall 3	Pass
015	Unit 7 Living Room Wall 4	Pass
016	Unit 7 Bedroom Wall 3	Pass
017	Unit 7 Bedroom Wall 4	Pass

001	Unit 8 Main Door	Pass
002	Unit 8 Living Room Windowsill	Pass
003	Unit 8 Living Room Wall 1	Pass
005	Unit 8 Living Room Wall 2	Pass
006	Unit 8 Kitchen Wall 1	Pass
007	Unit 8 Kitchen Wall 2	Pass
008	Unit 8 Bedroom Door	Pass
008	Unit 8 Bedroom Windowsill	Pass
009	Unit 8 Bedroom Wall 1	Pass
010	Unit 8 Bedroom Wall 2	Pass
011	Unit 8 Bathroom Door	Pass
012	Unit 8 Bathroom Wall 1	Pass
013	Unit 8 Bathroom Wall 2	Pass
014	Unit 8 Living Room Wall 3	Pass
015	Unit 8 Living Room Wall 4	Pass
016	Unit 8 Bedroom Wall 3	Pass
017	Unit 8 Bedroom Wall 4	Pass

Table 55. Lead Based Paint Test Results Table

	1100 Sheffield Street	
Sample #	Location	Pass/ Fail
001	Unit 1 Main Door	Pass
002	Unit 1 Living Room Windowsill	Pass
003	Unit 1 Living Room Wall 1	Pass
004	Unit 1 Main Door Jambs	Pass
005	Unit 1 Living Room Wall 2	Pass
006	Unit 1 Kitchen Wall 1	Pass
007	Unit 1 Kitchen Wall 2	Pass
008	Unit 1 Bedroom Door	Pass
009	Unit 1 Bedroom Windowsill	Pass
010	Unit 1 Bedroom Wall 1	Pass
011	Unit 1 Bedroom Wall 2	Pass
012	Unit 1 Bathroom Door	Pass
013	Unit 1 Bathroom Wall 1	Pass
014	Unit 1 Bathroom Wall 2	Pass
015	Unit 1 Living Room Wall 3	Pass
016	Unit 1 Living Room Wall 4	Pass
017	Unit 1 Bedroom Wall 3	Pass
018	Unit 1 Bedroom Wall 4	Pass

001	Unit 2 Main Door	Pass
002	Unit 2 Living Room Windowsill	Pass
003	Unit 2 Living Room Wall 1	Pass
004	Unit 2 Main Door Jambs	Pass
005	Unit 2 Living Room Wall 2	Pass
006	Unit 2 Kitchen Wall 1	Pass
007	Unit 2 Kitchen Wall 2	Pass
008	Unit 2 Bedroom Door	Pass
009	Unit 2 Bedroom Windowsill	Pass
010	Unit 2 Bedroom Wall 1	Pass
011	Unit 2 Bedroom Wall 2	Pass
012	Unit 2 Bathroom Door	Pass
013	Unit 2 Bathroom Wall 1	Pass
014	Unit 2 Bathroom Wall 2	Pass
015	Unit 2 Living Room Wall 3	Pass
016	Unit 2 Living Room Wall 4	Pass
017	Unit 2 Bedroom Wall 3	Pass
018	Unit 2 Bedroom Wall 4	Pass

001	Unit 3 Main Door	Pass
002	Unit 3 Living Room Windowsill	Pass
003	Unit 3 Living Room Wall 1	Pass
004	Unit 3 Main Door Jambs	Pass
005	Unit 3 Living Room Wall 2	Pass
006	Unit 3 Kitchen Wall 1	Pass
007	Unit 3 Kitchen Wall 2	Pass
008	Unit 3 Bedroom Door	Pass
009	Unit 3 Bedroom Windowsill	Pass
010	Unit 3 Bedroom Wall 1	Pass
011	Unit 3 Bedroom Wall 2	Pass
012	Unit 3 Bathroom Door	Pass
013	Unit 3 Bathroom Wall 1	Pass
014	Unit 3 Bathroom Wall 2	Pass
015	Unit 3 Living Room Wall 3	Pass
016	Unit 3 Living Room Wall 4	Pass
017	Unit 3 Bedroom Wall 3	Pass
018	Unit 3 Bedroom Wall 4	Pass

001	Unit 4 Main Door	Pass
002	Unit 4 Living Room Windowsill	Pass
003	Unit 4 Living Room Wall 1	Pass
004	Unit 4 Main Door Jambs	Pass
005	Unit 4 Living Room Wall 2	Pass
006	Unit 4 Kitchen Wall 1	Pass
007	Unit 4 Kitchen Wall 2	Pass
008	Unit 4 Bedroom Door	Pass
009	Unit 4 Bedroom Windowsill	Pass
010	Unit 4 Bedroom Wall 1	Pass
011	Unit 4 Bedroom Wall 2	Pass
012	Unit 4 Bathroom Door	Pass
013	Unit 4 Bathroom Wall 1	Pass
014	Unit 4 Bathroom Wall 2	Pass
015	Unit 4 Living Room Wall 3	Pass
016	Unit 4 Living Room Wall 4	Pass
017	Unit 4 Bedroom Wall 3	Pass
018	Unit 4 Bedroom Wall 4	Pass

001	Unit 5 Main Door	Pass
002	Unit 5 Living Room Windowsill	Pass
003	Unit 5 Living Room Wall 1	Pass
004	Unit 5 Main Door Jambs	Pass
005	Unit 5 Living Room Wall 2	Pass
006	Unit 5 Kitchen Wall 1	Pass
007	Unit 5 Kitchen Wall 2	Pass
008	Unit 5 Bedroom Door	Pass
009	Unit 5 Bedroom Windowsill	Pass
010	Unit 5 Bedroom Wall 1	Pass
011	Unit 5 Bedroom Wall 2	Pass
012	Unit 5 Bathroom Door	Pass
013	Unit 5 Bathroom Wall 1	Pass
014	Unit 5 Bathroom Wall 2	Pass
015	Unit 5 Living Room Wall 3	Pass
016	Unit 5 Living Room Wall 4	Pass
017	Unit 5 Bedroom Wall 3	Pass
018	Unit 5 Bedroom Wall 4	Pass

001	Unit 6 Main Door	Pass
002	Unit 6 Living Room Windowsill	Pass
003	Unit 6 Living Room Wall 1	Pass
004	Unit 6 Main Door Jambs	Pass
005	Unit 6 Living Room Wall 2	Pass
006	Unit 6 Kitchen Wall 1	Pass
007	Unit 6 Kitchen Wall 2	Pass
008	Unit 6 Bedroom Door	Pass
009	Unit 6 Bedroom Windowsill	Pass
010	Unit 6 Bedroom Wall 1	Pass
011	Unit 6 Bedroom Wall 2	Pass
012	Unit 6 Bathroom Door	Pass
013	Unit 6 Bathroom Wall 1	Pass
014	Unit 6 Bathroom Wall 2	Pass
015	Unit 6 Living Room Wall 3	Pass
016	Unit 6 Living Room Wall 4	Pass
017	Unit 6 Bedroom Wall 3	Pass
018	Unit 6 Bedroom Wall 4	Pass

001	Unit 7 Main Door	Pass
002	Unit 7 Living Room Windowsill	Pass
003	Unit 7 Living Room Wall 1	Pass
004	Unit 7 Main Door Jambs	Pass
005	Unit 7 Living Room Wall 2	Pass
006	Unit 7 Kitchen Wall 1	Pass
007	Unit 7 Kitchen Wall 2	Pass
008	Unit 7 Bedroom Door	Pass
009	Unit 7 Bedroom Windowsill	Pass
010	Unit 7 Bedroom Wall 1	Pass
011	Unit 7 Bedroom Wall 2	Pass
012	Unit 7 Bathroom Door	Pass
013	Unit 7 Bathroom Wall 1	Pass
014	Unit 7 Bathroom Wall 2	Pass
015	Unit 7 Living Room Wall 3	Pass
016	Unit 7 Living Room Wall 4	Pass
017	Unit 7 Bedroom Wall 3	Pass
018	Unit 7 Bedroom Wall 4	Pass

001	Unit 8 Main Door	Pass
002	Unit 8 Living Room Windowsill	Pass
003	Unit 8 Living Room Wall 1	Pass
004	Unit 8 Main Door Jambs	Pass
005	Unit 8 Living Room Wall 2	Pass
006	Unit 8 Kitchen Wall 1	Pass
007	Unit 8 Kitchen Wall 2	Pass
008	Unit 8 Bedroom Door	Pass
009	Unit 8 Bedroom Windowsill	Pass
010	Unit 8 Bedroom Wall 1	Pass
011	Unit 8 Bedroom Wall 2	Pass
012	Unit 8 Bathroom Door	Pass
013	Unit 8 Bathroom Wall 1	Pass
014	Unit 8 Bathroom Wall 2	Pass
015	Unit 8 Living Room Wall 3	Pass
016	Unit 8 Living Room Wall 4	Pass
017	Unit 8 Bedroom Wall 3	Pass
018	Unit 8 Bedroom Wall 4	Pass

001	Unit 9 Main Door	Pass
002	Unit 9 Living Room Windowsill	Pass
003	Unit 9 Living Room Wall 1	Pass
004	Unit 9 Main Door Jambs	Pass
005	Unit 9 Living Room Wall 2	Pass
006	Unit 9 Kitchen Wall 1	Pass
007	Unit 9 Kitchen Wall 2	Pass
008	Unit 9 Bedroom Door	Pass
009	Unit 9 Bedroom Windowsill	Pass
010	Unit 9 Bedroom Wall 1	Pass
011	Unit 9 Bedroom Wall 2	Pass
012	Unit 9 Bathroom Door	Pass
013	Unit 9 Bathroom Wall 1	Pass
014	Unit 9 Bathroom Wall 2	Pass
015	Unit 9 Living Room Wall 3	Pass
016	Unit 9 Living Room Wall 4	Pass
017	Unit 9 Bedroom Wall 3	Pass
018	Unit 9 Bedroom Wall 4	Pass

001	Unit 10 Main Door	Pass
002	Unit 10 Living Room Windowsill	Pass
003	Unit 10 Living Room Wall 1	Pass
004	Unit 10 Main Door Jambs	Pass
005	Unit 10 Living Room Wall 2	Pass
006	Unit 10 Kitchen Wall 1	Pass
007	Unit 10 Kitchen Wall 2	Pass
008	Unit 10 Bedroom Door	Pass
009	Unit 10 Bedroom Windowsill	Pass
010	Unit 10 Bedroom Wall 1	Pass
011	Unit 10 Bedroom Wall 2	Pass
012	Unit 10 Bathroom Door	Pass
013	Unit 10 Bathroom Wall 1	Pass
014	Unit 10 Bathroom Wall 2	Pass
015	Unit 10 Living Room Wall 3	Pass
016	Unit 10 Living Room Wall 4	Pass
017	Unit 10 Bedroom Wall 3	Pass
018	Unit 10 Bedroom Wall 4	Pass

001	Unit 11 Main Door	Pass
002	Unit 11 Living Room Windowsill	Pass
003	Unit 11 Living Room Wall 1	Pass
004	Unit 11 Main Door Jambs	Pass
005	Unit 11 Living Room Wall 2	Pass
006	Unit 11 Kitchen Wall 1	Pass
007	Unit 11 Kitchen Wall 2	Pass
008	Unit 11 Bedroom Door	Pass
009	Unit 11 Bedroom Windowsill	Pass
010	Unit 11 Bedroom Wall 1	Pass
011	Unit 11 Bedroom Wall 2	Pass
012	Unit 11 Bathroom Door	Pass
013	Unit 11 Bathroom Wall 1	Pass
014	Unit 11 Bathroom Wall 2	Pass
015	Unit 11 Living Room Wall 3	Pass
016	Unit 11 Living Room Wall 4	Pass
017	Unit 11 Bedroom Wall 3	Pass
018	Unit 11 Bedroom Wall 4	Pass

001	Unit 12 Main Door	Pass
002	Unit 12 Living Room Windowsill	Pass
003	Unit 12 Living Room Wall 1	Pass
004	Unit 12 Main Door Jambs	Pass
005	Unit 12 Living Room Wall 2	Pass
006	Unit 12 Kitchen Wall 1	Pass
007	Unit 12 Kitchen Wall 2	Pass
008	Unit 12 Bedroom Door	Pass
009	Unit 12 Bedroom Windowsill	Pass
010	Unit 12 Bedroom Wall 1	Pass
011	Unit 12 Bedroom Wall 2	Pass
012	Unit 12 Bathroom Door	Pass
013	Unit 12 Bathroom Wall 1	Pass
014	Unit 12 Bathroom Wall 2	Pass
015	Unit 12 Living Room Wall 3	Pass
016	Unit 12 Living Room Wall 4	Pass
017	Unit 12 Bedroom Wall 3	Pass
018	Unit 12 Bedroom Wall 4	Pass

001	Unit 13 Main Door	Pass
002	Unit 13 Living Room Windowsill	Pass
003	Unit 13 Living Room Wall 1	Pass
004	Unit 13 Main Door Jambs	Pass
005	Unit 13 Living Room Wall 2	Pass
006	Unit 13 Kitchen Wall 1	Pass
007	Unit 13 Kitchen Wall 2	Pass
008	Unit 13 Bedroom Door	Pass
009	Unit 13 Bedroom Windowsill	Pass
010	Unit 13 Bedroom Wall 1	Pass
011	Unit 13 Bedroom Wall 2	Pass
012	Unit 13 Bathroom Door	Pass
013	Unit 13 Bathroom Wall 1	Pass
014	Unit 13 Bathroom Wall 2	Pass
015	Unit 13 Living Room Wall 3	Pass
016	Unit 13 Living Room Wall 4	Pass
017	Unit 13 Bedroom Wall 3	Pass
018	Unit 13 Bedroom Wall 4	Pass

001	Unit 14 Main Door	Pass
002	Unit 14 Living Room Windowsill	Pass
003	Unit 14 Living Room Wall 1	Pass
004	Unit 14 Main Door Jambs	Pass
005	Unit 14 Living Room Wall 2	Pass
006	Unit 14 Kitchen Wall 1	Pass
007	Unit 14 Kitchen Wall 2	Pass
008	Unit 14 Bedroom Door	Pass
009	Unit 14 Bedroom Windowsill	Pass
010	Unit 14 Bedroom Wall 1	Pass
011	Unit 14 Bedroom Wall 2	Pass
012	Unit 14 Bathroom Door	Pass
013	Unit 14 Bathroom Wall 1	Pass
014	Unit 14 Bathroom Wall 2	Pass
015	Unit 14 Living Room Wall 3	Pass
016	Unit 14 Living Room Wall 4	Pass
017	Unit 14 Bedroom Wall 3	Pass
018	Unit 14 Bedroom Wall 4	Pass

001	Unit 15 Main Door	Pass
002	Unit 15 Living Room Windowsill	Pass
003	Unit 15 Living Room Wall 1	Pass
004	Unit 15 Main Door Jambs	Pass
005	Unit 15 Living Room Wall 2	Pass
006	Unit 15 Kitchen Wall 1	Pass
007	Unit 15 Kitchen Wall 2	Pass
008	Unit 15 Bedroom Door	Pass
009	Unit 15 Bedroom Windowsill	Pass
010	Unit 15 Bedroom Wall 1	Pass
011	Unit 15 Bedroom Wall 2	Pass
012	Unit 15 Bathroom Door	Pass
013	Unit 15 Bathroom Wall 1	Pass
014	Unit 15 Bathroom Wall 2	Pass
015	Unit 15 Living Room Wall 3	Pass
016	Unit 15 Living Room Wall 4	Pass
017	Unit 15 Bedroom Wall 3	Pass
018	Unit 15 Bedroom Wall 4	Pass

Table 56. Lead Based Paint Test Results Table

1130 Sheffield Street - Unit 1		
Sample #	Location	Pass/ Fail
001	Unit 1 Main Door	Pass
002	Unit 1 Living Room Windowsill	Pass
003	Unit 1 Living Room Wall 1	Pass
004	Unit 1 Living Room Wall 2	Pass
005	Unit 1 Kitchen Wall 1	Pass
006	Unit 1 Kitchen Wall 2	Pass
007	Unit 1 Dining Room Wall 1	Pass
008	Unit 1 Dining Room Wall 2	Pass
009	Unit 1 Bedroom 1 Door	Pass

010	Unit 1 Bedroom 1 Windowsill	Pass
011	Unit 1 Bedroom 1 Wall 1	Pass
012	Unit 1 Bedroom 1 Wall 2	Pass
013	Unit 1 Bedroom 2 Door	Pass
014	Unit 1 Bedroom 2 Windowsill	Pass
015	Unit 1 Bedroom 2 Wall 1	Pass
016	Unit 1 Bedroom 2 Wall 2	Pass
017	Unit 1 Bathroom Door	Pass
018	Unit 1 Bathroom Wall 1	Pass
019	Unit 1 Bathroom Wall 2	Pass
020	Unit 1 Living Room Wall 3	Pass
021	Unit 1 Living Room Wall 4	Pass
022	Unit 1 Bedroom 1 Wall 3	Pass
023	Unit 1 Bedroom 1 Wall 4	Pass
024	Unit 1 Bedroom 2 Wall 3	Pass
025	Unit 1 Bedroom 2 Wall 4	Pass

Table 57. Lead Based Paint Test Results Table

1130 Sheffield Street - Unit 2		
Sample #	Location	Pass/Fail
001	Unit 2 Main Door	Pass
002	Unit 2 Living Room Windowsill	Pass
003	Unit 2 Living Room Wall 1	Pass
004	Unit 2 Living Room Wall 2	Pass
005	Unit 2 Kitchen Wall 1	Pass
006	Unit 2 Kitchen Wall 2	Pass
007	Unit 2 Dining Room Wall 1	Pass
008	Unit 2 Dining Room Wall 2	Pass
009	Unit 2 Bedroom 1 Door	Pass

010	Unit 2 Bedroom 1 Windowsill	Pass
011	Unit 2 Bedroom 1 Wall 1	Pass
012	Unit 2 Bedroom 1 Wall 2	Pass
013	Unit 2 Bedroom 2 Door	Pass
014	Unit 2 Bedroom 2 Windowsill	Pass
015	Unit 2 Bedroom 2 Wall 1	Pass
016	Unit 2 Bedroom 2 Wall 2	Pass
017	Unit 2 Bathroom Door	Pass
018	Unit 2 Bathroom Wall 1	Pass
019	Unit 2 Bathroom Wall 2	Pass
020	Unit 2 Living Room Wall 3	Pass
021	Unit 2 Living Room Wall 4	Pass
022	Unit 2 Bedroom 1 Wall 3	Pass
023	Unit 2 Bedroom 1 Wall 4	Pass
024	Unit 2 Bedroom 2 Wall 3	Pass
025	Unit 2 Bedroom 2 Wall 4	Pass

Table 58. Lead Based Paint Test Results Table

1130 Sheffield Street - Unit 3		
Sample #	Location	Pass/Fail
001	Unit 3 Main Door	Pass
002	Unit 3 Living Room Windowsill	Pass
003	Unit 3 Living Room Wall 1	Pass
004	Unit 3 Living Room Wall 2	Pass
005	Unit 3 Kitchen Wall 1	Pass
006	Unit 3 Kitchen Wall 2	Pass
007	Unit 3 Dining Room Wall 1	Pass
008	Unit 3 Dining Room Wall 2	Pass
009	Unit 3 Bedroom 1 Door	Pass

010	Unit 3 Bedroom 1 Windowsill	Pass
011	Unit 3 Bedroom 1 Wall 1	Pass
012	Unit 3 Bedroom 1 Wall 2	Pass
013	Unit 3 Bedroom 2 Door	Pass
014	Unit 3 Bedroom 2 Windowsill	Pass
015	Unit 3 Bedroom 2 Wall 1	Pass
016	Unit 3 Bedroom 2 Wall 2	Pass
017	Unit 3 Bathroom Door	Pass
018	Unit 3 Bathroom Wall 1	Pass
019	Unit 3 Bathroom Wall 2	Pass
020	Unit 3 Living Room Wall 3	Pass
021	Unit 3 Living Room Wall 4	Pass
022	Unit 3 Bedroom 1 Wall 3	Pass
023	Unit 3 Bedroom 1 Wall 4	Pass
024	Unit 3 Bedroom 2 Wall 3	Pass
025	Unit 3 Bedroom 2 Wall 4	Pass

Table 59. Lead Based Paint Test Results Table

1111 Sheffield Street – Unit 1		
Sample #	Location	Pass/ Fail
001	1st Floor Main Door	Pass
002	1 st Floor Living Room Wall 1	Pass
003	1 st Floor Living Room Windowsill	Pass
004	1 st Floor Kitchen Wall 1	Pass
005	1 st Floor Kitchen Windowsill	Pass
006	1 st Floor Dining Room Wall 1	Pass
007	1 st Floor Dining Room Wall 2	Pass
008	1 st Floor Bathroom Door	Pass
009	1 st Floor Bathroom Wall	Pass
010	1 st Floor Laundry Room Door	Pass
011	1 st Floor Laundry Room Wall	Pass
012	1 st Floor Room 1 Door	Pass
013	1 st Floor Room 2 Door	Pass
014	1 st Floor Room 1 Windowsill	Pass
015	1 st Floor Room 2 Windowsill	Pass
016	1 st Floor Room 1 Wall 1	Pass
017	1 st Floor Room 1 Wall 2	Pass
018	1 st Floor Room 2 Wall 1	Pass
019	1 st Floor Room 2 Wall 2	Pass
020	1 st Floor Living Room Wall 2	Pass
021	1 st Floor Living Room Wall 3	Pass

022	1 st Floor Living Room Wall 4	Pass
023	1 st Floor Kitchen Wall 2	Pass
024	1 st Floor Room 1 Wall 3	Pass
025	1 st Floor Room 1 Wall 4	Pass
026	1 st Floor Room 2 Wall 3	Pass
027	1 st Floor Room 2 Wall 4	Pass

Table 60. Lead Based Paint Test Results Table

1111 Sheffield Street – Unit 2		
Sample #	Location	Pass/Fail
001	1st Floor Main Door	Pass
002	1 st Floor Living Room Wall 1	Pass
003	1 st Floor Living Room Windowsill	Pass
004	1 st Floor Living Room Wall 2	Pass
005	1 st Floor Kitchen Wall 1	Pass
006	1 st Floor Kitchen Windowsill	Pass
007	2 nd Floor Room 1 Door	Pass
008	2 nd Floor Room 2 Door	Pass
009	2 nd Floor Bathroom Door	Pass
010	2 nd Floor Room 1 Windowsill	Pass
011	2 nd Floor Room 2 Windowsill	Pass
012	2 nd Floor Bathroom Windowsill	Pass
013	2 nd Floor Room 1 Wall 1	Pass
014	2 nd Floor Room 1 Wall 2	Pass
015	2 nd Floor Room 2 Wall 1	Pass
016	2 nd Floor Room 2 Wall 2	Pass
017	2 nd Floor Bathroom Wall 1	Pass
018	2 nd Floor Bathroom Wall 2	Pass
019	2 nd Floor Stairway wall	Pass

020	1 st Floor Living Room Wall 3	Pass
021	1 st Floor Living Room Wall 4	Pass
022	1 st Floor Kitchen Wall 2	Pass
023	2 nd Floor Room 1 Wall 3	Pass
024	2 nd Floor Room 1 Wall 4	Pass
025	2 nd Floor Room 2 Wall 3	Pass
026	2 nd Floor Room 2 Wall 4	Pass

Table 61. Lead Based Paint Test Results Table

1111 Sheffield Street – Unit 3		
Sample #	Location	Pass/ Fail
001	1st Floor Main Door	Pass
002	1 st Floor Living Room Wall 1	Pass
003	1 st Floor Living Room Windowsill	Pass
004	1 st Floor Living Room Wall 2	Pass
005	1 st Floor Kitchen Wall 1	Pass
006	1 st Floor Kitchen Windowsill	Pass
007	2 nd Floor Room 1 Door	Pass
008	2 nd Floor Room 2 Door	Pass
009	2 nd Floor Bathroom Door	Pass
010	2 nd Floor Room 1 Windowsill	Pass
011	2 nd Floor Room 2 Windowsill	Pass
012	2 nd Floor Bathroom Windowsill	Pass
013	2 nd Floor Room 1 Wall 1	Pass
014	2 nd Floor Room 1 Wall 2	Pass
015	2 nd Floor Room 2 Wall 1	Pass
016	2 nd Floor Room 2 Wall 2	Pass
017	2 nd Floor Bathroom Wall 1	Pass
018	2 nd Floor Bathroom Wall 2	Pass
019	1 st Floor Stairway wall	Pass

020	1 st Floor Living Room Wall 3	Pass
021	1 st Floor Living Room Wall 4	Pass
022	1 st Floor Kitchen Wall 2	Pass
023	2 nd Floor Room 1 Wall 3	Pass
024	2 nd Floor Room 1 Wall 4	Pass
025	2 nd Floor Room 2 Wall 3	Pass
026	2 nd Floor Room 2 Wall 4	Pass

Table 62. Lead Based Paint Test Results Table

1529 Sedgwick Street – Unit 1		
Sample #	Location	Pass/ Fail
001	A 1st Floor Main Door (Door Jamb Yellow Paint)	Fail
002	C 1 st Floor Stairway Wall	Pass
003	B Basement Door	Pass
004	B Basement Wall	Pass
005	C 2 nd Floor Kitchen Wall	Pass
006	D 2 nd Floor Kitchen Windowsill	Pass
007	C 2 nd Floor Living Room Wall	Pass
008	A 2 nd Floor Living Room Windowsill	Pass
009	C 2 nd Floor Dining Room Wall 1	Pass
010	A 2 nd Floor Dining Room Windowsill	Pass
011	2 nd Floor Bathroom Door	Pass
012	2 nd Floor Bathroom Windowsill	Pass
013	2 nd Floor Bedroom Door	Pass

014	2 nd Floor Bedroom Windowsill	Pass
015	2 nd Floor Bedroom Wall 1	Pass
016	2 nd Floor Bedroom Wall 2	Pass
017	3 rd Floor Bedroom Wall 1	Pass
018	3 rd Floor Bedroom Wall 2	Pass
019	3 rd Floor Bedroom Door	Pass
020	3 rd Floor Bedroom Windowsill	Pass
021	3 rd Floor Bathroom Wall 1	Pass
022	3 rd Floor Bathroom Wall 2	Pass
023	3 rd Floor Bathroom Door	Pass
024	3 rd Floor Bathroom Windowsill	Pass
025	1 st Floor Stairway wall	Pass
026	2 nd Floor Stairway wall	Pass
027	A 2 nd Floor Living Room Wall	Pass
028	B 2 nd Floor Living Room Wall	Pass
029	D 2 nd Floor Living Room Wall	Pass
030	D 2 nd Floor Kitchen Wall	Pass
031	B 2 nd Floor Kitchen Wall	Pass
032	2 nd Floor Bedroom Wall 3	Pass
033	2 nd Floor Bedroom Wall 4	Pass
034	3 rd Floor Bedroom Wall 3	Pass
035	3 rd Floor Bedroom Wall 4	Pass

Table 63. Lead Based Paint Test Results Table

1529 Sedgwick Street – Unit 2		
Sample #	Location	Pass/ Fail
001	Unit 2 Main Door	Pass
002	Unit 2 Living Room Windowsill	Pass
003	Unit 2 Living Room Wall 1	Pass
004	Unit 2 Living Room Wall 2	Pass
005	Unit 2 Kitchen Wall 1	Pass
006	Unit 2 Kitchen Wall 2	Pass
007	Unit 2 Bedroom Door	Pass
008	Unit 2 Bedroom Windowsill	Pass
009	Unit 2 Bedroom Wall 1	Pass
010	Unit 2 Bedroom Wall 2	Pass
011	Unit 2 Bathroom Door	Pass
012	Unit 2 Bathroom Wall 1	Pass
013	Unit 2 Bathroom Wall 2	Pass
014	Unit 2 Living Room Wall 3	Pass
015	Unit 2 Living Room Wall 4	Pass
016	Unit 2 Bedroom Wall 3	Pass
017	Unit 2 Bedroom Wall 4	Pass

LEAD PRESENT IN SOILS SURVEY:

Lead paint samples were taken utilizing an Olympus Brand, Model Delta Professional (Lead Paint Analyzer), X-Ray Fluorescence Type (XRF), direct reading/data-logging instrument. The XRF takes direct soil sample readings by pointing the XRF on the surface of the soils. The calibration procedure for the XRF is 3 positive calibration readings using the 1.0 mg/cm² calibration block and 3 negative readings at the beginning and end of the survey.

Sample results are electronically stored and downloaded into a spreadsheet format. A comprehensive list of all samples taken are listed in the "Lead in Soils Results Table".

The areas inspected for lead present in soils included the front yard and backyards of all the houses surveyed in the Manchester Project. All the samples that were found positive with lead, have been marked as "Fail" in the results table and the lead content readings have been noted, respectively.

Table 1. Soils – Lead in Soils Results Table

Sample #	Location	Pass/Fail
001	1101 Pennsylvania Avenue	Pass
002	1017 Pennsylvania Avenue	Pass
003	1019 Pennsylvania Avenue	Pass
004	1105 Pennsylvania Avenue	Pass
005	1103 Pennsylvania Avenue	Pass
006	1315 Pennsylvania Avenue	Fail – 67 ppm
007	1104 W North Avenue	Fail – 76 ppm
008	1106 W North Avenue	Pass
009	1108 W North Avenue	Pass
010	1242 W North Avenue	Fail – 48 ppm
011	1406 W North Avenue	Pass
012	1412 W North Avenue	Pass

013	1307 Fulton Street	Pass
014	1307 Fulton Street	Pass
015	1305 Fulton Street	Pass
016	1303 Fulton Street	Pass
017	1107 Sheffield Street	Pass
018	1109 Sheffield Street	Pass
019	1131 Sheffield Street	Pass
020	1133 Sheffield Street	Pass
021	1241 Sheffield Street	Pass
022	1223 Sheffield Street	Pass
023	1225 Sheffield Street	Pass
024	1227 Sheffield Street	Pass
025	1229 Sheffield Street	Pass
026	1134 Sheffield Street	Pass
027	1132 Sheffield Street	Pass
028	1130 Sheffield Street	Fail –214 ppm
029	1111 Sheffield Street	Fail –114 ppm
030	1100 Sheffield Street	Fail –968 ppm, 272 ppm
031	1529 Sedgwick Street	Pass
032	1431 Nixon Street	Fail – 33 ppm
033	1429 Nixon Street	Pass
034	1424 Nixon Street	Pass
035	1422 Nixon Street	Fail – 32 ppm

036	1403 Page Street	Pass
037	1405 Page Street	Pass
038	1208 Liverpool Street	No soils to sample
039	1315 Liverpool Street	Pass
040	1323 Columbus Avenue	Fail – 1631 ppm
041	1325 Columbus Avenue	Fail – 2597 ppm
042	1327 Columbus Avenue	Fail – 535 ppm
043	1335 N Franklin Street	Fail – 118 ppm
044	1333 N Franklin Street	Pass
045	1331 N Franklin Street	Pass
046	1329 N Franklin Street	Pass
047	1331 Adams Street	Pass
048	1337 Adams Street	Pass
049	1341 Adams Street	Fail – 75 ppm
050	1402 Adams Street	Pass
051	1404 Adams Street	Fail –123 ppm
052	1406 Adams Street	Pass
053	1439 Adams Street	Fail –172 ppm
054	1441 Adams Street	Pass
055	1443 Adams Street	Pass
056	1205 Juniata Street	Fail – 37 ppm
057	1207 Juniata Street	Fail – 99 ppm

ATTACHMENT A

jh2g3-zlih

Instrument Serial Num	Reading #	Date	Time	Method Name	Test Label	Collimation Status	Units	Pb Concentration	Pb Error1s	Test Count	Operator	Quality	Real Time 1
806226	1	2020-06-15	08:15:56	Cal Check	1C	No	mg/cm2						0.06288
806226	2	2020-06-15	08:17:01	Cal Check	2C	No	mg/cm2						15
806226	3	2020-06-15	08:20:59	LeadPaint		3 No	mg/cm:	0	0.00009	1 ru	Accept		30
806226	4	2020-06-15	08:22:17	LeadPaint		4 No	mg/cm:	0	0.00009	2 ru	Accept		13.2014
806226	5	2020-06-15	08:25:40	LeadPaint		5 No	mg/cm:	0	0.00006	3 ru	Accept		30
806226	6	2020-06-15	08:26:36	LeadPaint		6 No	mg/cm:	0	0.00006	4 ru	Accept		30
806226	7	2020-06-15	08:27:37	LeadPaint		7 No	mg/cm:	0	0.00006	5 ru	Accept		30
806226	8	2020-06-15	08:28:39	LeadPaint		8 No	mg/cm:	0	0.00006	6 ru	Accept		30
806226	9	2020-06-15	08:29:50	LeadPaint		9 No	mg/cm:	0	0.00009	7 ru	Accept		30
806226	10	2020-06-15	08:30:50	LeadPaint		10 No	mg/cm:	0	0.00008	8 ru	Accept		30
806226	11	2020-06-15	08:31:55	LeadPaint		11 No	mg/cm:	0	0.00065	9 ru	Accept		30
806226	12	2020-06-15	08:33:39	LeadPaint		12 No	mg/cm:	0	0.00009	10 ru	Accept		30
806226	13	2020-06-15	08:36:22	LeadPaint		13 No	mg/cm:	0	0.00013	11 ru	Accept		10.1642
806226	14	2020-06-15	08:36:55	LeadPaint		14 No	mg/cm:	0	0.00009	12 ru	Accept		30
806226	15	2020-06-15	08:37:45	LeadPaint		15 No	mg/cm:	0	0.00006	13 ru	Accept		30
806226	16	2020-06-15	08:38:32	LeadPaint		16 No	mg/cm:	0	0.00008	14 ru	Accept		17.8964
806226	17	2020-06-15	08:39:05	LeadPaint		17 No	mg/cm:	0	0.00006	15 ru	Accept		30
806226	18	2020-06-15	08:40:09	LeadPaint		18 No	mg/cm:	0	0.00009	16 ru	Accept		14.8386
806226	19	2020-06-15	08:40:34	LeadPaint		19 No	mg/cm:	0	0.00013	17 ru	Accept		10.8039
806226	20	2020-06-15	08:41:35	LeadPaint		20 No	mg/cm:	0	0.00011	18 ru	Accept		18.0603
806226	21	2020-06-15	08:42:36	LeadPaint		21 No	mg/cm:	0	0.00013	19 ru	Accept		13.9446
806226	22	2020-06-15	08:55:36	LeadPaint		22 No	mg/cm:	0	0.0001	19 ru	Accept		13.7268
806226	23	2020-06-15	08:56:04	LeadPaint		23 No	mg/cm:	0	0.0001	20 ru	Accept		17.9361
806226	24	2020-06-15	08:56:38	LeadPaint		24 No	mg/cm:	0	0.00008	21 ru	Accept		16.8444
806226	25	2020-06-15	08:57:06	LeadPaint		25 No	mg/cm:	0	0.0001	22 ru	Accept		12.7891
806226	26	2020-06-15	08:57:29	LeadPaint		26 No	mg/cm:	0	0.00021	23 ru	Accept		13.4803
806226	27	2020-06-15	08:58:03	LeadPaint		27 No	mg/cm:	0	0.00012	24 ru	Accept		12.845
806226	28	2020-06-15	08:58:30	LeadPaint		28 No	mg/cm:	0	0.00011	25 ru	Accept		14.315
806226	29	2020-06-15	08:59:01	LeadPaint		29 No	mg/cm:	0	0.00012	26 ru	Accept		12.0241
806226	30	2020-06-15	08:59:19	LeadPaint		30 No	mg/cm:	0	0.0001	27 ru	Accept		10.4545
806226	31	2020-06-15	08:59:37	LeadPaint		31 No	mg/cm:	0	0.0001	28 ru	Accept		12.1541
806226	32	2020-06-15	09:00:26	LeadPaint		32 No	mg/cm:	0	0.00031	29 ru	Accept		2.71195
806226	33	2020-06-15	09:00:35	LeadPaint		33 No	mg/cm:	0	0.00014	30 ru	Accept		14.3004
806226	34	2020-06-15	09:00:57	LeadPaint		34 No	mg/cm:	0	0.0001	31 ru	Accept		13.6902
806226	35	2020-06-15	09:01:41	LeadPaint		35 No	mg/cm2				Accept		
806226	36	2020-06-15	09:03:23	LeadPaint		36 No	mg/cm:	0	0.00018	33 ru	Accept		7.41161
806226	37	2020-06-15	09:03:41	LeadPaint		37 No	mg/cm:	0	0.00013	34 ru	Accept		12.8989
806226	38	2020-06-15	09:04:04	LeadPaint		38 No	mg/cm:	0	0.00014	35 ru	Accept		8.18624
806226	39	2020-06-15	09:04:22	LeadPaint		39 No	mg/cm:	0	0.00013	36 ru	Accept		7.97251
806226	40	2020-06-15	09:04:45	LeadPaint		40 No	mg/cm:	0	0.00014	37 ru	Accept		12.8774
806226	41	2020-06-15	09:05:05	LeadPaint		41 No	mg/cm:	0	0.00014	38 ru	Accept		6.41263
806226	42	2020-06-15	09:05:24	LeadPaint		42 No	mg/cm:	0	0.00011	39 ru	Accept		12.3752
806226	43	2020-06-15	09:05:49	LeadPaint		43 No	mg/cm:	0	0.00014	40 ru	Accept		12.8024
806226	44	2020-06-15	09:06:14	LeadPaint		44 No	mg/cm:	0	0.00014	41 ru	Accept		12.3964

jh2g3-zlih3

806226	45	2020-06-15	09:06:42	LeadPaint	45	No	mg/cm:	0	0.00013	42	ru	Accept	12.5929
806226	46	2020-06-15	09:07:15	LeadPaint	46	No	mg/cm:	0	0.00012	43	ru	Accept	12.8161
806226	47	2020-06-15	09:07:34	LeadPaint	47	No	mg/cm:	0	0.00015	44	ru	Accept	6.30197
806226	48	2020-06-15	09:07:50	LeadPaint	48	No	mg/cm:	0	0.00013	45	ru	Accept	12.8501
806226	49	2020-06-15	09:12:41	LeadPaint	49	No	mg/cm:	0	0.00013	45	ru	Accept	15.1929
806226	50	2020-06-15	09:14:28	LeadPaint	50	No	mg/cm:	0	0.00013	46	ru	Accept	12.2045
806226	51	2020-06-15	09:15:42	LeadPaint	51	No	mg/cm:	0	0.00018	47	ru	Accept	3.91858
806226	52	2020-06-15	09:15:59	LeadPaint	52	No	mg/cm:	0	0.00013	48	ru	Accept	7.64982
806226	53	2020-06-15	09:16:20	LeadPaint	53	No	mg/cm:	0	0.0001	49	ru	Accept	12.3616
806226	54	2020-06-15	09:16:52	LeadPaint	54	No	mg/cm:	0	0.00014	50	ru	Accept	12.145
806226	55	2020-06-15	09:17:20	LeadPaint	55	No	mg/cm:	0	0.00014	51	ru	Accept	12.4828
806226	56	2020-06-15	09:17:40	LeadPaint	56	No	mg/cm:	0	0.0001	52	ru	Accept	11.7819
806226	57	2020-06-15	09:18:15	LeadPaint	57	No	mg/cm:	0	0.00014	53	ru	Accept	12.4677
806226	58	2020-06-15	09:18:35	LeadPaint	58	No	mg/cm:	0	0.00014	54	ru	Accept	12.5836
806226	59	2020-06-15	09:20:05	LeadPaint	59	No	mg/cm:	0	0.00014	55	ru	Accept	12.0705
806226	60	2020-06-15	09:20:27	LeadPaint	60	No	mg/cm:	0	0.00011	56	ru	Accept	12.391
806226	61	2020-06-15	09:20:46	LeadPaint	61	No	mg/cm:	0	0.00014	57	ru	Accept	12.5318
806226	62	2020-06-15	09:21:12	LeadPaint	62	No	mg/cm:	0	0.00014	58	ru	Accept	12.574
806226	63	2020-06-15	09:21:32	LeadPaint	63	No	mg/cm:	0	0.00009	59	ru	Accept	13.8553
806226	64	2020-06-15	09:21:54	LeadPaint	64	No	mg/cm:	0	0.00012	60	ru	Accept	17.6532
806226	65	2020-06-15	09:22:26	LeadPaint	65	No	mg/cm:	0	0.00013	61	ru	Accept	12.4879
806226	66	2020-06-15	09:22:46	LeadPaint	66	No	mg/cm:	0	0.0001	62	ru	Accept	11.0341
806226	67	2020-06-15	09:23:06	LeadPaint	67	No	mg/cm:	0	0.00013	63	ru	Accept	13.5704
806226	68	2020-06-15	09:23:35	LeadPaint	68	No	mg/cm:	0	0.00016	64	ru	Accept	5.39218
806226	69	2020-06-15	09:23:46	LeadPaint	69	No	mg/cm:	0	0.00015	65	ru	Accept	12.0984
806226	70	2020-06-15	09:24:04	LeadPaint	70	No	mg/cm:	0	0.00014	66	ru	Accept	12.4465
806226	71	2020-06-15	09:35:29	LeadPaint	71	No	mg/cm:	0	0.00012	66	ru	Accept	12.3435
806226	72	2020-06-15	09:36:01	LeadPaint	72	No	mg/cm:	0	0.00111	67	ru	Accept	13.177
806226	73	2020-06-15	09:36:40	LeadPaint	73	No	mg/cm:	0	0.00012	68	ru	Accept	12.3346
806226	74	2020-06-15	09:36:59	LeadPaint	74	No	mg/cm:	0	0.00011	69	ru	Accept	12.0317
806226	75	2020-06-15	09:37:25	LeadPaint	75	No	mg/cm:	0	0.00011	70	ru	Accept	12.3561
806226	76	2020-06-15	09:37:44	LeadPaint	76	No	mg/cm:	0	0.00013	71	ru	Accept	13.2632
806226	77	2020-06-15	09:38:09	LeadPaint	77	No	mg/cm:	0	0.00013	72	ru	Accept	12.359
806226	78	2020-06-15	09:38:28	LeadPaint	78	No	mg/cm:	0	0.00013	73	ru	Accept	12.4823
806226	79	2020-06-15	09:38:47	LeadPaint	79	No	mg/cm:	0	0.00013	74	ru	Accept	12.037
806226	80	2020-06-15	09:40:20	LeadPaint	80	No	mg/cm:	0	0.00014	75	ru	Accept	12.6062
806226	81	2020-06-15	09:40:38	LeadPaint	81	No	mg/cm:	0	0.0001	76	ru	Accept	12.0351
806226	82	2020-06-15	09:41:02	LeadPaint	82	No	mg/cm:	0	0.00015	77	ru	Accept	12.3272
806226	83	2020-06-15	09:41:27	LeadPaint	83	No	mg/cm:	0	0.00013	78	ru	Accept	12.3069
806226	84	2020-06-15	09:41:44	LeadPaint	84	No	mg/cm:	0	0.00012	79	ru	Accept	11.8077
806226	85	2020-06-15	09:42:06	LeadPaint	85	No	mg/cm:	0	0.00014	80	ru	Accept	11.9881
806226	86	2020-06-15	09:42:27	LeadPaint	86	No	mg/cm:	0	0.00015	81	ru	Accept	12.1314
806226	87	2020-06-15	09:42:45	LeadPaint	87	No	mg/cm:	0	0.00011	82	ru	Accept	12.0764
806226	88	2020-06-15	09:43:03	LeadPaint	88	No	mg/cm:	0	0.00013	83	ru	Accept	14.1146
806226	89	2020-06-15	09:43:32	LeadPaint	89	No	mg/cm:	0	0.00059	84	ru	Accept	0.675272

jh2g3-zlih3

806226	90	2020-06-15	09:43:41	LeadPaint	90	No	mg/cm:	0	0.00014	85	ru	Accept	12.3825
806226	91	2020-06-15	12:14:22	LeadPaint	91	No	mg/cm:	0	0.00025	85	ru	Accept	3.75494
806226	92	2020-06-15	12:14:48	LeadPaint	92	No	mg/cm:	0	0.00014	86	ru	Accept	12.5104
806226	93	2020-06-15	12:15:08	LeadPaint	93	No	mg/cm:	0	0.0001	87	ru	Accept	11.9715
806226	94	2020-06-15	12:15:29	LeadPaint	94	No	mg/cm:	0	0.00009	88	ru	Accept	12.792
806226	95	2020-06-15	12:15:50	LeadPaint	95	No	mg/cm:	0	0.00014	89	ru	Accept	11.9745
806226	96	2020-06-15	12:16:12	LeadPaint	96	No	mg/cm:	0	0.0001	90	ru	Accept	12.2151
806226	97	2020-06-15	12:16:35	LeadPaint	97	No	mg/cm:	0	0.00015	91	ru	Accept	11.9403
806226	98	2020-06-15	12:16:57	LeadPaint	98	No	mg/cm:	0	0.00017	92	ru	Accept	5.27801
806226	99	2020-06-15	12:17:12	LeadPaint	99	No	mg/cm:	0	0.00011	93	ru	Accept	11.8415
806226	100	2020-06-15	12:17:50	LeadPaint	100	No	mg/cm:	0	0.00013	94	ru	Accept	12.1033
806226	101	2020-06-15	12:18:09	LeadPaint	101	No	mg/cm:	0	0.0001	95	ru	Accept	12.0212
806226	102	2020-06-15	12:18:28	LeadPaint	102	No	mg/cm:	0	0.00011	96	ru	Accept	11.9133
806226	103	2020-06-15	12:18:44	LeadPaint	103	No	mg/cm:	0	0.00014	97	ru	Accept	12.2799
806226	104	2020-06-15	12:19:07	LeadPaint	104	No	mg/cm:	0	0.00013	98	ru	Accept	12.0902
806226	105	2020-06-15	12:19:24	LeadPaint	105	No	mg/cm:	0	0.0001	99	ru	Accept	11.9525
806226	106	2020-06-15	12:19:45	LeadPaint	106	No	mg/cm:	0	0.0001	100	ru	Accept	12.4476
806226	107	2020-06-15	12:20:04	LeadPaint	107	No	mg/cm:	0	0.00015	101	ru	Accept	12.3082
806226	108	2020-06-15	12:20:33	LeadPaint	108	No	mg/cm:	0	0.00014	102	ru	Accept	12.333
806226	109	2020-06-15	12:20:55	LeadPaint	109	No	mg/cm:	0	0.00014	103	ru	Accept	12.3306
806226	110	2020-06-15	12:21:12	LeadPaint	110	No	mg/cm:	0	0.0001	104	ru	Accept	12.2269
806226	111	2020-06-15	12:21:30	LeadPaint	111	No	mg/cm:	0	0.00014	105	ru	Accept	12.7864
806226	112	2020-06-15	12:21:49	LeadPaint	112	No	mg/cm:	0	0.00014	106	ru	Accept	12.2643
806226	113	2020-06-15	12:23:31	LeadPaint	113	No	mg/cm:	0	0.00015	107	ru	Accept	12.3759
806226	114	2020-06-15	12:23:55	LeadPaint	114	No	mg/cm:	0	0.00009	108	ru	Accept	15.093
806226	115	2020-06-15	12:24:19	LeadPaint	115	No	mg/cm:	0	0.00009	109	ru	Accept	16.3073
806226	116	2020-06-15	12:24:48	LeadPaint	116	No	mg/cm:	0	0.0001	110	ru	Accept	12.265
806226	117	2020-06-15	12:25:13	LeadPaint	117	No	mg/cm:	0	0.00012	111	ru	Accept	12.3618
806226	118	2020-06-15	12:25:32	LeadPaint	118	No	mg/cm:	0	0.0001	112	ru	Accept	11.7679
806226	119	2020-06-15	12:25:52	LeadPaint	119	No	mg/cm:	0	0.00013	113	ru	Accept	12.4988
806226	120	2020-06-15	12:26:14	LeadPaint	120	No	mg/cm:	0	0.00014	114	ru	Accept	12.2056
806226	121	2020-06-15	12:26:33	LeadPaint	121	No	mg/cm:	0	0.00014	115	ru	Accept	12.2725
806226	122	2020-06-15	12:26:54	LeadPaint	122	No	mg/cm:	0	0.00021	116	ru	Accept	2.55049
806226	123	2020-06-15	12:27:17	LeadPaint	123	No	mg/cm2			117	ru	Accept	
806226	124	2020-06-15	12:28:11	LeadPaint	124	No	mg/cm2			118	ru	Accept	
806226	125	2020-06-15	12:28:21	LeadPaint	125	No	mg/cm2			119	ru	Accept	
806226	126	2020-06-15	12:28:27	LeadPaint	126	No	mg/cm2			120	ru	Accept	
806226	127	2020-06-15	12:28:52	LeadPaint	127	No	mg/cm2			121	ru	Accept	
806226	128	2020-06-15	12:32:01	LeadPaint	128	No	mg/cm2			121	ru	Accept	
806226	129	2020-06-15	12:35:37	LeadPaint	129	No	mg/cm2			121	ru	Accept	
806226	130	2020-06-15	12:38:59	LeadPaint	130	No	mg/cm2			121	ru	Accept	
806226	131	2020-06-15	12:39:49	Cal Check	131C	No	mg/cm2						
806226	132	2020-06-15	12:47:45	Cal Check	132C	No	mg/cm2						

Date	Time	Reading	Mode	Elapsed Tir	Elapsed Tir	Pass/Fail	Instrument Model	Tube Anod Unit	LBP Result
6/16/2020	8:54:03	#3	Cal Check	14.89	14.89		543396 Delta Profe Rh	%	
6/16/2020	8:55:10	#4	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	8:55:56	#5	Lead Paint	3.04	3.04	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	9:59:40	#6	Lead Paint	11.11	11.11	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	9:59:51	#7	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:00:04	#8	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:00:24	#9	Lead Paint	11.16	11.16	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:00:45	#10	Lead Paint	11.13	11.13	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:01:07	#11	Lead Paint	11.07	11.07	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:01:18	#12	Lead Paint	3.04	3.04	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:01:29	#13	Lead Paint	3.02	3.02	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:01:52	#14	Lead Paint	11.15	11.15	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:02:00	#15	Lead Paint	3.04	3.04	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:02:20	#16	Lead Paint	10.66	10.66	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:02:50	#17	Lead Paint	11.16	11.16	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:03:09	#18	Lead Paint	10.65	10.65	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:03:27	#19	Lead Paint	11.22	11.22	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:03:48	#20	Lead Paint	11.16	11.16	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:03:55	#21	Lead Paint	3.04	3.04	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:04:14	#22	Lead Paint	11.16	11.16	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:04:33	#23	Lead Paint	10.62	10.62	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:04:50	#24	Lead Paint	10.68	10.68	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:05:11	#25	Lead Paint	11.14	11.14	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:05:25	#26	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:05:42	#27	Lead Paint	11.16	11.16	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:05:54	#28	Lead Paint	3.04	3.04	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:06:12	#29	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:06:30	#30	Lead Paint	11.18	11.18	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:06:37	#31	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:06:50	#32	Lead Paint	3.02	3.02	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:08:05	#33	Lead Paint	10.09	10.09	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:08:12	#34	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:08:19	#35	Analysis Results			PASS	543396 Delta Profe Rh	%	
6/16/2020	10:08:33	#36	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:08:43	#37	Lead Paint	3.04	3.04	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:08:53	#38	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:09:09	#39	Lead Paint	11.16	11.16	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:09:17	#40	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:09:34	#41	Lead Paint	11.13	11.13	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:09:41	#42	Lead Paint	3.02	3.02	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:10:05	#43	Lead Paint	3.01	3.01	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:10:22	#44	Lead Paint	11.21	11.21	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:10:29	#45	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:10:38	#46	Lead Paint	3.04	3.04	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:10:47	#47	Lead Paint	3.04	3.04	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:11:03	#48	Lead Paint	11.17	11.17	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:11:11	#49	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:11:22	#50	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:11:32	#51	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:11:52	#52	Lead Paint	11.2	11.2	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:12:02	#53	Lead Paint	3.04	3.04	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:12:09	#54	Lead Paint	3.13	3.13	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:12:17	#55	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:12:26	#56	Lead Paint	3.03	3.03	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:14:39	#57	Lead Paint	11.13	11.13	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:14:56	#58	Lead Paint	11.13	11.13	PASS	543396 Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:15:04	#59	Lead Paint	3.04	3.04	PASS	543396 Delta Profe Rh	mg/cm2	Negative

6/16/2020	10:15:22	#60	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:15:41	#61	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:15:50	#62	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:16:12	#63	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:16:20	#64	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:16:39	#65	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:16:48	#66	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:16:58	#67	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:17:14	#68	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:17:25	#69	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:17:54	#70	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:18:04	#71	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:18:22	#72	Lead Paint	10.68	10.68	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:18:40	#73	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:18:48	#74	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:19:05	#75	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:19:14	#76	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:19:33	#77	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:19:49	#78	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:20:09	#79	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:20:26	#80	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:20:35	#81	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:20:47	#82	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:20:57	#83	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:21:06	#84	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:21:25	#85	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:21:40	#86	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:21:50	#87	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:22:08	#88	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:22:22	#89	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:22:39	#90	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:22:46	#91	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:23:01	#92	Lead Paint	10.83	10.83	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:23:23	#93	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:23:39	#94	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:23:55	#95	Lead Paint	11.23	11.23	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:24:04	#96	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:24:18	#97	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:24:43	#98	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:25:04	#99	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:25:25	#100	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:27:06	#101	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:27:15	#102	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:27:24	#103	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:27:50	#104	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:27:58	#105	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:28:13	#106	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:28:23	#107	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:28:32	#108	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:28:49	#109	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:28:58	#110	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:29:20	#111	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:29:27	#112	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:30:02	#113	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:30:19	#114	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:30:34	#115	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:30:42	#116	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:30:59	#117	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/16/2020	10:31:09	#118	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:31:22	#119	Lead Paint			PASS	543396	Delta Profe Rh	mg/cm2	Insufficient
6/16/2020	10:31:38	#120	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:32:01	#121	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:32:18	#122	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:32:24	#123	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:32:32	#124	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:32:39	#125	Lead Paint	3.54	3.54	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:32:57	#126	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:33:10	#127	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:33:40	#128	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:33:51	#129	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:34:08	#130	Lead Paint	11.26	11.26	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:34:17	#131	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:34:33	#132	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:34:54	#134	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:35:10	#135	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:35:35	#136	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:35:52	#137	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:36:09	#138	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:36:28	#139	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:36:39	#140	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:36:54	#141	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:37:12	#142	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:37:29	#143	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:46:40	#144	Lead Paint	11.08	11.08	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:46:58	#145	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:47:08	#146	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:47:17	#147	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:47:33	#148	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:47:44	#149	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:47:56	#150	Lead Paint	3.06	3.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:48:14	#151	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:48:33	#152	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:48:43	#153	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:48:53	#154	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:49:10	#155	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:49:25	#156	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:49:44	#157	Lead Paint	10.68	10.68	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:50:03	#158	Lead Paint	3.13	3.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:50:33	#159	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:50:50	#160	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:51:07	#161	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:51:18	#162	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:51:28	#163	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:51:44	#164	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:52:06	#165	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:52:15	#166	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:52:32	#167	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:52:43	#168	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:52:52	#169	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:53:09	#170	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:53:25	#171	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:53:33	#172	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:53:50	#173	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:54:00	#174	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:54:17	#175	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:54:25	#176	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/16/2020	10:54:43	#177	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:55:01	#178	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:55:17	#179	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:55:33	#180	Lead Paint	10.68	10.68	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:55:41	#181	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:55:58	#182	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:56:14	#183	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:58:01	#184	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:58:18	#185	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:58:29	#186	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:58:40	#187	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:59:06	#188	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:59:27	#189	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	10:59:44	#190	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:00:04	#191	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:00:12	#192	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:00:21	#193	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:00:35	#194	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:00:53	#195	Lead Paint	11.24	11.24	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:01:09	#196	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:01:16	#197	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:01:31	#198	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:01:56	#199	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:02:12	#200	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:02:19	#201	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:02:29	#202	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:02:47	#203	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:03:05	#204	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:03:26	#205	Lead Paint	11.23	11.23	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:03:34	#206	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:03:42	#207	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:03:51	#208	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:04:09	#209	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:04:31	#210	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:04:54	#211	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:05:01	#212	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:05:18	#213	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:05:27	#214	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:05:56	#215	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:10:18	#216	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:10:42	#217	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:10:58	#218	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:11:25	#219	Lead Paint	11.12	11.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:11:45	#220	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:12:03	#221	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:12:10	#222	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:12:18	#223	Lead Paint	3.2	3.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:12:37	#224	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:12:47	#225	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:13:02	#226	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:13:18	#227	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:13:45	#228	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:14:01	#229	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:14:10	#230	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:14:26	#231	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:14:42	#232	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:14:49	#233	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:15:06	#234	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/16/2020	11:15:27	#235	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:15:43	#236	Lead Paint	11.23	11.23	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:15:55	#237	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:16:06	#238	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:16:22	#239	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:16:30	#240	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:16:48	#241	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:17:03	#242	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:17:10	#243	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:17:28	#244	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:17:44	#245	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:17:52	#246	Lead Paint	3.06	3.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:18:10	#247	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:18:18	#248	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:18:45	#249	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:20:09	#250	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:20:26	#251	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:20:38	#252	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:20:46	#253	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:20:56	#254	Lead Paint	3.57	3.57	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:21:06	#255	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:21:23	#256	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:21:34	#257	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:21:50	#258	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:22:01	#259	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:22:23	#260	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:22:41	#261	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:22:53	#262	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:23:12	#263	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:23:31	#264	Lead Paint	10.68	10.68	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:23:42	#265	Lead Paint	4.12	4.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:24:00	#266	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:24:10	#267	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:24:36	#268	Lead Paint	11.31	11.31	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:24:54	#269	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:25:03	#270	Lead Paint	3.06	3.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:25:21	#271	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:25:29	#272	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:25:46	#273	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:26:02	#274	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:26:20	#275	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:26:29	#276	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:26:46	#277	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:26:55	#278	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:27:06	#279	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:27:20	#280	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:27:33	#281	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:27:51	#282	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:28:10	#283	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/16/2020	11:28:19	#284	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:08:53	#2	Cal Check	14.86	14.86		543396	Delta Profe Rh	%	
6/17/2020	7:09:45	#3	Lead Paint	11.47	11.47	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:10:02	#4	Lead Paint	5.18	5.18	PASS	543396	Delta Profe Rh	mg/cm2	Positive
6/17/2020	7:11:27	#5	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:11:35	#6	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:11:50	#7	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:11:59	#8	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:12:08	#9	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/17/2020	7:12:18 #10	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:12:28 #11	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:12:38 #12	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:12:47 #13	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:12:58 #14	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:13:10 #15	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:13:21 #16	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:13:29 #17	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:13:39 #18	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:14:21 #19	Lead Paint	3.54	3.54	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:14:35 #20	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:14:59 #21	Lead Paint	10.68	10.68	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:15:39 #22	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:15:52 #23	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:16:00 #24	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:16:18 #25	Lead Paint	10.71	10.71	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:16:28 #26	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:16:39 #27	Lead Paint	5.2	5.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:16:51 #28	Lead Paint	3.14	3.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:17:03 #29	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:17:14 #30	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:17:25 #31	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:17:35 #32	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:17:44 #33	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:17:56 #34	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:18:12 #35	Lead Paint	9.06	9.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:18:20 #36	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:18:31 #37	Lead Paint	3.53	3.53	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:18:38 #38	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:18:48 #39	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:19:07 #40	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:19:23 #41	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:19:33 #42	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:19:48 #43	Lead Paint	10.68	10.68	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:19:58 #44	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:20:06 #45	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:20:21 #46	Lead Paint			PASS	543396	Delta Profe Rh	mg/cm2	Insufficient
6/17/2020	7:20:38 #47	Lead Paint	10.71	10.71	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:20:55 #48	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:22:04 #49	Lead Paint	3.52	3.52	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:24:36 #50	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:25:38 #51	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:25:47 #52	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:26:00 #53	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Positive - P
6/17/2020	7:26:10 #54	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:26:22 #55	Lead Paint	4.15	4.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:26:38 #56	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:26:50 #57	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:26:57 #58	Lead Paint	3.53	3.53	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:27:46 #59	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:27:59 #60	Lead Paint	5.2	5.2	PASS	543396	Delta Profe Rh	mg/cm2	Positive
6/17/2020	7:28:48 #61	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:28:57 #62	Lead Paint	3.06	3.06	PASS	543396	Delta Profe Rh	mg/cm2	Positive - P
6/17/2020	7:29:12 #63	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:29:21 #64	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:29:40 #65	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:29:50 #66	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:29:57 #67	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/17/2020	7:30:13 #68	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:30:24 #69	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:30:33 #70	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:30:43 #71	Lead Paint	3.57	3.57	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:30:53 #72	Lead Paint	3.56	3.56	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:31:26 #73	Lead Paint	10.64	10.64	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:31:40 #74	Lead Paint	8.5	8.5	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:32:12 #75	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:32:32 #76	Lead Paint	10.72	10.72	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:32:45 #77	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:32:56 #78	Lead Paint	3.08	3.08	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:33:05 #79	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:33:12 #80	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:33:22 #81	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:33:29 #82	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:33:36 #83	Lead Paint	3.56	3.56	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:33:50 #84	Lead Paint	8.43	8.43	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:34:07 #85	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:34:25 #86	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:34:40 #87	Lead Paint	5.2	5.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:34:57 #88	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:35:07 #89	Lead Paint	3.53	3.53	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:35:17 #90	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:35:37 #91	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:35:45 #92	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:35:58 #93	Lead Paint	5.77	5.77	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:36:17 #94	Lead Paint	10.68	10.68	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:36:26 #95	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:36:40 #96	Lead Paint	5.76	5.76	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:36:58 #97	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:38:11 #98	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:38:44 #99	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Positive - P
6/17/2020	7:39:27 #100	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:39:38 #101	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:39:54 #102	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:40:15 #103	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:40:24 #104	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Positive - P
6/17/2020	7:40:38 #105	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Positive - P
6/17/2020	7:41:19 #106	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:41:28 #107	Lead Paint	3.51	3.51	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:41:51 #108	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:42:27 #109	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:42:45 #110	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:43:09 #111	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:43:54 #112	Lead Paint	10.64	10.64	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:44:03 #113	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:44:22 #114	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:44:33 #115	Lead Paint	5.19	5.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:44:46 #116	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:44:56 #117	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:45:05 #118	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:45:18 #119	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:45:26 #120	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:45:33 #121	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:45:45 #122	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:45:54 #123	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:46:03 #124	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:46:16 #125	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/17/2020	7:46:24 #126	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:46:36 #127	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:46:51 #128	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:47:08 #129	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:47:29 #130	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:47:46 #131	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:48:07 #132	Lead Paint	10.64	10.64	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:48:16 #133	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:48:28 #134	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:48:45 #135	Lead Paint	10.68	10.68	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:50:44 #136	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	7:50:55 #137	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Positive - P
6/17/2020	7:51:06 #138	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:03:14 #139	Lead Paint	11.06	11.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:03:32 #140	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:03:41 #141	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:03:52 #142	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:04:06 #143	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:04:17 #144	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:04:37 #145	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:04:52 #146	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:05:09 #147	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:05:27 #148	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:05:43 #149	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:06:09 #150	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:06:23 #151	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:06:40 #152	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:06:59 #153	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:07:44 #154	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:08:02 #155	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:08:12 #156	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:08:34 #157	Lead Paint	11.12	11.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:08:54 #158	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:09:12 #159	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:09:32 #160	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:09:48 #161	Lead Paint	11.23	11.23	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:10:03 #162	Lead Paint	3.06	3.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:10:25 #163	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:10:33 #164	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:10:45 #165	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:10:56 #166	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:13:03 #167	Lead Paint	11.12	11.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:13:31 #168	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:13:42 #169	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:14:00 #170	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:14:20 #171	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:14:42 #172	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:14:53 #173	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:15:14 #174	Lead Paint	10.63	10.63	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:15:24 #175	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:15:49 #176	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:16:19 #177	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:16:28 #178	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:16:49 #179	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:17:15 #180	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:17:32 #181	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:17:59 #182	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:18:09 #183	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/17/2020	8:18:19 #184	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:18:31 #185	Lead Paint	5.77	5.77	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:18:50 #186	Lead Paint	11.11	11.11	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:19:07 #187	Lead Paint	3.07	3.07	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:19:22 #188	Lead Paint	11.12	11.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:19:31 #189	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:19:50 #190	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:20:14 #191	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:20:25 #192	Lead Paint	4.12	4.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:20:38 #193	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:20:58 #194	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:22:13 #195	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:22:36 #196	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:23:05 #197	Lead Paint	10.64	10.64	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:31:19 #198	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:32:09 #199	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:32:31 #200	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:32:39 #201	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:32:51 #202	Lead Paint	3	3	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:33:06 #203	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:33:25 #204	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:33:45 #205	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:34:06 #206	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:34:22 #207	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:34:32 #208	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:34:55 #209	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:35:17 #210	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:35:33 #211	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:35:49 #212	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:36:10 #213	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:36:33 #214	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:36:48 #215	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:37:05 #216	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:37:15 #217	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:37:26 #218	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:37:33 #219	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:37:52 #220	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:38:35 #221	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	8:39:56 #222	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:35:23 #223	Lead Paint	11.08	11.08	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:35:33 #224	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:35:43 #225	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:36:09 #226	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:36:24 #227	Lead Paint	11.08	11.08	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:36:36 #228	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:36:55 #229	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:37:14 #230	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:37:32 #231	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:37:45 #232	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:37:57 #233	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:38:13 #234	Lead Paint	11.1	11.1	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:38:22 #235	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:38:42 #236	Lead Paint	11.11	11.11	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:39:08 #237	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:39:23 #238	Lead Paint	3.14	3.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:39:44 #239	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:39:59 #240	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:40:06 #241	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/17/2020	9:40:22 #242	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:40:28 #243	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:40:45 #244	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:41:03 #245	Lead Paint	11.1	11.1	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:41:22 #246	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:41:29 #247	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:41:38 #248	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:41:54 #249	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:42:01 #250	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:42:20 #251	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:42:31 #252	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:42:52 #253	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:43:12 #254	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:43:22 #255	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:43:38 #256	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:43:55 #257	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:44:06 #258	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:44:19 #259	Analysis Results			PASS	543396	Delta Profe Rh	%	
6/17/2020	9:44:37 #260	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:44:46 #261	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:44:55 #262	Lead Paint	3.51	3.51	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:45:11 #263	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:45:25 #264	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:45:34 #265	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:46:02 #266	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:46:18 #267	Lead Paint	11.12	11.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:46:42 #268	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:52:31 #269	Lead Paint	11.46	11.46	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:52:40 #270	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:53:13 #271	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:53:22 #272	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:53:34 #273	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:54:02 #274	Lead Paint	10.69	10.69	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:54:17 #275	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:54:25 #276	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:54:51 #277	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:54:59 #278	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:55:28 #279	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:55:38 #280	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:55:59 #281	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:56:08 #282	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:56:28 #283	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:56:43 #284	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:56:58 #285	Lead Paint	10.69	10.69	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:57:14 #286	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:57:30 #287	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:57:38 #288	Lead Paint	3.59	3.59	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:57:48 #289	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:57:59 #290	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:58:16 #291	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:58:33 #292	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:58:43 #293	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:59:01 #294	Lead Paint	11.12	11.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	9:59:16 #295	Lead Paint	11.24	11.24	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:13:20 #296	Lead Paint	10.96	10.96	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:13:33 #297	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:13:41 #298	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:13:49 #299	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/17/2020	10:14:05	#300	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:14:16	#301	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:14:28	#302	Analysis Results			PASS	543396	Delta Profe Rh	%	
6/17/2020	10:14:48	#303	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:15:04	#304	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:15:21	#305	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:15:28	#306	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:15:40	#307	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:16:09	#308	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:16:25	#309	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:16:42	#310	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:17:05	#311	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:17:20	#312	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:17:35	#313	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:17:50	#314	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:18:09	#315	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:18:27	#316	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:18:41	#317	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:18:59	#318	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:19:16	#319	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:19:30	#320	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:19:49	#321	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:20:06	#322	Lead Paint	11.27	11.27	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:20:12	#323	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:20:19	#324	Lead Paint	3.54	3.54	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:20:28	#325	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:28:14	#326	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:28:25	#327	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:28:36	#328	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:28:56	#329	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:29:12	#330	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:29:23	#331	Lead Paint	4.11	4.11	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:29:32	#332	Lead Paint	4.12	4.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:29:53	#333	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:30:07	#334	Lead Paint	10.7	10.7	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:30:23	#335	Lead Paint	10.7	10.7	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:30:45	#336	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:30:56	#337	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:31:10	#338	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:31:28	#339	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:31:34	#340	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:31:53	#341	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:32:08	#342	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:32:16	#343	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:32:32	#344	Lead Paint	10.69	10.69	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:32:50	#345	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:33:05	#346	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:33:33	#347	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:33:41	#348	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:33:57	#349	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:34:04	#350	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:34:14	#351	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:34:30	#352	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:34:42	#353	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:34:52	#354	Lead Paint	3.54	3.54	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/17/2020	10:35:00	#355	Lead Paint	3.07	3.07	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:16:01	#2	Cal Check	14.86	14.86		543396	Delta Profe Rh	%	
6/18/2020	7:18:44	#3	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/18/2020	7:18:53 #4	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:19:09 #5	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:19:26 #6	Lead Paint	10.18	10.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:19:57 #7	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:20:12 #8	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:20:23 #9	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:20:40 #10	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:20:49 #11	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:21:00 #12	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:21:14 #13	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:21:31 #14	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:21:51 #15	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:22:07 #16	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:22:25 #17	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:22:42 #18	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:22:57 #19	Lead Paint	9.6	9.6	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:23:14 #20	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:23:23 #21	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:23:42 #22	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:23:58 #23	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:24:08 #24	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:24:27 #25	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:24:46 #26	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:24:58 #27	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:25:18 #28	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:25:32 #29	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:25:46 #30	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:26:07 #31	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:26:16 #32	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:39:18 #33	Lead Paint	11.46	11.46	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:39:47 #34	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:40:49 #35	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:41:06 #36	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:41:23 #37	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:41:53 #38	Lead Paint	11.28	11.28	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:42:10 #39	Lead Paint	10.61	10.61	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:42:19 #40	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:42:35 #41	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:42:44 #42	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:43:07 #43	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:43:30 #44	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:43:44 #45	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:43:59 #46	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:44:24 #47	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:44:51 #48	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:45:11 #49	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:45:30 #50	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:45:56 #51	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:46:20 #52	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:46:37 #53	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:46:55 #54	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:47:08 #55	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:47:24 #56	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:47:46 #57	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:48:11 #58	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:48:32 #59	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:48:49 #60	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:49:04 #61	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/18/2020	7:49:23 #62	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:49:45 #63	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:49:59 #64	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:50:23 #65	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:50:48 #66	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:51:01 #67	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:51:11 #68	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:51:29 #69	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:51:52 #70	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:52:13 #71	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:52:26 #72	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:52:48 #73	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:53:03 #74	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:53:11 #75	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	7:53:28 #76	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:08:41 #77	Lead Paint	11.69	11.69	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:09:11 #78	Lead Paint	11.7	11.7	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:12:36 #79	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:12:46 #80	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:13:04 #81	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:13:26 #82	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:13:36 #83	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:13:46 #84	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:14:08 #85	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:14:23 #86	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:14:32 #87	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:15:05 #88	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:15:24 #89	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:15:43 #90	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:16:00 #91	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:16:19 #92	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:16:42 #93	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:16:51 #94	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:17:11 #95	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:17:37 #96	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:18:06 #97	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:18:29 #98	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:18:46 #99	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:18:59 #100	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:19:20 #101	Lead Paint	11.11	11.11	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:19:30 #102	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:19:42 #103	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:19:53 #104	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	8:20:07 #105	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:04:55 #106	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:06:19 #107	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:06:28 #108	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:06:44 #109	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:06:56 #110	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:07:34 #111	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:07:54 #112	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:08:11 #113	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:08:37 #114	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:08:50 #115	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:09:16 #116	Lead Paint			PASS	543396	Delta Profe Rh	mg/cm2	Insufficient
6/18/2020	9:09:24 #117	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:09:38 #118	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:09:59 #119	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/18/2020	9:10:16 #120	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:10:30 #121	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:10:48 #122	Lead Paint	11.1	11.1	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:10:58 #123	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:11:18 #124	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:11:30 #125	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:11:56 #126	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:12:08 #127	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:12:21 #128	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:12:37 #129	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:12:48 #130	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:13:24 #131	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:13:40 #132	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:18:29 #133	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:18:38 #134	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:18:55 #135	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:19:16 #136	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:19:34 #137	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:19:59 #138	Lead Paint	10.71	10.71	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:20:16 #139	Lead Paint	10.69	10.69	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:20:40 #140	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:21:12 #141	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:21:24 #142	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:21:33 #143	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:21:54 #144	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:22:25 #145	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:22:46 #146	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:22:54 #147	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:23:01 #148	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:23:18 #149	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:23:34 #150	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:23:41 #151	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:23:50 #152	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:24:02 #153	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:24:12 #154	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:24:28 #155	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:24:43 #156	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:41:42 #157	Analysis Results			PASS	543396	Delta Profe Rh	%	
6/18/2020	9:42:50 #158	Lead Paint	10.6	10.6	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:43:09 #159	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:43:26 #160	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:43:37 #161	Lead Paint	4.14	4.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:43:48 #162	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:44:20 #163	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:44:38 #164	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:44:46 #165	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:45:05 #166	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:45:24 #167	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:45:32 #168	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:45:51 #169	Lead Paint	10.68	10.68	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:46:08 #170	Lead Paint			PASS	543396	Delta Profe Rh	mg/cm2	Insufficient
6/18/2020	9:46:33 #171	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:46:50 #172	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:47:06 #173	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:47:23 #174	Lead Paint	6.31	6.31	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:47:41 #175	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:47:59 #176	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:48:17 #177	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/18/2020	9:48:25 #178	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:48:44 #179	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:49:00 #180	Lead Paint	10.7	10.7	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:49:23 #181	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:49:37 #182	Lead Paint	7.4	7.4	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:49:53 #183	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:50:10 #184	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:50:28 #185	Lead Paint	10.64	10.64	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:50:47 #186	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:51:04 #187	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:51:21 #188	Lead Paint	10.69	10.69	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:51:40 #189	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:51:51 #190	Lead Paint	4.13	4.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:52:06 #191	Lead Paint	3.06	3.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:52:16 #192	Lead Paint	3.61	3.61	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:52:33 #193	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:52:50 #194	Lead Paint	10.68	10.68	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:53:07 #195	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:53:24 #196	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:53:44 #197	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:54:01 #198	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:54:21 #199	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:54:42 #200	Lead Paint	10.64	10.64	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:55:00 #201	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:55:18 #202	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:55:25 #203	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:57:30 #204	Lead Paint	3.53	3.53	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:57:50 #205	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:57:59 #206	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:58:20 #207	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:58:39 #208	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:59:02 #209	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:59:11 #210	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:59:34 #211	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	9:59:57 #212	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:00:20 #213	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:00:28 #214	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:00:49 #215	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:01:00 #216	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:01:13 #217	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:01:33 #218	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:01:49 #219	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:01:57 #220	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:02:16 #221	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:02:39 #222	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:02:48 #223	Lead Paint	3	3	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:03:00 #224	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:03:09 #225	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:03:24 #226	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:03:37 #227	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:04:02 #228	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:04:19 #229	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:04:36 #230	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:04:54 #231	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:05:17 #232	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:05:32 #233	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:05:49 #234	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/18/2020	10:06:06 #235	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/19/2020	7:13:01 #2	Cal Check	14.87	14.87	543396	Delta Profe Rh	%	
6/19/2020	7:21:44 #3	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:22:00 #4	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:22:23 #5	Lead Paint	11.2	11.2 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:22:45 #6	Lead Paint	11.18	11.18 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:22:56 #7	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:23:15 #8	Lead Paint	9.58	9.58 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:23:28 #9	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:23:49 #10	Lead Paint	4.03	4.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:24:00 #11	Lead Paint	3.01	3.01 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:24:29 #12	Lead Paint	11.17	11.17 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:24:39 #13	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:24:50 #14	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:25:10 #15	Lead Paint	11.18	11.18 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:25:32 #16	Lead Paint	3.02	3.02 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:25:46 #17	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:26:06 #18	Lead Paint	11.15	11.15 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:26:24 #19	Lead Paint	11.17	11.17 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:26:39 #20	Lead Paint	3.05	3.05 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:26:55 #21	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:27:14 #22	Lead Paint	11.15	11.15 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:27:29 #23	Lead Paint	11.19	11.19 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:27:56 #24	Lead Paint	11.13	11.13 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:28:18 #25	Lead Paint	11.23	11.23 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:28:42 #26	Lead Paint	11.15	11.15 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:28:59 #27	Lead Paint	11.17	11.17 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:29:22 #28	Lead Paint	11.16	11.16 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:29:36 #29	Lead Paint	3.05	3.05 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:29:59 #30	Lead Paint	11.23	11.23 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:40:55 #31	Analysis Results		PASS	543396	Delta Profe Rh	%	
6/19/2020	7:41:13 #32	Lead Paint	3.08	3.08 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:41:36 #33	Lead Paint	11.23	11.23 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:42:01 #34	Lead Paint	10.67	10.67 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:42:18 #35	Lead Paint	10.67	10.67 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:42:40 #36	Lead Paint	11.22	11.22 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:43:04 #37	Lead Paint	3.05	3.05 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:43:25 #38	Lead Paint	11.19	11.19 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:43:49 #39	Lead Paint	11.19	11.19 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:44:08 #40	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:44:18 #41	Lead Paint	3.05	3.05 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:44:27 #42	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:44:47 #43	Lead Paint	11.11	11.11 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:45:04 #44	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:45:32 #45	Lead Paint	11.17	11.17 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:45:51 #46	Lead Paint	11.2	11.2 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:46:26 #47	Lead Paint	10.68	10.68 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:46:34 #48	Lead Paint	3.02	3.02 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:46:46 #49	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:47:13 #50	Lead Paint	11.17	11.17 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:47:37 #51	Lead Paint	10.65	10.65 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:47:59 #52	Lead Paint	11.16	11.16 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:48:09 #53	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:48:30 #54	Lead Paint	11.19	11.19 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:48:39 #55	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:48:53 #56	Lead Paint	3.05	3.05 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:49:06 #57	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:49:16 #58	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:58:57 #59	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/19/2020	7:59:21 #60	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	7:59:40 #61	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:00:01 #62	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:00:22 #63	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:00:32 #64	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:00:47 #65	Lead Paint	11.1	11.1	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:00:56 #66	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:01:07 #67	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:02:05 #68	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:03:07 #69	Lead Paint	6.3	6.3	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:03:23 #70	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:03:33 #71	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:03:40 #72	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:03:47 #73	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:04:04 #74	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:04:20 #75	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:04:29 #76	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:04:55 #77	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:05:04 #78	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:05:51 #79	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:06:20 #80	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:06:31 #81	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:06:44 #82	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:06:56 #83	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:07:04 #84	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:07:19 #85	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:07:27 #86	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:07:33 #87	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:07:40 #88	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:07:47 #89	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:08:04 #90	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:08:11 #91	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:08:17 #92	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:09:40 #93	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:09:59 #94	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:10:08 #95	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:10:22 #96	Lead Paint			PASS	543396	Delta Profe Rh	mg/cm2	Insufficient
6/19/2020	8:10:41 #97	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:10:50 #98	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:11:08 #99	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:11:27 #100	Lead Paint	11.12	11.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:11:42 #101	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:11:55 #102	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:12:19 #103	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:12:36 #104	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:12:47 #105	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:13:08 #106	Lead Paint	3.53	3.53	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:13:30 #107	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:13:49 #108	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:14:02 #109	Lead Paint	3.06	3.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:14:20 #110	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:14:28 #111	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:14:38 #112	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:14:46 #113	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:14:54 #114	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:15:09 #115	Lead Paint	11.27	11.27	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:15:25 #116	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:15:34 #117	Lead Paint	3.06	3.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/19/2020	8:16:11 #118	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:16:17 #119	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:16:26 #120	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:16:33 #121	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:16:41 #122	Lead Paint	3.16	3.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:16:51 #123	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:17:02 #124	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:17:19 #125	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:20:17 #126	Lead Paint	11.09	11.09	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:20:53 #127	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:21:14 #128	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:21:34 #129	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:21:49 #130	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:22:11 #131	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:22:19 #132	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:22:28 #133	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:22:37 #134	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:22:48 #135	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:23:22 #136	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:23:41 #137	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:23:55 #138	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:24:16 #139	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:24:32 #140	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:24:43 #141	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:24:50 #142	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:24:58 #143	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:25:13 #144	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:25:20 #145	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:25:28 #146	Lead Paint	4.12	4.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:27:00 #147	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:27:23 #148	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:27:45 #149	Lead Paint	10.69	10.69	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:28:03 #150	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:28:19 #151	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:28:41 #152	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:29:32 #153	Lead Paint	10.64	10.64	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:29:58 #154	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:30:18 #155	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:30:33 #156	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:30:48 #157	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:31:03 #158	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:31:18 #159	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:31:36 #160	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:31:51 #161	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:32:07 #162	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:32:26 #163	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:32:49 #164	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:33:15 #165	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:33:37 #166	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:33:57 #167	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:34:12 #168	Lead Paint	10.69	10.69	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:52:38 #169	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:52:53 #170	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:53:11 #171	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:53:17 #172	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:53:25 #173	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:53:41 #174	Lead Paint	11.12	11.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:53:57 #175	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/19/2020	8:54:14	#176	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:54:30	#177	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:54:37	#178	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:54:54	#179	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:55:03	#180	Lead Paint	3.1	3.1	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:55:13	#181	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:55:28	#182	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:55:52	#183	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:56:02	#184	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:56:22	#185	Lead Paint	3.06	3.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:56:32	#186	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:56:45	#187	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:56:51	#188	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:57:07	#189	Lead Paint	10.74	10.74	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:57:22	#190	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:57:44	#191	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:57:58	#192	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:58:17	#193	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:58:25	#194	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:58:50	#195	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:58:57	#196	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:59:13	#197	Lead Paint	11.3	11.3	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:59:20	#198	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	8:59:42	#199	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:00:00	#200	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:00:17	#201	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:00:26	#202	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:00:42	#203	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:01:00	#204	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:01:14	#205	Lead Paint	3.13	3.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:01:23	#206	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:01:41	#207	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:01:48	#208	Lead Paint	3.57	3.57	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:01:54	#209	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:02:10	#210	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:02:27	#211	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:02:50	#212	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:03:09	#213	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:03:26	#214	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:03:45	#215	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:04:03	#216	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:04:14	#217	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:04:24	#218	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:04:41	#219	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:05:06	#220	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:05:23	#221	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:05:38	#222	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:05:56	#223	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:06:13	#224	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:06:22	#225	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:06:33	#226	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:06:48	#227	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:06:57	#228	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:07:12	#229	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/19/2020	9:07:21	#230	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:10:57	#1	Cal Check	15.14	15.14		543396	Delta Profe Rh	%	
6/22/2020	7:13:50	#2	Lead Paint	11.1	11.1	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:14:16	#3	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/22/2020	7:14:34 #4	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:14:49 #5	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:15:07 #6	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:15:26 #7	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:15:50 #8	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:16:07 #9	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:16:14 #10	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:16:20 #11	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:16:28 #12	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:16:37 #13	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:16:46 #14	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:17:12 #15	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:17:32 #16	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:17:47 #17	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:18:04 #18	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:18:19 #19	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:18:27 #20	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:18:46 #21	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:18:58 #22	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:19:07 #23	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:19:38 #24	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:19:46 #25	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:20:08 #26	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:26:19 #27	Lead Paint	11.27	11.27	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:26:30 #28	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:26:45 #29	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:27:03 #30	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:27:18 #31	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:27:26 #32	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:27:43 #33	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:28:01 #34	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:28:16 #35	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:28:31 #36	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:28:47 #37	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:28:57 #38	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:29:14 #39	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:29:22 #40	Lead Paint	3.51	3.51	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:29:32 #41	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:29:40 #42	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:29:48 #43	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:30:31 #44	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:30:39 #45	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:30:55 #46	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:31:03 #47	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:31:20 #48	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:31:39 #49	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:31:54 #50	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:32:09 #51	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:32:24 #52	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:32:39 #53	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:32:49 #54	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:33:41 #55	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:34:46 #56	Lead Paint	10.64	10.64	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:35:03 #57	Lead Paint	10.75	10.75	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:35:16 #58	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:35:33 #59	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:35:50 #60	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:36:07 #61	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/22/2020	7:36:34 #62	Analysis Results		PASS	543396	Delta Profe Rh	%	
6/22/2020	7:36:58 #63	Lead Paint	11.12	11.12 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:37:06 #64	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:37:16 #65	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:37:27 #66	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:37:42 #67	Lead Paint	11.16	11.16 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:38:00 #68	Lead Paint	11.19	11.19 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:38:14 #69	Lead Paint	10.64	10.64 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:38:34 #70	Lead Paint	11.21	11.21 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:38:51 #71	Lead Paint	11.16	11.16 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:39:06 #72	Lead Paint	11.13	11.13 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:39:21 #73	Lead Paint	11.18	11.18 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:39:37 #74	Lead Paint	11.16	11.16 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:39:54 #75	Lead Paint	11.12	11.12 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:40:02 #76	Lead Paint	3.06	3.06 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:40:08 #77	Lead Paint	3.05	3.05 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:40:19 #78	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:40:28 #79	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:40:44 #80	Lead Paint	11.19	11.19 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:41:03 #81	Lead Paint	11.23	11.23 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:41:14 #82	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:41:22 #83	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:41:31 #84	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:42:10 #85	Lead Paint		PASS	543396	Delta Profe Rh	mg/cm2	Insufficient
6/22/2020	7:42:28 #86	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:42:51 #87	Lead Paint	11.2	11.2 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:42:59 #88	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:43:18 #89	Lead Paint	11.15	11.15 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:43:46 #90	Lead Paint	3.02	3.02 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:44:03 #91	Lead Paint	11.15	11.15 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:44:18 #92	Lead Paint		PASS	543396	Delta Profe Rh	mg/cm2	Insufficient
6/22/2020	7:44:35 #93	Lead Paint	11.12	11.12 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:44:51 #94	Lead Paint	11.2	11.2 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:44:57 #95	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:45:04 #96	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:45:14 #97	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:45:24 #98	Lead Paint	3.01	3.01 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:45:41 #99	Lead Paint	11.18	11.18 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:45:49 #100	Lead Paint	3.05	3.05 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:46:04 #101	Lead Paint	11.21	11.21 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:46:18 #102	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:46:26 #103	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:46:41 #104	Lead Paint	11.13	11.13 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:46:58 #105	Lead Paint	11.09	11.09 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:47:10 #106	Lead Paint	3.05	3.05 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:47:23 #107	Lead Paint	3.02	3.02 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:47:45 #108	Lead Paint	11.2	11.2 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:48:02 #109	Lead Paint	11.24	11.24 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:48:17 #110	Lead Paint	11.14	11.14 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:48:26 #111	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:48:33 #112	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:48:49 #113	Lead Paint	11.21	11.21 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:48:56 #114	Analysis Results		PASS	543396	Delta Profe Rh	%	
6/22/2020	7:49:14 #115	Lead Paint	11.14	11.14 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:49:20 #116	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:49:30 #117	Lead Paint	3.02	3.02 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:49:38 #118	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:49:53 #119	Lead Paint	11.18	11.18 PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/22/2020	7:50:00 #120	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:50:07 #121	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	7:50:14 #122	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:18:56 #123	Lead Paint	11.09	11.09	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:19:07 #124	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:19:20 #125	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:19:40 #126	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:19:49 #127	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:20:13 #128	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:20:39 #129	Lead Paint	10.63	10.63	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:20:56 #130	Lead Paint	11.11	11.11	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:21:05 #131	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:21:11 #132	Lead Paint	3.15	3.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:22:00 #133	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:22:08 #134	Analysis Results			PASS	543396	Delta Profe Rh	%	
6/22/2020	8:22:23 #135	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:22:37 #136	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:22:46 #137	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:22:54 #138	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:23:02 #139	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:23:10 #140	Lead Paint	3.57	3.57	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:23:17 #141	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:23:24 #142	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:23:32 #143	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:23:40 #144	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:23:47 #145	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:23:53 #146	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:24:03 #147	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:24:18 #148	Lead Paint	10.72	10.72	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:24:27 #149	Lead Paint	5.79	5.79	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:24:37 #150	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:24:54 #151	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:25:02 #152	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:25:24 #153	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:25:30 #154	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:34:10 #155	Lead Paint	11.05	11.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:35:11 #156	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:35:27 #157	Lead Paint	10.7	10.7	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:35:47 #158	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:36:02 #159	Lead Paint	10.69	10.69	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:36:41 #160	Lead Paint	10.64	10.64	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:36:52 #161	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:37:10 #162	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:37:49 #163	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:37:56 #164	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:38:10 #165	Lead Paint	5.74	5.74	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:38:33 #166	Lead Paint	10.64	10.64	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:38:51 #167	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:39:09 #168	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:39:23 #169	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:39:36 #170	Lead Paint	4.15	4.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:39:45 #171	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:39:58 #172	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:40:10 #173	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:40:27 #174	Lead Paint	10.68	10.68	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:40:42 #175	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:40:52 #176	Lead Paint	3.57	3.57	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:41:01 #177	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/22/2020	8:41:07 #178	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:41:17 #179	Lead Paint	3.57	3.57	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:41:32 #180	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:41:48 #181	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:42:03 #182	Lead Paint	10.62	10.62	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:42:10 #183	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:42:27 #184	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:42:42 #185	Lead Paint	5.77	5.77	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:42:54 #186	Lead Paint	4.65	4.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:43:04 #187	Lead Paint	5.22	5.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:43:27 #188	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:43:35 #189	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:43:49 #190	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:43:58 #191	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:44:13 #192	Lead Paint	10.72	10.72	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:44:30 #193	Lead Paint	7.98	7.98	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:44:46 #194	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:45:01 #195	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:45:09 #196	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:45:27 #197	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:45:42 #198	Lead Paint	10.63	10.63	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:45:57 #199	Lead Paint	10.7	10.7	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:46:12 #200	Lead Paint	10.71	10.71	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:46:29 #201	Lead Paint	10.63	10.63	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:46:45 #202	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:47:05 #203	Lead Paint	10.64	10.64	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:47:24 #204	Lead Paint	11.12	11.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:47:40 #205	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:47:59 #206	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:48:16 #207	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:48:32 #208	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:49:00 #209	Lead Paint	4.66	4.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	8:49:44 #210	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:00:59 #211	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:01:46 #212	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:02:05 #213	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:02:14 #214	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:02:29 #215	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:02:54 #216	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:03:03 #217	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:03:11 #218	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:03:20 #219	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:03:31 #220	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:03:48 #221	Lead Paint	11.29	11.29	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:03:56 #222	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:04:05 #223	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:04:13 #224	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:04:20 #225	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:04:28 #226	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:04:45 #227	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:04:52 #228	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:05:04 #229	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:05:13 #230	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:05:23 #231	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:05:31 #232	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:05:43 #233	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:05:54 #234	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:06:05 #235	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/22/2020	9:06:23	#236	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:06:34	#237	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:06:42	#238	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:06:51	#239	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:07:01	#240	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:07:10	#241	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:07:16	#242	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:41:40	#243	Lead Paint	11.03	11.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:41:56	#244	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:42:12	#245	Lead Paint	10.69	10.69	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:42:27	#246	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:42:49	#247	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:43:03	#248	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:43:11	#249	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:43:20	#250	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:43:29	#251	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:43:37	#252	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:44:01	#253	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:44:21	#254	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:44:31	#255	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:44:39	#256	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:44:49	#257	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:44:57	#258	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:45:05	#259	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:45:12	#260	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:45:20	#261	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:45:26	#262	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:45:32	#263	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:45:41	#264	Lead Paint	4.67	4.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:45:49	#265	Lead Paint	3.59	3.59	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:45:58	#266	Lead Paint	3.08	3.08	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:46:13	#267	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:46:27	#268	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:46:35	#269	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:46:42	#270	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:46:50	#271	Lead Paint	3.59	3.59	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:46:59	#272	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:47:06	#273	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:47:13	#274	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:47:22	#275	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:47:31	#276	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:47:38	#277	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:47:47	#278	Lead Paint	3.5	3.5	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:47:56	#279	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:49:26	#280	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:49:42	#281	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:50:02	#282	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:50:14	#283	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:52:40	#284	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:57:58	#285	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:58:10	#286	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:58:17	#287	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:58:26	#288	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:58:33	#289	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:58:42	#290	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:59:03	#291	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:59:22	#292	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:59:32	#293	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/22/2020	9:59:45	#294	Lead Paint	9.54	9.54	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	9:59:53	#295	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:00:00	#296	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:00:08	#297	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:00:15	#298	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:00:21	#299	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:00:29	#300	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:02:02	#301	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:02:12	#302	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:02:29	#303	Lead Paint	10.64	10.64	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:02:49	#304	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:02:59	#305	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:03:06	#306	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:03:12	#307	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:03:19	#308	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:03:28	#309	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:03:56	#310	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:04:15	#311	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:04:23	#312	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:04:33	#313	Lead Paint	5.72	5.72	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:04:40	#314	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:04:46	#315	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:04:56	#316	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:05:03	#317	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:05:16	#318	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:05:27	#319	Lead Paint	3.06	3.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:05:38	#320	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:05:54	#321	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	10:06:02	#322	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:13:05	#323	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:13:16	#324	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:13:32	#325	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:13:56	#326	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:14:14	#327	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:14:31	#328	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:14:43	#329	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:15:01	#330	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:15:16	#331	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:15:37	#332	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:15:54	#333	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:16:12	#334	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:16:29	#335	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:16:44	#336	Lead Paint	11.22	11.22	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:17:00	#337	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:17:08	#338	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:17:17	#339	Lead Paint	3.19	3.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:17:40	#340	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:17:57	#341	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:18:15	#342	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:18:24	#343	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:18:33	#344	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:18:59	#345	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:19:06	#346	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:19:21	#347	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:19:29	#348	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:19:48	#349	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:20:00	#350	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:20:20	#351	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/22/2020	12:20:34	#352	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:22:24	#353	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:22:31	#354	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:23:53	#355	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:24:00	#356	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:24:08	#357	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:24:19	#358	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:24:30	#359	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:24:49	#360	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:25:05	#361	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:25:13	#362	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:25:36	#363	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:25:46	#364	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:26:05	#365	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:26:21	#366	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:26:28	#367	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:26:48	#368	Lead Paint	11.12	11.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:27:02	#369	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:27:22	#370	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:27:28	#371	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:27:40	#372	Lead Paint	5.8	5.8	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:27:59	#373	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:28:17	#374	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:28:34	#375	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:28:49	#376	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:29:08	#377	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:29:20	#378	Lead Paint	5.21	5.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:29:38	#379	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:29:45	#380	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:30:00	#381	Lead Paint	10.68	10.68	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:30:15	#382	Lead Paint	10.69	10.69	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:33:25	#383	Lead Paint	3.57	3.57	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:34:39	#384	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:34:51	#385	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:34:59	#386	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:35:09	#387	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:35:18	#388	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:35:29	#389	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:35:46	#390	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:35:57	#391	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:36:10	#392	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:36:27	#393	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:36:42	#394	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:36:58	#395	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:37:14	#396	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:37:33	#397	Lead Paint	11.13	11.13	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:37:51	#398	Lead Paint	10.69	10.69	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:38:06	#399	Lead Paint	10.7	10.7	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:38:15	#400	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:38:41	#401	Lead Paint	3	3	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:38:48	#402	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:39:10	#403	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:39:30	#404	Lead Paint	11.21	11.21	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:39:39	#405	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:39:54	#406	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:40:11	#407	Lead Paint	11.2	11.2	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:40:25	#408	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:40:32	#409	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/22/2020	12:40:47	#410	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:40:57	#411	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:41:04	#412	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:41:20	#413	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:41:35	#414	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:41:46	#415	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:41:59	#416	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:44:17	#417	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:44:25	#418	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:44:36	#419	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:44:49	#420	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:44:58	#421	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:45:13	#422	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:45:24	#423	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:45:39	#424	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:45:54	#425	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:46:10	#426	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:46:28	#427	Lead Paint	11.19	11.19	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:46:36	#428	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:46:55	#429	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:47:13	#430	Lead Paint	11.72	11.72	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:47:34	#431	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:47:48	#432	Lead Paint	3.07	3.07	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:47:58	#433	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:48:19	#434	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:48:26	#435	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:48:43	#436	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:48:59	#437	Lead Paint	11.17	11.17	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:49:09	#438	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:49:35	#439	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:49:50	#440	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:49:57	#441	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:50:10	#442	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:50:18	#443	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/22/2020	12:50:27	#444	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:15:04	#1	Cal Check	14.88	14.88		543396	Delta Profe Rh	%	
6/23/2020	7:19:38	#2	Lead Paint	11.49	11.49	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:19:58	#3	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:20:07	#4	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:20:16	#5	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:20:31	#6	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:20:41	#7	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:20:53	#8	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:21:02	#9	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:21:11	#10	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:21:21	#11	Lead Paint	3.61	3.61	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:21:34	#12	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:22:09	#13	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:22:34	#14	Lead Paint	4.67	4.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:23:17	#15	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:23:27	#16	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:23:35	#17	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:23:43	#18	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:23:50	#19	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:24:05	#20	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:24:13	#21	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:24:23	#22	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:24:30	#23	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/23/2020	7:24:39 #24	Analysis Results		PASS	543396	Delta Profe Rh	%	
6/23/2020	7:24:56 #25	Lead Paint	11.21	11.21 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:25:04 #26	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:25:20 #27	Lead Paint	11.16	11.16 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:25:34 #28	Lead Paint	11.17	11.17 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:26:31 #29	Lead Paint	10.64	10.64 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:26:39 #30	Lead Paint	3.02	3.02 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:26:52 #31	Lead Paint	10.65	10.65 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:27:07 #32	Lead Paint	10.66	10.66 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:27:23 #33	Lead Paint	10.68	10.68 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:27:39 #34	Lead Paint	10.7	10.7 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:27:55 #35	Lead Paint	10.64	10.64 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:28:11 #36	Lead Paint	10.66	10.66 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:28:28 #37	Lead Paint	10.67	10.67 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:28:43 #38	Lead Paint	10.65	10.65 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:29:00 #39	Lead Paint	10.72	10.72 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:29:14 #40	Lead Paint	10.66	10.66 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:29:30 #41	Lead Paint	10.68	10.68 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:29:46 #42	Lead Paint	10.65	10.65 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:30:03 #43	Lead Paint	11.14	11.14 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:30:18 #44	Lead Paint	11.22	11.22 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:30:35 #45	Lead Paint	10.62	10.62 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:30:46 #46	Lead Paint	3.02	3.02 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:32:04 #47	Lead Paint	11.11	11.11 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:32:12 #48	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:32:21 #49	Lead Paint	3.01	3.01 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:32:28 #50	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:32:39 #51	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:32:47 #52	Lead Paint	3.05	3.05 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:33:06 #53	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:33:19 #54	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:33:26 #55	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:33:34 #56	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:33:45 #57	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:34:03 #58	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:34:13 #59	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:34:22 #60	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:34:35 #61	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:34:43 #62	Lead Paint	3.02	3.02 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:34:49 #63	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:34:57 #64	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:35:08 #65	Lead Paint	3.53	3.53 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:35:22 #66	Lead Paint	3.01	3.01 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:35:31 #67	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:35:38 #68	Lead Paint	3.02	3.02 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:35:44 #69	Lead Paint	3.02	3.02 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:35:51 #70	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:36:09 #71	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:36:24 #72	Lead Paint	11.16	11.16 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:36:33 #73	Lead Paint	5.81	5.81 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:36:41 #74	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:36:47 #75	Lead Paint	3.02	3.02 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:37:27 #76	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:37:42 #77	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:37:49 #78	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:37:56 #79	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:38:02 #80	Lead Paint	3.04	3.04 PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:38:08 #81	Lead Paint	3.03	3.03 PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/23/2020	7:38:17 #82	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:38:27 #83	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:38:33 #84	Lead Paint	3.06	3.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:38:43 #85	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:38:52 #86	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:38:58 #87	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:39:04 #88	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:39:16 #89	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:39:24 #90	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:39:31 #91	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:39:39 #92	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:39:49 #93	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:39:56 #94	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:40:03 #95	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:40:23 #96	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:40:52 #97	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:41:21 #98	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:41:30 #99	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:41:47 #100	Lead Paint	11.12	11.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:41:54 #101	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:42:02 #102	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:42:10 #103	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:42:17 #104	Lead Paint	3.1	3.1	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:42:25 #105	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:42:32 #106	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:42:40 #107	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:42:48 #108	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:43:05 #109	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:43:33 #110	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:43:44 #111	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:44:00 #112	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:44:07 #113	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:44:14 #114	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:44:33 #115	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:45:34 #116	Lead Paint	11.14	11.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:46:01 #117	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:46:10 #118	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:46:27 #119	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	7:46:45 #120	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:14:21 #121	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:14:31 #122	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:14:50 #123	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:14:58 #124	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:15:07 #125	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:15:17 #126	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:15:24 #127	Lead Paint	3.54	3.54	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:15:31 #128	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:15:44 #129	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:15:57 #130	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:16:08 #131	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:16:20 #132	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:16:28 #133	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:16:43 #134	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:16:51 #135	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:16:58 #136	Lead Paint	3.12	3.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:17:09 #137	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:17:15 #138	Lead Paint	3.14	3.14	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:17:23 #139	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/23/2020	8:17:32	#140	Lead Paint	3.11	3.11	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:17:41	#141	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:17:53	#142	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:18:03	#143	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:18:16	#144	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:18:25	#145	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:18:33	#146	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:19:01	#147	Lead Paint	10.67	10.67	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:19:24	#148	Lead Paint	10.65	10.65	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:19:38	#149	Lead Paint	10.68	10.68	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:19:55	#150	Lead Paint	11.12	11.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:20:11	#151	Lead Paint	11.15	11.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:20:22	#152	Lead Paint			PASS	543396	Delta Profe Rh	mg/cm2	Insufficient
6/23/2020	8:20:37	#153	Lead Paint	10.63	10.63	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:20:50	#154	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:21:27	#155	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:21:35	#156	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:21:43	#157	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:21:52	#158	Lead Paint	3	3	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:22:00	#159	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:22:11	#160	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:22:19	#161	Lead Paint	3.59	3.59	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:22:30	#162	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:22:38	#163	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:22:45	#164	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:22:58	#165	Lead Paint	7.92	7.92	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:23:07	#166	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:23:28	#167	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:23:43	#168	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:23:50	#169	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:23:58	#170	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:24:35	#171	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:24:51	#172	Lead Paint	10.66	10.66	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:24:59	#173	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:25:09	#174	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:25:17	#175	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:25:25	#176	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:25:48	#177	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:26:02	#178	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:26:16	#179	Lead Paint	11.16	11.16	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:26:26	#180	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:26:32	#181	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:26:41	#182	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:27:16	#183	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:27:31	#184	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:27:38	#185	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:27:47	#186	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:27:56	#187	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:28:22	#188	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:28:30	#189	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:28:38	#190	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:28:44	#191	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:28:52	#192	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:29:03	#193	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:29:10	#194	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:29:19	#195	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:29:28	#196	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:29:36	#197	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/23/2020	8:41:03 #256	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:41:12 #257	Lead Paint	3.06	3.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:41:21 #258	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:41:30 #259	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:41:40 #260	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:41:58 #261	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:42:38 #262	Lead Paint	11.18	11.18	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:42:45 #263	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:42:53 #264	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:43:04 #265	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:43:13 #266	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:43:21 #267	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:43:30 #268	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:43:37 #269	Lead Paint	3	3	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:43:46 #270	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:43:55 #271	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:44:30 #272	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:44:40 #273	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:44:56 #274	Lead Paint	11.12	11.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:45:20 #275	Lead Paint			PASS	543396	Delta Profe Rh	mg/cm2	Insufficient
6/23/2020	8:45:30 #276	Lead Paint	3.56	3.56	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:45:38 #277	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:45:52 #278	Lead Paint	4.15	4.15	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:46:09 #279	Lead Paint	3.6	3.6	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:46:21 #280	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:46:28 #281	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:46:38 #282	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:46:47 #283	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:46:55 #284	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:47:01 #285	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:47:15 #286	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:47:23 #287	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:47:30 #288	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:47:37 #289	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:47:44 #290	Lead Paint	3.12	3.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:56:12 #291	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:56:21 #292	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:56:31 #293	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:56:38 #294	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:56:45 #295	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:56:53 #296	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:57:10 #297	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:57:18 #298	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:57:58 #299	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:58:14 #300	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:58:21 #301	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:58:28 #302	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:58:38 #303	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:58:47 #304	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:58:55 #305	Lead Paint	3.06	3.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:59:03 #306	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:59:10 #307	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:59:17 #308	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:59:24 #309	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	8:59:32 #310	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:00:04 #311	Lead Paint	3.54	3.54	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:00:28 #312	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:00:37 #313	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative

6/23/2020	9:00:46	#314	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:00:55	#315	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:01:03	#316	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:01:26	#317	Lead Paint	3.01	3.01	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:01:33	#318	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:01:40	#319	Lead Paint	3.5	3.5	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:01:53	#320	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:03:21	#321	Lead Paint	11.12	11.12	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:03:58	#322	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:04:06	#323	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:04:15	#324	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:04:22	#325	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:04:29	#326	Lead Paint	3.02	3.02	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:04:48	#327	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:04:55	#328	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:05:24	#329	Lead Paint	3.51	3.51	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:05:33	#330	Lead Paint	3.03	3.03	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:05:48	#331	Lead Paint	3.06	3.06	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:05:58	#332	Lead Paint	3.04	3.04	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:06:07	#333	Lead Paint	3.05	3.05	PASS	543396	Delta Profe Rh	mg/cm2	Negative
6/23/2020	9:06:24	#334	Lead Paint	10.72	10.72	PASS	543396	Delta Profe Rh	mg/cm2	Negative

ATTACHMENT B

Date	Time	Reading	Mode	Elapsed Tir	Elapsed Tir	Elapsed Tir	Elapsed Tir	Pb	Pb +/-	Pass/Fail
6/22/2020	7:28:26	#1	Cal Check	14.89				14.89		
6/22/2020	7:33:33	#2	Lead Paint	10.82				10.82		PASS
6/22/2020	7:34:22	#3	Lead Paint	10.77				10.77		PASS
6/22/2020	7:35:42	#4	Soil	1.96				1.96 ND		PASS
6/22/2020	7:37:08	#5	Cal Check	14.9				14.9		
6/22/2020	7:37:36	#6	Analysis Results							PASS
6/22/2020	7:37:44	#7	Soil	3.6				3.6	546	53 PASS
6/22/2020	7:38:07	#8	Soil	9.97	7.93			17.9	527	17 PASS
6/22/2020	7:38:10	#9	Analysis Results							PASS
6/22/2020	7:38:15	#10	Analysis Results							PASS
6/22/2020	7:38:54	#11	Soil	9.96	9.92	9.95		29.83	905	21 PASS
6/22/2020	7:42:38	#12	Soil	9.95	9.9	9.96		29.8	114	6 PASS
6/22/2020	7:52:00	#13	Analysis Results							PASS
6/22/2020	7:52:45	#14	Soil	9.94	9.88	9.95		29.77	18	3 PASS
6/22/2020	7:55:10	#15	Soil	9.97	9.94	9.98		29.89 ND		PASS
6/22/2020	7:55:54	#16	Soil	9.95	9.9	9.97		29.83	20	4 PASS
6/22/2020	8:04:12	#17	Soil	9.96	9.94	9.93		29.83	202	12 PASS
6/22/2020	8:04:28	#18	Analysis Results							PASS
6/22/2020	8:05:06	#19	Soil	9.94	9.88	9.94		29.76	33	4 PASS
6/22/2020	8:09:32	#20	Analysis Results							PASS
6/22/2020	8:10:07	#21	Soil	9.97	9.92	9.89		29.77	96	8 PASS
6/22/2020	8:10:51	#22	Soil	9.96	9.92	9.97		29.85	86	6 PASS
6/22/2020	8:18:13	#23	Soil	9.94	9.89	9.95		29.78	469	12 PASS
6/22/2020	8:18:54	#24	Soil	9.94	9.87	1.41		21.22	14	3 PASS
6/22/2020	8:24:28	#25	Soil	9.98	9.96			19.95 ND		PASS
6/22/2020	8:27:43	#26	Analysis Results							PASS
6/22/2020	8:28:02	#28	Soil	3.07				3.07	3218	211 PASS
6/22/2020	8:29:35	#29	Soil	9.95	9.92	9.96		29.83	95	6 PASS
6/22/2020	8:36:36	#30	Soil	9.96	9.91	2.59		22.46	1384	26 PASS
6/22/2020	8:38:27	#31	Soil	9.99	9.99	1.43		21.41	151	13 PASS
6/22/2020	8:46:33	#32	Soil	9.96	9.92	1.42		21.3	53	5 PASS
6/22/2020	8:47:09	#33	Soil	9.96	9.92			19.88	27	4 PASS
6/22/2020	8:58:49	#34	Soil	9.96	9.91	1.99		21.86	86	6 PASS
6/22/2020	8:59:21	#35	Soil	9.97	9.93	2.6		22.5	39	5 PASS
6/22/2020	9:16:15	#36	Analysis Results							PASS
6/22/2020	9:16:37	#37	Soil	9.96	4.16			14.12 ND		PASS
6/22/2020	9:17:12	#38	Analysis Results							PASS
6/22/2020	9:17:16	#39	Analysis Results							PASS
6/22/2020	9:17:28	#40	Soil	7.43				7.43	29	8 PASS
6/22/2020	9:17:40	#41	Soil	9.95				9.95 ND		PASS
6/22/2020	9:18:11	#42	Soil	9.97	9.94	1.41		21.32	42	5 PASS
6/22/2020	9:27:40	#43	Soil	9.96	9.92			19.88	127	7 PASS
6/22/2020	9:28:26	#44	Soil	9.95	9.89			19.84	29	4 PASS
6/22/2020	9:42:26	#45	Soil	9.96	9.93	2.64		22.54	1763	34 PASS
6/22/2020	9:42:59	#46	Soil	9.93	9.87	1.41		21.22	79	5 PASS
6/22/2020	9:51:15	#47	Soil	9.95	9.91			19.85	441	13 PASS
6/22/2020	9:51:49	#48	Soil	9.95	9.91			19.86	76	6 PASS
6/22/2020	9:58:41	#49	Soil	9.96	9.91	2.03		21.9	133	8 PASS
6/22/2020	9:59:19	#50	Soil	9.95	9.89	6.24		26.07	30	4 PASS
6/22/2020	10:15:05	#51	Soil	7.07				7.07	45	10 PASS
6/22/2020	10:15:11	#53	Analysis Results							PASS
6/22/2020	10:15:29	#54	Soil	8.47				8.47	20	6 PASS
6/22/2020	10:15:56	#55	Analysis Results							PASS
6/22/2020	10:25:12	#56	Soil	4.74				4.74	94	13 PASS

6/22/2020	10:25:34	#57	Soil	9.94	5.18		15.12	104	8	PASS
6/22/2020	10:26:02	#60	Soil	7.93			7.93	103	10	PASS
6/22/2020	10:26:04	#61	Analysis Results							PASS
6/22/2020	10:26:35	#62	Soil	9.95	9.89	4.41	24.24	105	6	PASS
6/22/2020	10:26:58	#63	Soil	9.95	3.09		13.04	34	7	PASS
6/22/2020	10:35:18	#64	Soil	9.96	9.9	2.6	22.46	72	6	PASS
6/22/2020	10:35:50	#65	Soil	9.94	9.87		19.82	22	3	PASS
6/22/2020	10:55:28	#66	Soil	9.58			9.58	ND		PASS
6/22/2020	10:55:30	#67	Analysis Results							PASS
6/22/2020	10:55:48	#68	Analysis Results							PASS
6/22/2020	10:55:56	#69	Analysis Results							PASS
6/22/2020	10:56:17	#70	Analysis Results							PASS
6/22/2020	10:56:37	#71	Analysis Results							PASS
6/22/2020	10:56:47	#72	Analysis Results							PASS
6/22/2020	10:57:42	#73	Soil	9.95	9.91	2.6	22.46	ND		PASS
6/22/2020	10:57:47	#74	Soil	1.41			1.41	ND		PASS
6/22/2020	10:58:55	#75	Soil	9.96	3.65		13.62	742	38	PASS
6/22/2020	10:59:51	#76	Soil	4.13			4.13	ND		PASS
6/22/2020	11:00:06	#77	Soil	2.54			2.54	48	15	PASS
6/22/2020	11:00:24	#78	Soil	3.62			3.62	54	13	PASS
6/22/2020	11:01:04	#80	Soil	9.94	9.88	3.21	23.02	32	4	PASS
6/22/2020	13:18:06	#81	Soil	1.95			1.95	250	37	PASS
6/22/2020	13:18:39	#82	Soil	9.96	9.91	2.6	22.47	155	8	PASS
6/22/2020	13:19:16	#83	Soil	9.94	9.88		19.82	101	6	PASS
6/22/2020	13:29:41	#84	Soil	9.93	9.87		19.8	87	4	PASS
6/22/2020	13:30:03	#85	Soil	9.97	3.05		13.01	34	9	PASS
6/22/2020	14:06:07	#86	Soil	3.13			3.13	5284	336	PASS
6/22/2020	14:06:10	#87	Analysis Results							PASS
6/22/2020	14:06:14	#88	Analysis Results							PASS
6/22/2020	14:06:27	#90	Soil	2.54			2.54	5370	339	PASS
6/22/2020	14:51:28	#91	Soil					2083	78	PASS
6/22/2020	14:51:29	#92	Analysis Results							PASS
6/22/2020	14:51:34	#93	Analysis Results							PASS
6/22/2020	14:51:36	#94	Analysis Results							PASS
6/22/2020	14:51:43	#95	Analysis Results							PASS
6/22/2020	14:51:45	#96	Analysis Results							PASS
6/22/2020	14:51:51	#97	Analysis Results							PASS
6/22/2020	14:53:12	#98	Soil	9.94	9.89		19.82	1604	25	PASS
6/22/2020	15:06:55	#99	Soil	9.97	9.93	1.41	21.32	259	12	PASS
6/22/2020	15:07:32	#100	Soil	9.95	6.31		16.27	60	6	PASS
6/22/2020	15:18:33	#102	Soil	3.15			3.15	774	64	PASS
6/22/2020	15:19:20	#105	Analysis Results							PASS
6/22/2020	15:20:34	#107	Soil	9.94	9.89	1.99	21.82	768	17	PASS
6/22/2020	15:21:01	#108	Soil	4.74			4.74	496	41	PASS
6/22/2020	15:21:33	#109	Soil	9.97	9.93	1.42	21.31	507	15	PASS
6/22/2020	15:24:49	#110	Soil	9.93	9.89	1.99	21.81	33	4	PASS
6/22/2020	15:25:16	#111	Soil	4.13			4.13	33	10	PASS
6/22/2020	15:25:18	#112	Analysis Results							PASS
6/22/2020	15:25:48	#113	Soil	9.95	9.9		19.86	24	4	PASS
6/22/2020	15:26:21	#114	Soil	9.95	9.9		19.86	119	7	PASS
6/22/2020	15:32:00	#116	Analysis Results							PASS
6/22/2020	15:32:35	#117	Soil	9.96	9.91	4.38	24.25	39	5	PASS
6/22/2020	15:32:47	#118	Soil	2.02			2.02	ND		PASS
6/22/2020	15:32:56	#120	Soil	2.01			2.01	ND		PASS
6/22/2020	15:33:03	#122	Analysis Results							PASS

6/24/2020	7:35:46 #44	Analysis Results			PASS
6/24/2020	7:36:01 #45	Lead Paint	5.79	5.79	PASS
6/24/2020	7:38:18 #47	Lead Paint	2.5	2.5	PASS
6/24/2020	7:38:37 #48	Lead Paint	9.06	9.06	PASS
6/24/2020	7:38:42 #49	Lead Paint	3.07	3.07	PASS
6/24/2020	7:38:58 #50	Lead Paint	9.09	9.09	PASS
6/24/2020	7:39:05 #51	Lead Paint	1.98	1.98	PASS
6/24/2020	7:39:18 #52	Analysis Results			PASS
6/24/2020	7:39:30 #53	Lead Paint	2.54	2.54	PASS
6/24/2020	7:39:46 #54	Lead Paint	10.75	10.75	PASS
6/24/2020	7:40:02 #55	Lead Paint	10.74	10.74	PASS
6/24/2020	7:40:23 #56	Lead Paint	10.74	10.74	PASS
6/24/2020	7:40:37 #57	Lead Paint	2.5	2.5	PASS
6/24/2020	7:40:47 #58	Analysis Results			PASS
6/24/2020	7:40:52 #59	Lead Paint	2.51	2.51	PASS
6/24/2020	7:41:10 #60	Lead Paint	2.48	2.48	PASS
6/24/2020	7:41:30 #61	Lead Paint	2.52	2.52	PASS
6/24/2020	7:41:38 #62	Lead Paint	2.52	2.52	PASS
6/24/2020	7:41:50 #63	Lead Paint	3.07	3.07	PASS
6/24/2020	7:41:57 #64	Lead Paint	5.26	5.26	PASS
6/24/2020	7:42:00 #65	Analysis Results			PASS
6/24/2020	7:42:05 #66	Lead Paint	0.87	0.87	PASS
6/24/2020	7:42:18 #67	Lead Paint	1.96	1.96	PASS
6/24/2020	7:42:28 #68	Lead Paint	2.5	2.5	PASS
6/24/2020	7:44:22 #69	Lead Paint	2.52	2.52	PASS
6/24/2020	7:44:46 #70	Lead Paint	10.14	10.14	PASS
6/24/2020	7:44:51 #71	Analysis Results			PASS
6/24/2020	7:45:30 #72	Lead Paint	2.53	2.53	PASS
6/24/2020	7:45:33 #73	Analysis Results			PASS
6/24/2020	7:45:39 #74	Lead Paint	3.64	3.64	PASS
6/24/2020	7:45:42 #75	Analysis Results			PASS
6/24/2020	7:45:56 #76	Lead Paint	5.8	5.8	PASS
6/24/2020	7:46:07 #77	Lead Paint	4.69	4.69	PASS
6/24/2020	7:46:12 #78	Analysis Results			PASS
6/24/2020	7:46:28 #79	Lead Paint	11.16	11.16	PASS
6/24/2020	7:46:37 #80	Lead Paint	2.52	2.52	PASS
6/24/2020	7:46:44 #81	Lead Paint	4.68	4.68	PASS
6/24/2020	7:46:50 #82	Lead Paint	1.97	1.97	PASS
6/24/2020	7:46:52 #83	Analysis Results			PASS
6/24/2020	7:46:58 #84	Lead Paint	0.87	0.87	PASS
6/24/2020	7:47:02 #85	Analysis Results			PASS
6/24/2020	7:47:05 #86	Analysis Results			PASS
6/24/2020	7:47:07 #87	Analysis Results			PASS
6/24/2020	7:47:14 #88	Lead Paint	2.5	2.5	PASS
6/24/2020	7:47:25 #89	Lead Paint	2.51	2.51	PASS
6/24/2020	7:47:34 #90	Lead Paint	4.11	4.11	PASS
6/24/2020	7:47:39 #91	Analysis Results			PASS
6/24/2020	7:47:41 #92	Analysis Results			PASS
6/24/2020	7:47:44 #93	Analysis Results			PASS
6/24/2020	7:47:52 #94	Lead Paint	4.68	4.68	PASS
6/24/2020	7:47:54 #95	Analysis Results			PASS
6/24/2020	7:48:27 #96	Analysis Results			PASS
6/24/2020	7:48:35 #97	Lead Paint	2.52	2.52	PASS
6/24/2020	7:49:23 #98	Lead Paint	2.52	2.52	PASS
6/24/2020	7:50:21 #99	Lead Paint	3.08	3.08	PASS

6/24/2020	7:50:29 #100	Lead Paint	2.53	2.53	PASS
6/24/2020	7:51:00 #101	Analysis Results			PASS
6/24/2020	7:51:15 #103	Analysis Results			PASS
6/24/2020	7:51:19 #104	Lead Paint	2.51	2.51	PASS
6/24/2020	7:51:31 #105	Analysis Results			PASS
6/24/2020	7:51:38 #106	Lead Paint	2.52	2.52	PASS
6/24/2020	7:51:57 #107	Analysis Results			PASS
6/24/2020	7:52:19 #109	Lead Paint	1.95	1.95	PASS
6/24/2020	7:52:25 #110	Lead Paint	2.52	2.52	PASS
6/24/2020	7:52:48 #111	Lead Paint	2.52	2.52	PASS
6/24/2020	7:53:09 #112	Lead Paint	2.53	2.53	PASS
6/24/2020	7:53:30 #113	Lead Paint	1.98	1.98	PASS
6/24/2020	7:53:39 #114	Lead Paint	0.88	0.88	PASS
6/24/2020	7:53:41 #115	Analysis Results			PASS
6/24/2020	7:53:50 #116	Lead Paint	2.51	2.51	PASS
6/24/2020	7:53:58 #117	Lead Paint	2.5	2.5	PASS
6/24/2020	7:54:09 #118	Lead Paint	2.53	2.53	PASS
6/24/2020	7:54:21 #119	Analysis Results			PASS
6/24/2020	7:54:26 #120	Lead Paint	1.97	1.97	PASS
6/24/2020	7:57:20 #121	Analysis Results			PASS
6/24/2020	7:57:40 #123	Analysis Results			PASS
6/24/2020	7:58:20 #124	Lead Paint	2.51	2.51	PASS
6/24/2020	7:58:28 #125	Lead Paint	2.52	2.52	PASS
6/24/2020	7:58:42 #127	Analysis Results			PASS
6/24/2020	7:58:52 #128	Lead Paint	1.42	1.42	PASS
6/24/2020	7:59:05 #129	Lead Paint	2.52	2.52	PASS
6/24/2020	7:59:13 #130	Lead Paint	2.53	2.53	PASS
6/24/2020	7:59:18 #131	Lead Paint	1.96	1.96	PASS
6/24/2020	7:59:25 #132	Lead Paint	2.52	2.52	PASS
6/24/2020	7:59:31 #133	Lead Paint	2.51	2.51	PASS
6/24/2020	7:59:39 #134	Lead Paint	2.54	2.54	PASS
6/24/2020	7:59:58 #135	Lead Paint	1.43	1.43	PASS
6/24/2020	8:00:11 #136	Lead Paint	2.51	2.51	PASS
6/24/2020	8:00:20 #137	Lead Paint	1.43	1.43	PASS
6/24/2020	8:00:29 #138	Lead Paint	3.62	3.62	PASS
6/24/2020	8:00:37 #139	Lead Paint	1.96	1.96	PASS
6/24/2020	8:00:57 #140	Lead Paint	1.95	1.95	PASS
6/24/2020	8:01:06 #141	Lead Paint	2.5	2.5	PASS
6/24/2020	8:01:09 #142	Analysis Results			PASS
6/24/2020	8:01:15 #143	Lead Paint	2.52	2.52	PASS
6/24/2020	8:01:20 #144	Analysis Results			PASS
6/24/2020	8:01:34 #145	Lead Paint	2.51	2.51	PASS
6/24/2020	8:02:50 #147	Analysis Results			PASS
6/24/2020	8:24:29 #148	Lead Paint	0.35	0.35	PASS
6/24/2020	8:25:32 #149	Lead Paint	2.5	2.5	PASS
6/24/2020	8:25:44 #150	Lead Paint	2.52	2.52	PASS
6/24/2020	8:26:06 #151	Lead Paint	1.97	1.97	PASS
6/24/2020	8:26:13 #152	Lead Paint	3.03	3.03	PASS
6/24/2020	8:26:20 #153	Lead Paint	1.42	1.42	PASS
6/24/2020	8:28:00 #154	Lead Paint	2.46	2.46	PASS
6/24/2020	8:28:08 #155	Lead Paint	2.52	2.52	PASS
6/24/2020	8:28:14 #156	Lead Paint	2.51	2.51	PASS
6/24/2020	8:28:22 #157	Lead Paint	2.52	2.52	PASS
6/24/2020	8:28:28 #158	Lead Paint	2.5	2.5	PASS
6/24/2020	8:28:36 #159	Lead Paint	2.54	2.54	PASS

6/24/2020	8:29:24 #160	Lead Paint	5.81	5.81		PASS
6/24/2020	8:29:38 #161	Lead Paint	5.8	5.8		PASS
6/24/2020	8:30:21 #162	Lead Paint	2.53	2.53		PASS
6/24/2020	8:30:31 #163	Lead Paint	2.51	2.51		PASS
6/24/2020	8:30:36 #164	Lead Paint	0.33	0.33		PASS
6/24/2020	8:31:04 #165	Analysis Results				PASS
6/24/2020	8:31:14 #166	Lead Paint	5.25	5.25		PASS
6/24/2020	8:31:30 #167	Lead Paint	0.33	0.33		PASS
6/24/2020	8:31:45 #168	Lead Paint	2.52	2.52		PASS
6/24/2020	8:31:54 #169	Lead Paint	2.51	2.51		PASS
6/24/2020	8:32:01 #170	Lead Paint	1.97	1.97		PASS
6/24/2020	8:32:12 #171	Lead Paint	3.61	3.61		PASS
6/24/2020	8:32:30 #175	Lead Paint	1.44	1.44		PASS
6/24/2020	8:32:37 #176	Lead Paint	1.43	1.43		PASS
6/24/2020	8:32:42 #177	Lead Paint	0.33	0.33		PASS
6/24/2020	8:32:48 #178	Analysis Results				PASS
6/24/2020	8:32:57 #179	Lead Paint	2.52	2.52		PASS
6/24/2020	8:33:11 #180	Lead Paint	2.52	2.52		PASS
6/24/2020	8:33:21 #182	Lead Paint	2.52	2.52		PASS
6/24/2020	8:33:30 #183	Lead Paint	2.53	2.53		PASS
6/24/2020	8:33:51 #185	Lead Paint	2.49	2.49		PASS
6/24/2020	8:34:01 #186	Analysis Results				PASS
6/24/2020	8:34:06 #187	Lead Paint	2.52	2.52		PASS
6/24/2020	8:34:12 #188	Analysis Results				PASS
6/24/2020	8:34:18 #189	Lead Paint	2.51	2.51		PASS
6/24/2020	8:34:35 #191	Lead Paint	2.51	2.51		PASS
6/24/2020	8:34:41 #192	Analysis Results				PASS
6/24/2020	8:34:44 #193	Analysis Results				PASS
6/24/2020	8:35:37 #194	Lead Paint	1.43	1.43		PASS
6/24/2020	8:35:42 #196	Analysis Results				PASS
6/24/2020	8:35:45 #197	Analysis Results				PASS
6/24/2020	8:36:02 #199	Analysis Results				PASS
6/24/2020	8:36:16 #200	Lead Paint				PASS
6/24/2020	8:36:35 #201	Lead Paint	10.71	10.71		PASS
6/24/2020	8:36:56 #202	Lead Paint	3.09	3.09		PASS
6/24/2020	8:37:00 #203	Analysis Results				PASS
6/24/2020	8:37:05 #204	Lead Paint	1.44	1.44		PASS
6/24/2020	8:37:31 #206	Analysis Results				PASS
6/24/2020	8:37:40 #207	Lead Paint	0.33	0.33		PASS
6/24/2020	8:37:53 #209	Lead Paint	7.37	7.37		PASS
6/24/2020	8:37:55 #210	Lead Paint	0.35	0.35		PASS
6/24/2020	8:38:16 #211	Lead Paint	11.14	11.14		PASS
6/24/2020	8:38:47 #212	Lead Paint	0.88	0.88		PASS
6/24/2020	8:38:59 #213	Lead Paint	2.5	2.5		PASS
6/24/2020	8:39:07 #215	Lead Paint	1.43	1.43		PASS
6/24/2020	8:39:16 #216	Lead Paint	3.61	3.61		PASS
6/24/2020	8:39:30 #217	Lead Paint	11.17	11.17		PASS
6/24/2020	8:39:39 #218	Lead Paint	4.12	4.12		PASS
6/24/2020	8:39:54 #219	Analysis Results				PASS
6/24/2020	8:39:59 #220	Lead Paint	1.42	1.42		PASS
6/24/2020	10:47:28 #221	Analysis Results				PASS
6/24/2020	10:47:32 #222	Analysis Results				PASS
6/24/2020	10:47:39 #223	Soil	3.51	3.51	518	68 PASS
6/24/2020	10:48:24 #224	Analysis Results				PASS
6/24/2020	10:48:30 #225	Analysis Results				PASS

6/24/2020	10:48:44	#226	Analysis Results					PASS
6/24/2020	10:48:48	#227	Analysis Results					PASS
6/24/2020	10:49:06	#228	Analysis Results					PASS
6/24/2020	10:49:24	#229	Analysis Results					PASS
6/24/2020	10:49:27	#230	Analysis Results					PASS
6/24/2020	10:49:38	#232	Analysis Results					PASS
6/24/2020	10:49:41	#233	Analysis Results					PASS
6/24/2020	10:49:47	#235	Analysis Results					PASS
6/24/2020	11:00:10	#236	Analysis Results					PASS
6/24/2020	11:00:16	#237	Soil	2.55	2.55	72	15	PASS
6/24/2020	11:01:22	#238	Analysis Results					PASS
6/24/2020	11:01:40	#241	Analysis Results					PASS
6/24/2020	11:02:05	#243	Soil	1.42	1.42	153	28	PASS
6/24/2020	11:04:05	#246	Soil	2.03	2.03	ND		PASS
6/24/2020	11:05:38	#247	Soil	1.41	1.41	ND		PASS
6/24/2020	11:06:05	#248	Analysis Results					PASS
6/24/2020	11:06:15	#249	Analysis Results					PASS
6/24/2020	11:06:24	#250	Analysis Results					PASS
6/24/2020	11:06:32	#252	Analysis Results					PASS
6/24/2020	11:06:47	#253	Soil	1.41	1.41	ND		PASS
6/24/2020	11:08:21	#254	Soil	2.04	2.04	103	22	PASS
6/24/2020	11:08:42	#255	Analysis Results					PASS
6/24/2020	11:08:45	#256	Analysis Results					PASS
6/24/2020	11:08:50	#258	Analysis Results					PASS
6/24/2020	11:09:00	#259	Analysis Results					PASS
6/24/2020	11:09:05	#260	Analysis Results					PASS
6/24/2020	11:09:22	#262	Analysis Results					PASS
6/24/2020	11:09:25	#263	Analysis Results					PASS
6/24/2020	11:09:54	#265	Analysis Results					PASS
6/24/2020	11:10:13	#267	Analysis Results					PASS
6/24/2020	11:10:21	#268	Soil	2	2	312	46	PASS
6/24/2020	11:10:25	#269	Analysis Results					PASS
6/24/2020	11:10:41	#271	Soil	4.19	4.19	425	35	PASS
6/24/2020	11:10:51	#273	Analysis Results					PASS
6/24/2020	11:10:55	#274	Analysis Results					PASS
6/24/2020	11:11:00	#275	Soil	2.04	2.04	ND		PASS
6/24/2020	11:11:20	#276	Soil	2.03	2.03	214	31	PASS
6/24/2020	11:14:00	#277	Soil	1.41	1.41	ND		PASS
6/24/2020	11:14:36	#278	Analysis Results					PASS
6/24/2020	11:14:40	#279	Soil	1.4	1.4	ND		PASS
6/24/2020	11:15:17	#280	Soil	1.99	1.99	ND		PASS
6/24/2020	11:15:48	#282	Analysis Results					PASS
6/24/2020	11:15:56	#283	Analysis Results					PASS
6/24/2020	11:16:07	#284	Analysis Results					PASS
6/24/2020	11:16:18	#285	Analysis Results					PASS
6/24/2020	11:16:21	#286	Analysis Results					PASS
6/24/2020	11:16:24	#287	Analysis Results					PASS
6/24/2020	11:16:36	#288	Analysis Results					PASS
6/24/2020	11:16:38	#289	Analysis Results					PASS
6/24/2020	11:16:54	#290	Analysis Results					PASS
6/24/2020	11:17:04	#292	Soil	2.02	2.02	ND		PASS
6/24/2020	11:17:45	#293	Analysis Results					PASS
6/24/2020	11:17:58	#294	Analysis Results					PASS
6/24/2020	11:18:03	#295	Analysis Results					PASS
6/24/2020	11:18:11	#296	Soil	1.41	1.41	ND		PASS

6/24/2020	11:25:39	#297	Soil	1.93	1.93	ND			PASS
6/24/2020	11:26:10	#299	Soil	1.95	1.95		172	29	PASS
6/24/2020	11:26:54	#301	Analysis Results						PASS
6/24/2020	11:27:12	#304	Analysis Results						PASS
6/24/2020	11:27:23	#305	Analysis Results						PASS
6/24/2020	11:27:38	#307	Analysis Results						PASS
6/24/2020	11:27:46	#308	Analysis Results						PASS
6/24/2020	11:28:08	#310	Soil	1.42	1.42		201	35	PASS
6/24/2020	11:29:19	#312	Analysis Results						PASS
6/24/2020	11:29:27	#314	Analysis Results						PASS
6/24/2020	11:29:49	#316	Analysis Results						PASS
6/24/2020	11:29:52	#317	Analysis Results						PASS
6/24/2020	11:30:11	#319	Analysis Results						PASS
6/24/2020	11:30:20	#320	Analysis Results						PASS
6/24/2020	11:30:27	#321	Soil	2.53	2.53	ND			PASS
6/24/2020	11:30:51	#322	Analysis Results						PASS
6/24/2020	11:30:53	#323	Analysis Results						PASS
6/24/2020	11:31:01	#324	Analysis Results						PASS
6/24/2020	11:31:04	#325	Soil	1.41	1.41	ND			PASS
6/24/2020	11:31:16	#326	Analysis Results						PASS
6/24/2020	11:31:18	#327	Analysis Results						PASS
6/24/2020	11:31:21	#328	Analysis Results						PASS
6/24/2020	11:31:23	#329	Analysis Results						PASS
6/24/2020	11:31:30	#330	Analysis Results						PASS
6/24/2020	11:31:39	#332	Analysis Results						PASS
6/24/2020	11:32:02	#334	Soil	1.41	1.41	ND			PASS
6/24/2020	11:34:25	#336	Analysis Results						PASS
6/24/2020	11:34:27	#337	Analysis Results						PASS
6/24/2020	11:34:41	#338	Analysis Results						PASS
6/24/2020	11:34:46	#339	Analysis Results						PASS
6/24/2020	11:35:09	#340	Soil	1.43	1.43	ND			PASS
6/24/2020	11:35:31	#341	Analysis Results						PASS
6/24/2020	11:35:35	#342	Analysis Results						PASS
6/24/2020	11:35:39	#343	Analysis Results						PASS
6/24/2020	11:36:04	#344	Analysis Results						PASS
6/24/2020	11:36:24	#346	Analysis Results						PASS
6/24/2020	11:36:56	#347	Analysis Results						PASS
6/24/2020	11:36:59	#348	Analysis Results						PASS
6/24/2020	11:37:17	#349	Analysis Results						PASS
6/24/2020	11:37:26	#350	Analysis Results						PASS
6/24/2020	11:37:31	#352	Analysis Results						PASS
6/24/2020	11:37:44	#353	Analysis Results						PASS
6/24/2020	11:37:52	#354	Analysis Results						PASS
6/24/2020	11:37:55	#355	Analysis Results						PASS
6/24/2020	11:37:59	#356	Analysis Results						PASS
6/24/2020	11:38:08	#357	Analysis Results						PASS
6/24/2020	11:38:15	#358	Analysis Results						PASS
6/24/2020	11:38:21	#359	Soil	2.02	2.02	ND			PASS
6/24/2020	11:43:40	#360	Analysis Results						PASS
6/24/2020	11:43:44	#361	Analysis Results						PASS
6/24/2020	11:44:14	#363	Analysis Results						PASS
6/24/2020	11:44:43	#367	Analysis Results						PASS
6/24/2020	11:44:50	#368	Soil	2.01	2.01		67	18	PASS
6/24/2020	11:54:02	#369	Analysis Results						PASS
6/24/2020	11:54:17	#371	Analysis Results						PASS

6/24/2020	11:54:28	#372	Analysis Results					PASS
6/24/2020	11:54:33	#373	Analysis Results					PASS
6/24/2020	11:54:58	#375	Analysis Results					PASS
6/24/2020	11:55:08	#376	Analysis Results					PASS
6/24/2020	11:55:12	#377	Analysis Results					PASS
6/24/2020	11:55:20	#378	Analysis Results					PASS
6/24/2020	11:55:21	#379	Analysis Results					PASS
6/24/2020	11:55:25	#380	Analysis Results					PASS
6/24/2020	11:55:39	#381	Analysis Results					PASS
6/24/2020	11:55:49	#382	Analysis Results					PASS
6/24/2020	11:55:54	#383	Analysis Results					PASS
6/24/2020	11:55:58	#384	Analysis Results					PASS
6/24/2020	11:56:16	#385	Soil	1.42	1.42	76	22	PASS
6/24/2020	11:56:41	#386	Analysis Results					PASS
6/24/2020	11:56:53	#387	Analysis Results					PASS
6/24/2020	11:56:58	#388	Analysis Results					PASS
6/24/2020	11:57:11	#390	Analysis Results					PASS
6/24/2020	11:57:28	#392	Analysis Results					PASS
6/24/2020	11:57:39	#393	Analysis Results					PASS
6/24/2020	11:57:43	#394	Analysis Results					PASS
6/24/2020	11:57:48	#395	Analysis Results					PASS
6/24/2020	11:57:50	#396	Analysis Results					PASS
6/24/2020	11:58:07	#397	Soil	1.41	1.41	ND		PASS
6/24/2020	11:58:28	#400	Soil	3.04	3.04	ND		PASS
6/24/2020	11:58:33	#401	Analysis Results					PASS
6/24/2020	11:58:36	#402	Analysis Results					PASS
6/24/2020	11:58:47	#404	Soil	2.56	2.56	ND		PASS
6/24/2020	12:06:30	#405	Analysis Results					PASS
6/24/2020	12:06:50	#406	Lead Paint	2.34	2.34			PASS
6/24/2020	12:06:55	#407	Analysis Results					PASS
6/24/2020	12:06:59	#408	Lead Paint	1.42	1.42			PASS
6/24/2020	12:07:07	#409	Lead Paint	0.33	0.33			PASS
6/24/2020	12:07:16	#410	Analysis Results					PASS
6/24/2020	12:07:21	#411	Analysis Results					PASS
6/24/2020	12:07:31	#412	Lead Paint	2.5	2.5			PASS
6/24/2020	12:07:36	#413	Analysis Results					PASS
6/24/2020	12:07:45	#414	Analysis Results					PASS
6/24/2020	12:07:54	#416	Analysis Results					PASS
6/24/2020	12:07:58	#417	Analysis Results					PASS
6/24/2020	12:08:06	#418	Analysis Results					PASS
6/24/2020	12:08:18	#419	Lead Paint	3.06	3.06			PASS
6/24/2020	12:08:21	#420	Analysis Results					PASS
6/24/2020	12:08:29	#421	Lead Paint	2.53	2.53			PASS
6/24/2020	12:08:32	#422	Analysis Results					PASS
6/24/2020	12:08:37	#423	Lead Paint	2.53	2.53			PASS
6/24/2020	12:08:42	#424	Lead Paint	1.43	1.43			PASS
6/24/2020	12:08:49	#426	Lead Paint	1.96	1.96			PASS
6/24/2020	12:08:55	#427	Lead Paint	2.51	2.51			PASS
6/24/2020	12:09:07	#428	Lead Paint	3.62	3.62			PASS
6/24/2020	12:09:17	#429	Lead Paint	5.81	5.81			PASS
6/24/2020	12:09:21	#430	Lead Paint	0.33	0.33			PASS
6/24/2020	12:09:24	#431	Analysis Results					PASS
6/24/2020	12:09:34	#432	Lead Paint	7.44	7.44			PASS
6/24/2020	12:09:48	#433	Analysis Results					PASS
6/24/2020	12:09:51	#434	Analysis Results					PASS

6/24/2020	12:09:55	#435	Lead Paint	0.87	0.87			PASS
6/24/2020	12:10:09	#436	Lead Paint	11.25	11.25			PASS
6/24/2020	12:28:26	#438	Analysis Results					PASS
6/24/2020	12:28:32	#439	Analysis Results					PASS
6/24/2020	12:28:41	#440	Soil	3.48	3.48	48	16	PASS
6/24/2020	12:28:57	#441	Analysis Results					PASS
6/24/2020	12:29:05	#442	Soil	4.71	4.71	ND		PASS
6/24/2020	12:33:31	#443	Soil	2	2	ND		PASS
6/24/2020	12:33:45	#444	Analysis Results					PASS
6/24/2020	12:33:51	#445	Analysis Results					PASS
6/24/2020	12:33:53	#446	Analysis Results					PASS
6/24/2020	12:34:03	#448	Analysis Results					PASS
6/24/2020	12:34:10	#449	Analysis Results					PASS
6/24/2020	12:34:27	#450	Analysis Results					PASS
6/24/2020	12:34:32	#451	Analysis Results					PASS
6/24/2020	12:34:34	#452	Analysis Results					PASS
6/24/2020	12:34:38	#453	Analysis Results					PASS
6/24/2020	12:34:41	#454	Analysis Results					PASS
6/24/2020	12:34:45	#455	Analysis Results					PASS
6/24/2020	12:34:50	#456	Analysis Results					PASS
6/24/2020	12:34:55	#457	Analysis Results					PASS
6/24/2020	12:35:02	#458	Analysis Results					PASS
6/24/2020	12:35:07	#459	Analysis Results					PASS
6/24/2020	12:35:16	#460	Analysis Results					PASS
6/24/2020	12:35:20	#461	Analysis Results					PASS
6/24/2020	12:35:29	#462	Analysis Results					PASS
6/24/2020	12:35:35	#463	Analysis Results					PASS
6/24/2020	12:35:45	#464	Soil	2.01	2.01	ND		PASS
6/24/2020	12:36:15	#466	Analysis Results					PASS
6/24/2020	12:36:18	#467	Analysis Results					PASS
6/24/2020	12:36:21	#468	Analysis Results					PASS
6/24/2020	12:36:24	#469	Analysis Results					PASS
6/24/2020	12:36:28	#470	Analysis Results					PASS
6/24/2020	12:36:31	#471	Analysis Results					PASS
6/24/2020	12:36:37	#472	Analysis Results					PASS
6/24/2020	12:36:41	#473	Analysis Results					PASS
6/24/2020	12:36:49	#474	Analysis Results					PASS
6/24/2020	12:36:54	#475	Analysis Results					PASS
6/24/2020	12:36:57	#476	Analysis Results					PASS
6/24/2020	12:37:03	#477	Soil	1.96	1.96	ND		PASS
6/24/2020	12:42:08	#478	Analysis Results					PASS
6/24/2020	12:42:13	#479	Analysis Results					PASS
6/24/2020	12:42:25	#480	Analysis Results					PASS
6/24/2020	12:42:31	#481	Analysis Results					PASS
6/24/2020	12:42:38	#482	Analysis Results					PASS
6/24/2020	12:42:41	#483	Analysis Results					PASS
6/24/2020	12:42:52	#486	Analysis Results					PASS
6/24/2020	12:42:55	#487	Analysis Results					PASS
6/24/2020	12:43:03	#488	Analysis Results					PASS
6/24/2020	12:43:10	#489	Analysis Results					PASS
6/24/2020	12:43:14	#490	Analysis Results					PASS
6/24/2020	12:43:21	#492	Soil	1.42	1.42	ND		PASS
6/24/2020	12:43:50	#493	Analysis Results					PASS
6/24/2020	12:43:57	#494	Analysis Results					PASS
6/24/2020	12:44:09	#496	Analysis Results					PASS

6/24/2020	12:44:13	#497	Analysis Results					PASS
6/24/2020	12:44:19	#499	Analysis Results					PASS
6/24/2020	12:44:22	#500	Analysis Results					PASS
6/24/2020	12:44:26	#501	Analysis Results					PASS
6/24/2020	12:44:34	#502	Soil	1.41	1.41	ND		PASS
6/24/2020	12:56:03	#503	Analysis Results					PASS
6/24/2020	12:56:08	#504	Analysis Results					PASS
6/24/2020	12:56:17	#506	Analysis Results					PASS
6/24/2020	12:56:20	#507	Analysis Results					PASS
6/24/2020	12:56:28	#508	Soil	1.42	1.42	968	98	PASS
6/24/2020	12:56:57	#509	Soil	2.04	2.04	272	30	PASS
6/24/2020	12:57:47	#510	Analysis Results					PASS
6/24/2020	12:57:55	#512	Analysis Results					PASS
6/24/2020	12:57:59	#513	Analysis Results					PASS
6/24/2020	12:58:02	#514	Analysis Results					PASS
6/24/2020	12:58:16	#516	Analysis Results					PASS
6/24/2020	12:58:18	#517	Analysis Results					PASS
6/24/2020	12:58:23	#518	Soil	1.41	1.41	114	25	PASS
6/24/2020	13:01:52	#519	Analysis Results					PASS
6/24/2020	13:02:05	#522	Analysis Results					PASS
6/24/2020	13:07:30	#524	Analysis Results					PASS
6/24/2020	13:07:38	#525	Analysis Results					PASS
6/24/2020	13:07:45	#526	Analysis Results					PASS
6/24/2020	13:07:51	#528	Analysis Results					PASS
6/24/2020	13:07:57	#530	Analysis Results					PASS
6/24/2020	13:08:02	#531	Analysis Results					PASS
6/24/2020	13:08:06	#532	Analysis Results					PASS
6/24/2020	13:08:13	#533	Analysis Results					PASS
6/24/2020	13:08:32	#535	Analysis Results					PASS
6/24/2020	13:08:36	#536	Analysis Results					PASS
6/24/2020	13:08:50	#537	Analysis Results					PASS
6/24/2020	13:10:51	#541	Analysis Results					PASS
6/24/2020	13:11:05	#543	Soil	4.2	4.2	734	58	PASS
6/24/2020	13:12:01	#544	Analysis Results					PASS
6/24/2020	13:12:15	#546	Analysis Results					PASS
6/24/2020	13:12:21	#547	Analysis Results					PASS
6/24/2020	13:12:27	#548	Soil	2.03	2.03	118	21	PASS
6/24/2020	13:12:55	#549	Analysis Results					PASS
6/24/2020	13:13:03	#550	Analysis Results					PASS
6/24/2020	13:13:05	#551	Analysis Results					PASS
6/24/2020	13:13:09	#552	Analysis Results					PASS
6/24/2020	13:13:15	#553	Analysis Results					PASS
6/24/2020	13:13:23	#554	Soil	1.42	1.42	ND		PASS
6/24/2020	13:13:50	#555	Analysis Results					PASS
6/24/2020	13:13:55	#556	Analysis Results					PASS
6/24/2020	13:13:59	#557	Analysis Results					PASS
6/24/2020	13:14:04	#558	Soil	1.4	1.4	ND		PASS
6/24/2020	13:14:31	#559	Analysis Results					PASS
6/24/2020	13:14:40	#561	Soil	1.42	1.42	ND		PASS
6/24/2020	13:23:36	#562	Analysis Results					PASS
6/24/2020	13:23:46	#563	Soil	2.04	2.04	1631	123	PASS
6/24/2020	13:24:24	#564	Analysis Results					PASS
6/24/2020	13:24:34	#566	Soil	2.01	2.01	2597	181	PASS
6/24/2020	13:25:04	#567	Analysis Results					PASS
6/24/2020	13:25:14	#569	Analysis Results					PASS

6/24/2020	13:25:17	#570	Analysis Results					PASS
6/24/2020	13:25:22	#571	Analysis Results					PASS
6/24/2020	13:25:25	#572	Analysis Results					PASS
6/24/2020	13:25:50	#574	Analysis Results					PASS
6/24/2020	13:25:56	#575	Soil	2.06	2.06	535	54	PASS
6/24/2020	13:29:19	#577	Analysis Results					PASS
6/24/2020	13:29:29	#578	Analysis Results					PASS
6/24/2020	13:29:39	#579	Analysis Results					PASS
6/24/2020	13:29:41	#580	Analysis Results					PASS
6/24/2020	13:29:54	#581	Soil	1.41	1.41	ND		PASS
6/24/2020	13:32:25	#583	Soil	1.4	1.4	ND		PASS
6/24/2020	13:32:45	#585	Analysis Results					PASS
6/24/2020	13:32:54	#587	Analysis Results					PASS
6/24/2020	13:32:59	#588	Soil	2.01	2.01	123	26	PASS
6/24/2020	13:37:41	#589	Soil	2.58	2.58	ND		PASS
6/24/2020	13:38:10	#590	Analysis Results					PASS
6/24/2020	13:38:18	#591	Soil	2.02	2.02	75	19	PASS
6/24/2020	13:38:47	#592	Analysis Results					PASS
6/24/2020	13:39:06	#594	Analysis Results					PASS
6/24/2020	13:39:10	#595	Analysis Results					PASS
6/24/2020	13:39:16	#596	Soil			ND		PASS
6/24/2020	13:40:15	#597	Analysis Results					PASS
6/24/2020	13:40:28	#599	Analysis Results					PASS
6/24/2020	13:40:33	#600	Analysis Results					PASS
6/24/2020	13:40:54	#602	Analysis Results					PASS
6/24/2020	13:40:57	#603	Analysis Results					PASS
6/24/2020	13:41:44	#604	Analysis Results					PASS
6/24/2020	13:41:56	#605	Analysis Results					PASS
6/24/2020	13:42:00	#606	Analysis Results					PASS
6/24/2020	13:42:09	#608	Soil	1.43	1.43	172	30	PASS
6/24/2020	13:48:46	#609	Analysis Results					PASS
6/24/2020	13:49:01	#611	Soil	2.49	2.49	ND		PASS
6/24/2020	13:49:27	#612	Analysis Results					PASS
6/24/2020	13:49:31	#613	Analysis Results					PASS
6/24/2020	13:49:34	#614	Analysis Results					PASS
6/24/2020	13:49:36	#615	Analysis Results					PASS
6/24/2020	13:49:51	#617	Soil	3.1	3.1	32	10	PASS
6/24/2020	13:50:37	#618	Soil	2.5	2.5	ND		PASS
6/24/2020	13:50:51	#619	Analysis Results					PASS
6/24/2020	13:50:53	#620	Analysis Results					PASS
6/24/2020	13:51:10	#621	Analysis Results					PASS
6/24/2020	13:59:28	#622	Soil	1.39	1.39	99	33	PASS
6/24/2020	14:00:04	#623	Analysis Results					PASS
6/24/2020	14:00:11	#624	Analysis Results					PASS
6/24/2020	14:00:20	#625	Analysis Results					PASS
6/24/2020	14:00:32	#626	Soil	8.37	8.37	37	11	PASS
6/24/2020	14:07:34	#628	Analysis Results					PASS
6/24/2020	14:07:42	#629	Soil	2.57	2.57	ND		PASS
6/24/2020	14:08:01	#630	Soil	4.18	4.18	ND		PASS
6/25/2020	12:23:19	#1	Cal Check	14.88	14.88			
6/25/2020	12:55:21	#2	Cal Check	14.91	14.91			



**FIELD ENVIRONMENTAL
INSTRUMENTS, INC.**

**Congratulations on successfully completing
FEI's Radiation Safety Training**

Radiation Safety Training | Certificate of Completion

This certifies that

**Rucha Ragalwar
Of
Cosmos Technologies**

*Successfully completed the FEI Innov-X Systems
Radiation Safety Tutorial for field portable X-Ray
Fluorescence Spectrum Analyzers.*

**Training Presented by:
Mike Waltman
FEI Radiation Safety Officer**

Completion date: 3/2020