

## Housing Authority of the City of Pittsburgh

Contracting Officer
412 Boulevard of the Allies, 6<sup>th</sup> Floor
Pittsburgh, PA 15219
(412) 456-5116
www.hacp.org

## March 11, 2025

## **Quote Request – Arlington Heights Glass Block Removal and Replacement** (Revised)

## ADDENDUM NO. 3

This addendum issued March 11, 2025, becomes in its entirety a part of the Quote Request as is fully set forth herein:

- Item 1: This revised addendum replaced the original in its entirety.
- Item 2: Q: The information that was relayed in your specs for the glass block What you have there now is a Pittsburgh Corning VUE pattern and a Pittsburgh Corning LX pattern stripe to obscure the landings. That's not important to us since we know what it is. What is important is this going to require a 45, 60 or 90 Fire rating opening since this is an escape stairwell? I didn't see that in the information.
- A: The proposals requested in this procurement are part of the agency's maintenance plan; therefore, this project is classified as a maintenance project. The contractor shall replace only broken or damaged glass blocks in each one of the stairwells with those that are equal to or similar to the existing blocks. The existing glass blocks are not marked or identified as fire-rated.
- Item 3: The due date, time and location remain unchanged at March 18, 2025 at 10:00 a.m. Bids should be emailed to kathleen.obringer@hacp.org

**END OF ADDENDUM NO. 3** 

Mr. Brandon Havranek

Associate Director of Procurement/Contracting Officer

03/11/2025

Date